

BIARRITZ AP, France

WMO: 076020

Lat: 43.4694N

Lon: 1.5344W

Elev: 75

StdP: 100.43

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-2.0	-0.4	-5.5	2.4	0.9	-3.6	2.8	2.2	12.6	9.8	11.2	10.1	2.4	100	0.442

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.7	31.0	21.9	28.5	20.6	26.2	19.8	23.0	28.0	22.0	26.3	21.1	24.7	3.9	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.5	16.3	25.2	20.6	15.4	23.9	19.9	14.7	23.1	68.3	28.1	64.5	26.4	61.5	24.8	28.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.8	8.2	7.0	-4.6	36.1	1.8	2.0	-5.9	37.5	-6.9	38.7	-7.9	39.8	-9.2	41.2		
(5)			-5.1	25.4	1.8	1.0	-6.5	26.1	-7.6	26.7	-8.6	27.2	-9.9	27.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	14.3	8.5	8.7	11.0	12.5	15.4	18.5	20.3	20.8	18.5	16.2	11.2	9.1		
	DBStd	5.55	3.84	3.82	3.46	3.06	3.11	3.20	2.56	2.59	3.00	3.60	3.69	4.19		
	HDD10.0	272	74	62	28	8	1	0	0	0	0	3	29	66		
	HDD18.3	1747	306	270	227	176	101	35	8	5	33	84	216	286		
	CDD10.0	1826	26	26	60	85	168	255	319	334	254	195	65	39		
	CDD18.3	259	0	0	1	2	10	39	69	81	37	18	1	0		
	CDH23.3	1380	0	1	5	26	107	262	295	369	218	96	2	0		
	CDH26.7	432	0	0	0	5	28	107	98	122	59	13	0	0		
(14) Wind	WSAvg	3.2	3.3	3.2	3.4	3.5	3.4	3.3	3.2	3.0	2.8	2.8	3.1	3.2		
(15) Precipitation	PrecAvg	1722	175	152	135	158	132	99	86	94	126	156	234	175		
	PrecMax	2305	441	352	305	346	325	216	212	265	246	439	391	289		
	PrecMin	1286	13	35	33	63	52	24	25	31	45	21	52	9		
	PrecStd	227	102	90	72	81	57	50	49	56	58	98	99	79		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	19.1	21.8	23.9	26.9	30.1	33.9	33.9	34.4	31.1	28.5	22.9	20.0		
		MCWB	12.2	12.6	14.0	16.9	19.4	22.2	23.3	22.9	21.0	19.1	15.7	12.7		
	2%	DB	17.1	18.5	21.4	23.0	26.4	29.9	29.2	30.1	28.4	25.8	20.8	18.1		
		MCWB	11.7	11.4	13.3	14.8	18.1	21.1	21.9	22.1	20.2	18.1	14.5	12.3		
	5%	DB	15.5	16.4	19.0	20.1	23.6	26.0	26.0	27.0	25.9	24.0	18.7	16.5		
		MCWB	10.8	10.6	12.4	13.5	16.9	19.5	20.8	21.4	19.5	17.3	13.4	11.5		
	10%	DB	14.0	14.3	17.0	17.7	20.9	23.1	24.2	24.8	23.6	22.1	16.9	15.0		
		MCWB	10.3	10.1	11.5	12.7	15.9	18.7	20.3	20.6	19.0	16.5	12.9	10.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.6	13.7	15.1	17.5	20.9	23.7	24.2	24.6	22.7	20.2	16.8	14.2		
		MCDB	16.6	18.4	21.6	24.8	28.3	31.1	30.5	30.1	27.9	25.1	20.5	17.0		
	2%	WB	12.6	12.5	13.9	15.6	18.9	21.6	22.7	23.1	21.5	19.1	15.5	13.3		
		MCDB	15.2	15.9	19.4	21.1	24.4	28.0	27.3	27.6	25.7	23.3	18.7	16.0		
	5%	WB	11.8	11.7	13.0	14.4	17.6	20.3	21.6	22.1	20.5	18.2	14.5	12.5		
		MCDB	14.2	14.5	17.4	18.6	22.0	24.7	25.2	26.0	24.2	22.1	17.4	15.1		
	10%	WB	11.0	10.9	12.2	13.6	16.5	19.2	20.7	21.2	19.6	17.4	13.6	11.6		
		MCDB	13.2	13.4	15.7	16.6	20.0	22.6	23.6	24.3	22.9	20.8	16.2	14.3		
(35) Mean Daily Temperature Range	5% DB	MDBR	7.0	7.7	8.0	7.9	8.0	7.7	7.2	7.7	8.9	8.5	7.5	7.2		
		MCDBR	8.8	11.3	12.3	12.9	14.1	14.0	12.3	12.6	13.2	11.4	10.1	8.4		
	5% WB	MCWBR	5.3	6.1	6.1	6.4	6.9	6.7	5.9	6.0	6.4	5.5	5.5	4.8		
		MCWBR	7.3	8.6	9.9	10.6	11.4	11.6	10.0	10.4	10.5	10.0	8.4	7.1		
(40) Clear-Sky Solar Irradiance	taub		0.327	0.343	0.376	0.401	0.410	0.422	0.413	0.412	0.389	0.367	0.343	0.324		
		taud	2.495	2.438	2.354	2.295	2.313	2.314	2.345	2.356	2.408	2.466	2.482	2.500		
	Ebn at Noon		804	850	860	864	864	852	855	844	838	811	775	772		
		Edh at Noon	72	89	109	125	126	127	122	116	103	86	72	66		
(44) All-Sky Solar Radiation	RadAvg		1.39	2.26	3.49	4.48	5.30	5.87	5.83	5.22	4.24	2.75	1.64	1.31		
	RadStd		0.17	0.29	0.43	0.47	0.44	0.37	0.34	0.33	0.22	0.23	0.20	0.16		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (17 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page