

DAX SEYRESSE AP, FranceWMO: **076030**Lat: **43.6897N**Lon: **1.0700W**Elev: **33**StdP: **100.93**Time Zone: **1.00 (EUC)**Period: **99-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-3.0	-1.6	-6.2	2.2	-0.4	-4.1	2.7	1.2	8.6	11.6	7.5	11.5	1.1	70	0.408

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.2	32.9	22.4	30.7	21.4	28.8	20.7	23.6	30.4	22.5	28.7	21.6	27.1	3.1	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
21.5	16.2	26.7	20.5	15.3	25.1	19.8	14.5	24.1	70.3	30.5	66.4	29.0	62.9	27.1	27.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
7.1	5.9	5.1	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			-5.4	37.3	2.0	1.4	-6.9	38.3	-8.1	39.1	-9.2	39.9	-10.7	40.9
			-5.9	25.4	2.2	0.8	-7.5	26.0	-8.8	26.4	-10.0	26.9	-11.6	27.5
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	14.4	7.4	7.9	10.8	13.3	16.2	19.9	21.4	21.6	19.3	15.6	10.5	8.0
	DBStd	6.18	3.78	3.71	3.46	3.13	3.29	3.24	2.83	2.82	3.08	3.50	3.56	3.86
	HDD10.0	333	96	75	32	5	1	0	0	0	0	4	37	84
	HDD18.3	1807	340	292	234	156	82	19	5	3	24	97	236	320
	CDD10.0	1924	14	17	57	103	194	298	354	358	279	177	51	22
	CDD18.3	356	0	0	0	3	17	67	101	103	53	11	0	0
	CDH23.3	2855	0	1	9	64	199	548	756	768	424	83	2	0
	CDH26.7	970	0	0	0	12	61	201	264	286	132	13	0	0
Wind	WSAvg	2.1	2.2	2.2	2.5	2.4	2.3	2.2	2.2	2.0	1.8	1.8	2.0	2.1
Precipitation	PrecAvg	1287	129	106	87	118	100	77	66	73	104	124	182	121
	PrecMax	1722	331	224	192	282	267	201	151	234	228	270	405	202
	PrecMin	879	9	17	13	34	31	16	13	16	28	23	30	13
	PrecStd	206	79	59	52	64	49	46	40	47	51	70	101	52
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	18.2	20.7	24.7	28.5	31.6	34.6	35.1	36.9	32.7	28.6	22.3	19.5
		MCWB	12.6	12.6	14.2	17.2	20.0	23.3	23.3	22.6	21.5	19.2	16.0	13.1
	2%	DB	15.9	18.0	21.9	25.0	28.2	31.4	32.1	32.6	30.1	25.5	19.8	17.1
		MCWB	11.9	11.7	13.6	15.6	18.6	21.6	22.9	22.7	20.5	18.3	14.5	12.2
	5%	DB	14.2	15.9	19.5	22.4	25.2	28.9	29.6	29.7	27.9	23.4	17.4	15.2
		MCWB	11.3	10.9	12.8	14.6	17.7	20.7	21.6	21.7	19.9	17.5	13.9	11.6
	10%	DB	12.9	13.8	17.2	19.6	22.7	26.4	27.5	27.5	25.7	21.3	15.6	13.5
		MCWB	10.9	10.1	11.7	13.5	16.6	19.5	20.9	20.7	19.2	16.7	13.1	11.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.8	14.0	15.6	17.8	21.1	24.4	24.8	24.9	23.2	20.6	17.5	14.1
		MCDB	15.8	18.9	21.7	25.6	28.4	31.9	31.5	32.1	30.0	25.3	20.3	16.9
	2%	WB	12.9	12.6	14.3	16.4	19.5	22.7	23.5	23.4	21.8	19.2	15.8	13.1
		MCDB	14.8	16.1	20.1	23.3	26.5	30.0	30.1	29.8	27.2	23.7	18.5	15.8
	5%	WB	12.0	11.7	13.2	15.2	18.3	21.3	22.5	22.2	20.8	18.3	14.6	12.2
		MCDB	13.7	14.5	18.0	20.9	24.0	27.1	28.2	28.4	26.0	21.9	16.7	14.3
	10%	WB	11.0	10.8	12.3	14.2	17.2	20.2	21.4	21.3	19.8	17.4	13.5	11.3
		MCDB	12.6	13.4	16.2	18.4	21.5	25.1	26.2	26.3	24.3	20.5	15.3	13.3
Mean Daily Temperature Range	5% DB	MDBR	7.6	9.4	10.1	10.3	9.9	10.0	10.2	10.7	11.3	10.3	8.1	8.0
		MCDBR	9.4	13.6	14.6	15.7	15.4	15.0	14.5	14.9	14.8	13.4	11.1	10.3
		MCWBR	6.2	7.9	7.2	7.2	7.1	6.5	6.3	6.2	6.3	6.8	6.7	6.4
	5% WB	MCDBR	7.7	10.9	12.1	13.3	13.1	12.9	12.7	13.0	12.6	11.3	9.5	8.7
		MCWBR	5.7	7.0	6.2	6.4	6.3	6.1	5.9	5.6	5.7	6.1	6.3	6.1
Clear-Sky Solar Irradiance	taub	0.328	0.343	0.376	0.402	0.410	0.423	0.414	0.412	0.387	0.368	0.343	0.324	
	taud	2.488	2.429	2.346	2.283	2.306	2.305	2.335	2.347	2.403	2.459	2.474	2.490	
	Ebn at Noon	800	848	859	863	863	851	854	843	838	808	771	767	
	Edh at Noon	72	89	110	126	127	128	123	117	103	86	72	66	
All-Sky Solar Radiation	RadAvg	1.41	2.30	3.51	4.52	5.30	5.88	5.84	5.23	4.26	2.77	1.66	1.31	
	RadStd	0.15	0.29	0.42	0.47	0.45	0.39	0.38	0.34	0.22	0.23	0.20	0.16	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (21 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page