

AUCH GERS AP, France

WMO: 076220

Lat: 43.6889N

Lon: 0.6011E

Elev: 411

StdP: 14.48

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	23.1	26.0	19.4	14.8	25.5	22.7	17.3	28.6	18.8	47.8	16.3	48.3	2.4	200	0.430

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.3	92.1	70.6	88.4	69.4	85.1	68.3	73.1	86.7	71.5	84.4	70.0	81.6	5.9	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
68.9	108.0	78.6	67.4	102.2	77.0	66.0	97.4	75.0	36.9	87.2	35.5	84.4	34.1	81.7	81.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
15.1	12.9	11.3	DB	18.5	97.9	4.0	4.1	15.6	100.8	13.2	103.2	11.0	105.5	8.1	108.4	
			WB	18.0	76.0	4.0	1.8	15.1	77.2	12.7	78.3	10.5	79.3	7.6	80.6	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	56.1	42.4	43.5	48.9	53.6	60.2	67.3	70.7	70.7	64.6	58.3	48.4	43.3
	DBStd	11.90	6.57	6.50	5.69	5.28	5.55	5.85	5.14	5.31	5.57	6.51	6.48	6.85
	HDD50	884	244	192	87	23	2	0	0	0	0	12	103	221
	HDD65	3840	700	602	498	342	168	43	10	9	74	221	499	674
	CDD50	3098	9	10	54	131	317	518	643	641	439	270	54	12
	CDD65	580	0	0	0	1	18	111	188	185	63	14	0	0
	CDH74	5921	0	0	3	43	282	1172	1848	1777	684	112	0	0
	CDH80	2187	0	0	0	4	62	427	736	742	201	15	0	0
(14) Wind	WSAvg	4.6	4.8	5.1	5.4	5.3	4.8	4.5	4.6	4.2	3.9	3.9	4.5	4.4
(15) Precipitation	PrecAvg	28.6	2.6	2.0	2.0	2.8	3.1	2.4	2.1	2.0	2.2	2.3	2.8	2.2
	PrecMax	38.8	6.6	4.1	4.9	6.0	6.0	8.7	4.3	3.9	4.9	7.6	6.1	4.5
	PrecMin	21.1	0.2	0.3	0.3	0.6	1.1	0.5	0.2	0.4	0.6	0.7	0.3	0.3
	PrecStd	4.4	1.6	1.2	1.1	1.4	1.2	1.5	1.1	0.9	1.3	1.5	1.4	1.1
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	61.4	66.2	72.8	79.3	85.9	95.0	96.2	99.2	89.7	82.2	69.7	62.2
		MCWB	53.9	54.3	56.7	62.6	67.1	71.3	71.0	71.0	68.0	64.3	60.3	54.7
	2%	DB	57.7	61.3	68.0	73.9	80.9	88.8	91.2	92.5	85.5	77.1	65.2	58.8
		MCWB	52.4	52.0	55.7	59.4	65.6	69.7	70.7	70.6	66.8	64.1	57.9	53.3
	5%	DB	55.0	57.6	64.2	69.8	76.7	84.6	87.7	87.9	81.7	73.2	61.7	56.3
		MCWB	51.1	50.6	53.8	57.6	63.6	68.4	69.3	69.8	65.6	62.8	56.3	52.0
	10%	DB	52.7	54.4	60.7	65.6	72.7	81.0	84.0	83.5	77.7	69.9	58.5	53.9
		MCWB	49.5	49.5	52.2	55.6	61.7	66.9	68.3	68.6	64.3	61.6	54.5	50.7
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	55.7	55.8	59.2	63.6	69.1	74.7	74.5	75.4	71.5	68.0	61.8	56.3
		MCDB	58.7	63.1	68.4	75.5	81.4	87.6	89.8	89.1	84.9	77.5	67.3	60.3
	2%	WB	53.5	53.1	56.6	60.8	66.9	71.7	72.7	73.4	69.2	65.9	59.0	54.2
		MCDB	57.0	58.4	65.0	71.8	78.8	85.1	86.7	86.3	80.3	73.1	63.7	57.7
	5%	WB	51.5	51.6	54.9	58.5	64.6	69.7	71.1	71.6	67.5	64.2	56.9	52.5
		MCDB	54.4	56.3	62.6	67.3	74.2	81.9	83.8	83.9	77.3	70.8	60.6	55.6
	10%	WB	49.7	50.0	53.2	56.5	62.5	67.9	69.5	69.8	65.7	62.6	54.9	50.9
		MCDB	52.3	54.1	59.5	63.9	71.1	78.6	80.7	80.9	74.9	68.7	58.0	53.7
(35) Mean Daily Temperature Range	5% DB	MDBR	14.8	17.7	20.0	19.7	19.8	20.7	21.3	21.8	22.4	19.9	15.6	15.5
		MCDBR	18.1	25.0	27.9	28.6	28.5	29.0	30.0	31.0	30.0	24.8	21.0	19.2
		MCWBR	13.1	16.4	16.5	15.5	14.7	12.5	11.7	11.6	12.9	13.1	14.0	14.0
	5% WB	MCDBR	15.9	20.9	23.5	24.6	24.4	24.9	25.3	25.6	23.8	20.5	17.7	16.6
		MCWBR	12.1	14.5	14.5	13.8	13.2	11.6	10.5	10.5	10.8	11.4	12.6	12.5
(40) Clear-Sky Solar Irradiance	taub		0.321	0.336	0.373	0.400	0.408	0.422	0.413	0.412	0.380	0.363	0.337	0.318
	taud		2.477	2.412	2.313	2.241	2.274	2.272	2.299	2.312	2.384	2.439	2.464	2.481
	Ebn at Noon		256	271	273	274	274	270	271	267	268	258	246	245
	Edh at Noon		23	29	36	42	42	42	40	38	33	28	23	21
(44) All-Sky Solar Radiation	RadAvg		462	758	1145	1472	1676	1900	1888	1685	1369	908	546	427
	RadStd		39	83	116	152	129	135	135	106	70	73	61	54

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	+1.66	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (23 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page