

AUCH GERS AP, France

WMO: 076220

Lat: 43.6889N

Lon: 0.6011E

Elev: 125

StdP: 99.83

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-4.9	-3.3	-7.0	2.1	-3.6	-5.2	2.5	-1.9	8.4	8.8	7.3	9.1	1.1	200	0.430

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.8	33.4	21.4	31.3	20.8	29.5	20.2	22.9	30.4	22.0	29.1	21.1	27.5	2.6	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.5	15.4	25.9	19.7	14.6	25.0	18.9	13.9	23.9	68.0	30.7	64.6	29.1	61.5	27.6	27.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
6.8	5.7	5.0	DB	-7.5	36.6	2.2	2.3	-9.1	38.2	-10.4	39.6	-11.7	40.8	-13.3	42.5	(4)
			WB	-7.8	24.4	2.2	1.0	-9.4	25.1	-10.7	25.7	-12.0	26.3	-13.6	27.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	13.4	5.8	6.4	9.4	12.0	15.6	19.6	21.5	21.5	18.1	14.6	9.1	6.3
	DBStd	6.61	3.65	3.61	3.16	2.93	3.08	3.25	2.85	2.95	3.09	3.62	3.60	3.81
	HDD10.0	491	136	107	48	13	1	0	0	0	7	57	123	123
	HDD18.3	2133	389	334	277	190	93	24	6	5	41	123	277	374
	CDD10.0	1721	5	6	30	73	176	288	357	356	244	150	30	7
	CDD18.3	322	0	0	0	1	10	62	104	103	35	8	0	0
	CDH23.3	3289	0	0	2	24	157	651	1027	987	380	62	0	0
	CDH26.7	1215	0	0	0	2	34	237	409	412	112	8	0	0
Wind	WSAvg	2.1	2.2	2.3	2.4	2.4	2.1	2.0	2.1	1.9	1.7	1.8	2.0	2.0
Precipitation	PrecAvg	727	66	52	51	72	78	61	54	52	55	58	71	57
	PrecMax	986	168	105	125	153	153	222	110	100	125	193	154	115
	PrecMin	536	5	8	8	16	28	12	5	10	14	18	7	7
	PrecStd	111	41	31	28	35	31	39	28	24	32	39	36	29
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	16.4	19.0	22.7	26.3	29.9	35.0	35.7	37.3	32.0	27.9	21.0	16.8
		MCWB	12.2	12.4	13.7	17.0	19.5	21.8	21.7	21.6	20.0	18.0	15.7	12.6
	2%	DB	14.3	16.3	20.0	23.3	27.2	31.6	32.9	33.6	29.7	25.0	18.4	14.9
		MCWB	11.3	11.1	13.2	15.2	18.7	20.9	21.5	21.5	19.4	17.8	14.4	11.8
	5%	DB	12.8	14.2	17.9	21.0	24.8	29.2	30.9	31.1	27.6	22.9	16.5	13.5
		MCWB	10.6	10.3	12.1	14.2	17.5	20.2	20.7	21.0	18.6	17.1	13.5	11.1
	10%	DB	11.5	12.4	15.9	18.7	22.6	27.2	28.9	28.6	25.4	21.0	14.7	12.2
		MCWB	9.7	9.7	11.2	13.1	16.5	19.4	20.2	20.3	18.0	16.4	12.5	10.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.2	13.2	15.1	17.6	20.6	23.7	23.6	24.1	22.0	20.0	16.6	13.5
		MCDB	14.8	17.3	20.2	24.2	27.5	30.9	32.1	31.7	29.4	25.3	19.6	15.7
	2%	WB	12.0	11.7	13.7	16.0	19.4	22.1	22.6	23.0	20.7	18.9	15.0	12.3
		MCDB	13.9	14.7	18.4	22.1	26.0	29.5	30.4	30.2	26.8	22.9	17.6	14.3
	5%	WB	10.9	10.9	12.7	14.7	18.1	20.9	21.7	22.0	19.7	17.9	13.8	11.4
		MCDB	12.5	13.5	17.0	19.6	23.5	27.7	28.8	28.8	25.2	21.6	15.9	13.1
	10%	WB	9.8	10.0	11.8	13.6	16.9	19.9	20.8	21.0	18.7	17.0	12.7	10.5
		MCDB	11.3	12.3	15.3	17.7	21.7	25.9	27.1	27.1	23.8	20.4	14.4	12.0
Mean Daily Temperature Range	5% DB	MDBR	8.2	9.8	11.1	11.0	11.0	11.5	11.8	12.1	12.5	11.0	8.7	8.6
		MCDBR	10.0	13.9	15.5	15.9	15.8	16.1	16.7	17.2	16.6	13.8	11.6	10.7
		MCWBR	7.3	9.1	9.2	8.6	8.2	6.9	6.5	6.4	7.2	7.3	7.8	7.8
	5% WB	MCDBR	8.8	11.6	13.1	13.7	13.5	13.9	14.1	14.2	13.2	11.4	9.9	9.2
		MCWBR	6.7	8.0	8.1	7.6	7.3	6.4	5.8	5.8	6.0	6.3	7.0	7.0
Clear-Sky Solar Irradiance	taub	0.321	0.336	0.373	0.400	0.408	0.422	0.413	0.412	0.380	0.363	0.337	0.318	
	taud	2.477	2.412	2.313	2.241	2.274	2.272	2.299	2.312	2.384	2.439	2.464	2.481	
	Ebn at Noon	808	855	861	864	865	852	855	843	844	812	777	773	
	Edh at Noon	72	91	113	132	131	132	127	121	105	87	73	66	
All-Sky Solar Radiation	RadAvg	1.46	2.39	3.61	4.64	5.28	5.99	5.95	5.31	4.32	2.86	1.72	1.35	
	RadStd	0.12	0.26	0.36	0.48	0.41	0.43	0.43	0.34	0.22	0.23	0.19	0.17	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	+0.92	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (23 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page