

ST GIRONS ANTICHAN AP, France

WMO: 076270

Lat: 43.0053N

Lon: 1.1069E

Elev: 1368

StdP: 13.98

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	23.1	26.4	17.8	14.2	27.1	20.8	16.4	30.1	21.1	48.1	18.8	46.9	3.4	300	0.448

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.8	88.7	70.6	85.1	69.4	81.9	67.8	72.8	84.5	70.9	81.9	69.2	79.4	4.9	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
68.9	111.9	79.7	67.1	105.0	77.0	65.5	99.1	74.6	37.4	84.6	35.5	81.9	34.1	79.3	79.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.0	14.3	12.2	17.7	95.0	3.9	3.3	14.9	97.4	12.6	99.3	10.4	101.2	7.5	103.6
			16.8	77.2	3.9	1.3	14.1	78.1	11.8	78.9	9.6	79.7	6.8	80.6
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	54.6	41.8	43.0	48.2	51.8	58.0	64.8	68.1	68.2	62.6	57.1	47.2	42.9	(6)
(7)		DBStd	11.27	6.23	6.95	6.13	5.89	6.04	6.08	5.20	5.28	5.34	6.12	6.24	6.32	(7)
(8)		HDD50	992	261	206	105	47	8	0	0	0	14	123	228		(8)
(9)		HDD65	4190	720	615	521	396	228	78	29	25	108	252	534	684	(9)
(10)		CDD50	2658	7	11	50	102	256	444	562	566	378	234	39	9	(10)
(11)		CDD65	379	0	0	0	0	12	72	126	126	36	7	0	0	(11)
(12)		CDH74	3689	0	0	3	33	173	729	1108	1164	391	87	1	0	(12)
(13)		CDH80	1140	0	0	0	2	28	213	362	436	90	9	0	0	(13)
(14)	Wind	WSAvg	4.6	5.0	5.4	5.4	5.3	4.7	4.3	4.4	4.1	3.9	4.0	4.4	4.4	(14)
(15)	Precipitation	PrecAvg	35.7	3.0	2.5	2.6	3.9	3.9	2.9	2.2	2.7	3.0	3.6	2.8		(15)
(16)		PrecMax	49.2	7.3	5.7	5.2	8.2	7.1	8.8	4.5	4.8	6.3	11.5	9.3	5.4	(16)
(17)		PrecMin	28.1	0.4	0.4	0.5	1.5	2.0	0.8	0.6	0.5	0.8	0.9	0.4	0.2	(17)
(18)		PrecStd	4.6	1.9	1.5	1.1	1.6	1.4	1.6	1.0	0.9	1.5	2.0	1.7	1.5	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	63.1	68.3	73.0	78.6	83.7	90.7	92.7	94.9	87.0	80.9	70.7	64.3	(19)
(20)		0.4%	MCWB	52.0	51.7	54.7	61.4	66.9	72.0	71.3	70.2	68.0	63.3	57.5	52.3	(20)
(21)		2%	DB	58.3	63.1	68.3	73.0	78.7	85.4	87.7	89.1	82.3	76.2	66.1	59.5	(21)
(22)		2%	MCWB	49.6	50.5	53.9	58.2	64.9	70.0	70.8	70.2	66.2	62.6	54.7	49.8	(22)
(23)		5%	DB	55.2	58.6	64.6	68.9	74.7	81.8	83.9	84.9	78.6	72.4	61.5	56.1	(23)
(24)		5%	MCWB	48.2	48.5	52.3	56.2	62.4	68.1	69.5	69.7	64.7	61.1	52.9	48.8	(24)
(25)		10%	DB	51.9	54.4	60.5	64.7	70.8	78.2	80.3	80.6	74.7	68.6	57.3	53.0	(25)
(26)		10%	MCWB	46.4	47.1	50.4	54.1	60.5	66.3	68.0	68.0	63.5	59.5	51.1	47.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	53.9	53.9	57.6	62.1	69.1	75.1	75.0	75.0	70.9	66.6	59.0	54.0	(27)
(28)		0.4%	MCDWB	60.0	64.1	68.1	75.2	79.9	87.0	87.1	87.2	82.2	76.2	67.5	60.6	(28)
(29)		2%	WB	51.3	51.6	55.0	59.4	65.9	71.7	72.5	72.6	68.2	64.0	56.1	51.7	(29)
(30)		2%	MCDWB	56.3	59.9	65.1	71.0	76.7	82.8	84.2	84.1	79.5	72.6	63.1	57.2	(30)
(31)		5%	WB	49.0	49.6	53.1	57.1	63.5	69.1	70.5	70.5	66.1	62.1	54.0	49.8	(31)
(32)		5%	MCDWB	53.8	56.5	62.8	67.1	72.7	79.3	81.2	81.5	75.5	70.1	59.6	54.8	(32)
(33)		10%	WB	46.8	47.6	51.3	54.9	61.2	67.1	68.8	68.7	64.1	60.2	52.0	47.7	(33)
(34)		10%	MCDWB	51.1	53.8	59.5	63.2	69.1	76.4	78.3	79.1	72.2	67.2	56.9	52.2	(34)
(35)	Mean Daily Temperature Range	MDBR	16.8	17.7	19.6	19.1	18.6	18.7	18.8	19.7	20.5	19.7	17.3	17.5	(35)	
(36)		5% DB	MCDBR	22.5	26.3	27.3	27.6	26.3	26.7	27.4	28.9	27.6	26.1	24.6	22.9	(36)
(37)		5% DB	MCWBR	14.4	15.8	15.4	15.2	14.3	13.8	13.4	13.6	13.4	14.4	15.1	14.9	(37)
(38)		5% WB	MCDWB	19.3	22.6	23.9	25.2	23.4	23.7	23.7	24.8	23.9	23.0	21.0	19.6	(38)
(39)		5% WB	MCWBR	13.2	14.4	14.1	14.4	13.4	13.1	12.6	12.9	12.3	13.4	13.6	13.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.303	0.320	0.366	0.386	0.401	0.414	0.406	0.406	0.371	0.354	0.323	0.302	(40)	
(41)		taud	2.499	2.437	2.327	2.286	2.289	2.286	2.316	2.321	2.412	2.459	2.494	2.508	(41)	
(42)		Ebn at Noon	267	279	277	279	277	273	273	270	272	263	255	256	(42)	
(43)		Edh at Noon	23	28	36	40	41	41	40	38	32	27	23	21	(43)	
(44)	All-Sky Solar Radiation	RadAvg	543	828	1207	1505	1725	1981	2001	1779	1422	967	611	495	(44)	
(45)		RadStd	51	94	114	150	137	125	116	102	69	81	63	61	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (19 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page