

ALBI LE SEQUESTRE AP, France

WMO: 076320

Lat: 43.9147N

Lon: 2.1164E

Elev: 564

StdP: 14.40

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	23.5	26.6	17.3	13.5	29.2	21.1	16.1	31.7	21.1	50.3	18.4	50.5	2.4	90	0.450

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.9	93.8	69.3	90.1	68.5	86.9	67.3	71.9	87.1	70.4	85.2	69.0	83.0	7.2	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
67.1	101.6	77.9	65.7	96.7	75.9	64.4	92.4	74.4	35.9	87.5	34.6	85.1	33.4	83.4	76.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.2	15.3	13.2	19.9	98.9	4.0	3.8	17.0	101.6	14.7	103.9	12.5	106.0	9.6	108.7
			19.0	74.3	3.9	1.1	16.2	75.1	13.9	75.7	11.7	76.3	8.8	77.1
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	56.6	42.2	43.3	49.3	54.2	61.1	68.6	72.5	72.1	65.3	58.9	48.2	42.8
	DBStd	12.66	6.40	6.90	5.89	5.69	6.03	6.55	5.54	6.06	5.96	6.71	6.95	7.02
	HDD50	916	250	198	84	23	2	0	0	0	0	12	112	235
	HDD65	3797	708	607	486	326	152	37	7	8	68	207	503	688
	CDD50	3335	7	11	63	149	345	559	696	686	460	287	60	12
	CDD65	740	0	0	0	2	30	146	238	229	78	17	0	0
	CDH74	7573	0	0	5	62	359	1521	2437	2324	743	122	0	0
	CDH80	3026	0	0	0	7	79	592	1063	1053	221	11	0	0
Wind	WSAvg	5.4	5.0	5.5	6.1	6.1	5.9	5.7	5.8	5.2	4.7	4.9	4.9	4.6
Precipitation	PrecAvg	33.3	2.8	2.4	2.4	3.7	3.5	2.9	2.0	2.2	2.6	2.8	3.2	2.8
	PrecMax	44.4	6.2	5.1	5.0	7.6	6.5	10.9	4.3	4.3	6.5	8.0	6.5	5.7
	PrecMin	25.4	0.3	0.3	0.5	0.8	1.3	0.6	0.4	0.6	0.7	0.8	0.4	0.3
	PrecStd	5.1	1.4	1.5	1.2	1.9	1.4	2.0	1.1	1.0	1.5	1.5	1.5	1.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	60.3	66.5	73.8	80.6	86.5	96.0	97.2	100.2	89.8	81.5	70.1	62.7
		MCWB	52.2	52.8	55.4	60.6	65.4	70.4	69.3	69.1	66.7	64.5	59.0	53.9
	2%	DB	57.6	61.5	68.5	74.8	81.9	90.0	93.1	94.4	85.8	77.4	66.0	59.2
		MCWB	51.1	50.9	54.2	58.6	63.9	68.5	69.4	69.0	65.4	63.3	57.0	52.6
	5%	DB	54.8	57.5	64.6	70.7	78.1	86.4	89.6	90.2	82.2	73.9	62.5	56.0
		MCWB	49.6	49.3	52.5	56.3	62.3	67.1	68.5	68.5	64.5	62.0	55.6	50.7
	10%	DB	51.9	54.1	60.8	66.5	73.9	82.9	86.2	86.0	78.2	70.6	59.0	53.2
		MCWB	48.1	48.0	50.7	54.5	60.4	65.9	67.4	67.6	63.2	61.0	53.9	49.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	54.5	54.7	58.2	62.6	68.7	73.2	73.6	73.6	70.5	66.8	60.5	55.5
		MCDB	57.5	62.9	69.2	77.0	82.8	89.8	89.2	89.0	84.2	77.2	67.9	60.3
	2%	WB	52.2	52.2	55.5	59.8	65.7	70.8	71.8	71.7	68.2	65.1	58.2	53.5
		MCDB	56.1	58.6	65.1	72.1	78.7	85.6	86.8	87.3	80.6	73.8	64.1	57.7
	5%	WB	50.3	50.5	53.7	57.5	63.6	69.0	70.3	70.1	66.4	63.5	56.4	51.8
		MCDB	53.8	55.7	61.9	67.7	74.7	82.8	84.8	85.3	77.6	71.5	61.0	55.1
	10%	WB	48.4	48.6	52.0	55.6	61.5	67.2	68.9	68.6	64.6	61.8	54.5	49.8
		MCDB	51.5	53.4	59.3	64.2	71.4	79.6	82.6	82.8	74.6	69.1	58.5	52.9
Mean Daily Temperature Range	5% DB	MDBR	13.4	16.7	19.5	19.9	19.7	20.9	21.9	22.4	21.4	18.8	14.4	14.0
		MCDBR	18.5	23.9	27.3	28.2	26.9	27.5	28.6	29.6	27.5	23.5	20.3	18.8
		MCWBR	12.5	14.5	15.1	14.3	12.6	10.9	10.0	10.2	10.9	11.4	12.5	12.6
	5% WB	MCDBR	14.9	20.5	22.6	24.3	23.4	24.3	24.3	24.7	22.3	19.6	16.9	15.8
		MCWBR	10.9	13.2	13.2	12.7	11.9	10.6	9.3	9.6	9.8	10.1	11.0	11.3
Clear-Sky Solar Irradiance	taub	0.313	0.329	0.365	0.396	0.403	0.412	0.404	0.405	0.376	0.362	0.333	0.311	
	taud	2.484	2.431	2.340	2.253	2.286	2.299	2.319	2.330	2.393	2.439	2.472	2.490	
	Ebn at Noon	259	274	276	275	276	273	273	269	269	257	248	248	
	Edh at Noon	23	28	35	41	41	41	39	38	33	28	23	21	
All-Sky Solar Radiation	RadAvg	455	747	1119	1470	1708	2001	1991	1755	1381	895	524	415	
	RadStd	48	89	109	171	137	153	146	113	83	80	59	58	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (26 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page