

CARCASSONNE AP, France

WMO: 076350

Lat: 43.2153N

Lon: 2.2956E

Elev: 132

StdP: 99.75

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-2.7	-1.1	-6.7	2.2	0.2	-4.9	2.5	1.2	13.1	8.1	12.0	8.0	4.2	290	0.574

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.3	33.2	20.8	31.4	20.3	29.8	19.8	22.6	29.1	21.9	27.9	21.2	27.0	4.6	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.8	15.7	24.8	20.0	14.9	24.5	19.2	14.2	24.0	67.2	29.2	64.5	28.0	61.9	27.0	25.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.5	10.4	9.5	DB	-4.6	36.0	2.0	1.7	-6.0	37.3	-7.2	38.3	-8.3	39.2	-9.7	40.5	(4)
(5)			WB	-5.2	23.8	2.0	0.7	-6.7	24.3	-7.9	24.6	-9.0	25.0	-10.5	25.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	14.3	6.6	7.1	10.2	12.7	16.2	20.5	23.0	22.7	19.1	15.6	10.1	7.2	(6)	
	DBStd	6.66	3.36	3.47	3.01	2.98	3.11	3.32	2.97	2.84	2.89	3.32	3.53	3.55	(7)	
	HDD10.0	387	112	88	34	9	1	0	0	0	0	3	41	98	(8)	
	HDD18.3	1913	363	314	251	171	81	16	4	3	24	94	247	345	(9)	
	CDD10.0	1955	7	8	42	90	192	315	402	393	274	177	44	12	(10)	
	CDD18.3	438	0	0	0	1	13	81	147	137	48	10	0	0	(11)	
	CDH23.3	3661	0	0	1	19	121	690	1308	1154	333	35	0	0	(12)	
	CDH26.7	1306	0	0	0	2	25	231	519	444	81	4	0	0	(13)	
(14) Wind	WSAvg	4.8	4.9	5.2	5.3	5.2	5.0	4.7	4.7	4.4	4.3	4.5	4.6	4.5	(14)	
(15) Precipitation	PrecAvg	728	66	70	67	70	68	47	26	44	50	80	62	76	(15)	
	PrecMax	1058	150	134	188	134	207	116	66	120	180	317	230	190	(16)	
	PrecMin	398	14	23	0	25	12	4	1	2	0	5	10	12	(17)	
	PrecStd	143	33	29	44	32	42	30	18	27	46	78	55	50	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	16.1	18.4	22.6	25.6	29.5	33.9	35.4	36.3	31.9	26.6	20.3	16.0	(19)	
		MCWB	12.3	12.0	13.0	15.7	18.6	21.4	21.0	21.3	19.8	17.8	15.3	12.8	(20)	
	2%	DB	14.0	15.5	19.5	22.7	26.4	31.2	33.1	33.3	28.9	23.9	18.2	14.6	(21)	
		MCWB	11.2	10.8	12.3	14.4	17.3	20.0	20.7	21.0	18.7	17.4	14.6	12.2	(22)	
	5%	DB	12.7	13.6	17.2	20.4	24.2	29.3	31.4	31.1	26.9	22.0	16.7	13.4	(23)	
		MCWB	10.6	10.2	11.4	13.4	16.5	19.7	20.4	20.4	18.3	17.0	14.0	11.5	(24)	
	10%	DB	11.6	12.2	15.4	18.4	22.3	27.3	29.7	29.2	25.0	20.5	15.4	12.3	(25)	
		MCWB	9.8	9.6	10.7	12.6	15.7	19.1	19.8	20.1	17.7	16.7	13.2	10.7	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.1	13.0	14.5	16.7	19.9	23.0	23.3	23.7	21.8	20.0	16.5	13.7	(27)	
		MCDB	15.3	16.4	19.7	23.7	27.8	30.7	30.5	30.1	26.5	22.6	18.6	15.2	(28)	
	2%	WB	11.8	11.7	13.1	15.3	18.4	21.8	22.5	22.7	20.8	19.0	15.4	12.7	(29)	
		MCDB	13.4	14.3	17.5	21.1	24.3	28.6	29.1	28.8	25.0	21.3	17.4	14.1	(30)	
	5%	WB	11.0	10.8	12.2	14.2	17.3	20.7	21.7	22.0	20.0	18.3	14.5	11.8	(31)	
		MCDB	12.4	12.8	15.8	18.7	22.3	26.9	28.1	27.6	23.8	20.5	16.3	13.2	(32)	
	10%	WB	10.0	9.9	11.5	13.3	16.4	19.8	20.9	21.3	19.1	17.5	13.5	10.8	(33)	
		MCDB	11.3	12.0	14.4	17.1	20.8	25.6	27.3	26.8	23.4	19.9	15.1	12.2	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	6.3	7.5	8.9	9.4	9.6	10.7	11.3	11.3	10.5	8.3	7.0	6.5	(35)	
		MCDBR	7.9	10.5	13.0	13.5	13.7	14.3	14.6	15.3	13.9	10.5	8.8	7.5	(36)	
	5% WB	MCWBR	5.5	6.6	6.9	6.7	6.3	5.4	5.1	5.2	5.8	5.2	5.5	5.4	(37)	
		MCWBR	6.6	9.1	10.1	11.1	11.4	12.0	11.6	11.6	9.8	7.2	7.0	6.4	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.313	0.328	0.367	0.392	0.402	0.411	0.406	0.406	0.378	0.364	0.334	0.311	(40)	
		taud	2.509	2.457	2.362	2.300	2.321	2.328	2.347	2.355	2.418	2.464	2.500	2.516	(41)	
	Edn at Noon	Edn at Noon	826	870	871	874	872	862	862	850	850	816	790	793	(42)	
		Edh at Noon	71	87	108	124	125	125	121	117	102	86	71	65	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1.58	2.49	3.66	4.71	5.45	6.36	6.38	5.64	4.42	2.91	1.80	1.43	(44)	
	RadStd	RadStd	0.15	0.27	0.32	0.49	0.42	0.43	0.41	0.34	0.24	0.27	0.19	0.17	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (23 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page