

SETE, France

WMO: 076410

Lat: 43.3972N

Lon: 3.6922E

Elev: 266

StdP: 14.56

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	31.5	34.3	11.9	10.2	37.7	17.1	13.1	38.4	30.6	48.9	26.3	48.7	11.9	320	0.472

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.2	88.2	68.5	85.7	67.9	83.3	67.2	74.5	80.6	73.0	79.3	71.6	77.6	8.9	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
72.8	122.9	77.7	71.1	115.7	76.2	69.6	109.9	75.2	38.2	80.2	36.8	79.2	35.5	77.5	79.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
26.6	21.5	18.4	DB	30.8	94.2	3.7	3.5	28.2	96.7	26.0	98.7	24.0	100.7	21.3	103.2	
			WB	25.3	75.9	3.6	1.8	22.7	77.2	20.6	78.3	18.5	79.3	15.9	80.6	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	60.6	46.8	47.4	52.8	58.1	63.8	71.8	76.0	74.9	69.2	62.8	54.1	48.5
	DBStd	11.50	5.53	6.00	5.13	4.75	4.89	5.29	4.15	3.85	4.32	5.28	5.66	5.76
	HDD50	390	129	105	29	2	0	0	0	0	0	2	27	96
	HDD65	2686	565	493	379	214	80	5	0	0	11	101	327	511
	CDD50	4255	28	32	116	244	428	655	806	772	577	397	150	50
	CDD65	1080	0	0	0	7	43	211	341	307	138	32	1	0
	CDH74	6007	0	0	3	15	136	1177	2358	1843	429	46	0	0
	CDH80	1449	0	0	0	1	22	302	632	430	55	7	0	0
(14) Wind	WSAvg	9.5	10.1	10.1	9.8	9.8	9.5	8.8	8.7	8.6	8.4	9.9	10.7	9.8
(15) Precipitation	PrecAvg	24.0	1.9	1.8	1.7	2.1	1.8	1.1	0.7	1.2	3.0	3.6	2.9	2.1
	PrecMax	43.5	8.2	7.6	7.6	5.6	5.8	5.3	2.3	4.0	7.7	7.8	9.2	7.8
	PrecMin	11.8	0.0	0.0	0.0	0.2	0.2	0.1	0.0	0.0	0.7	0.6	0.2	0.1
	PrecStd	6.9	2.3	1.8	1.8	1.4	1.3	1.2	0.6	0.9	1.9	2.0	2.6	2.2
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	62.5	63.6	69.4	76.1	82.7	90.9	92.6	91.1	85.0	78.9	68.4	62.1
		MCWB	53.4	51.6	54.2	59.2	65.4	69.6	68.3	70.4	66.3	62.8	59.3	54.9
	2%	DB	58.8	59.5	65.2	71.5	77.5	86.6	88.3	87.0	81.3	74.1	65.3	59.7
		MCWB	51.2	50.0	53.1	57.5	61.8	68.3	68.7	68.0	65.0	62.4	59.4	54.2
	5%	DB	56.3	56.6	62.3	68.3	74.4	83.4	85.9	84.5	78.5	71.5	63.4	58.0
		MCWB	50.5	49.2	51.6	56.0	60.6	67.4	68.2	67.0	64.0	62.8	58.7	53.3
	10%	DB	54.2	54.8	59.9	65.6	71.8	80.3	83.6	82.0	76.1	69.3	61.9	56.4
		MCWB	49.3	49.2	50.6	55.0	59.6	66.3	67.8	67.1	63.8	62.5	57.5	51.9
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	54.9	54.0	56.7	62.5	67.1	74.4	76.9	76.3	72.5	69.1	63.1	57.4
		MCDB	59.8	57.0	64.8	70.7	76.7	83.7	82.8	81.0	75.3	71.3	65.2	59.9
	2%	WB	53.3	52.9	54.9	60.2	65.0	72.4	75.0	74.2	70.7	67.5	61.4	55.8
		MCDB	56.6	55.8	60.7	67.1	72.9	79.9	80.6	80.0	74.4	69.9	63.6	58.5
	5%	WB	51.8	51.8	53.9	58.4	63.4	70.7	73.4	72.8	69.3	65.7	60.0	54.2
		MCDB	55.1	55.2	58.3	64.5	70.4	78.5	80.1	78.5	73.4	68.2	62.5	57.2
	10%	WB	50.1	50.4	52.9	57.0	61.9	69.0	71.7	71.4	67.9	64.5	58.3	52.6
		MCDB	53.9	54.4	57.3	62.7	68.4	77.1	78.2	76.9	72.4	67.2	61.3	56.0
(35) Mean Daily Temperature Range	5% DB	MDBR	9.0	10.2	11.1	11.3	12.2	12.7	13.2	13.0	11.7	9.6	8.9	8.7
		MCDBR	10.3	11.9	13.6	14.5	15.7	16.0	15.9	16.0	14.1	12.0	9.2	9.1
	5% WB	MCWBR	7.5	7.7	7.9	7.8	7.7	7.5	7.1	7.4	7.7	7.1	7.2	6.8
		MCWBR	9.0	9.4	10.7	11.8	12.3	12.6	11.3	11.3	9.7	7.5	7.2	8.1
(40) Clear-Sky Solar Irradiance	taub	taub	0.319	0.333	0.373	0.399	0.407	0.409	0.405	0.404	0.388	0.380	0.343	0.315
		taud	2.495	2.454	2.363	2.302	2.331	2.356	2.370	2.378	2.408	2.432	2.482	2.511
	Edn at Noon	Edn at Noon	259	274	274	275	275	274	274	270	266	252	246	249
		Edh at Noon	23	28	34	39	39	39	38	36	33	28	23	21
(44) All-Sky Solar Radiation	RadAvg	RadAvg	541	847	1237	1619	1950	2254	2259	1929	1466	912	602	474
	RadStd	RadStd	60	83	99	129	130	108	93	91	86	96	75	52

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (33 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page