

NIMES COURBESSAC AP, France

WMO: 076450

Lat: 43.8569N

Lon: 4.4064E

Elev: 203

StdP: 14.59

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	28.5	31.0	11.8	10.1	37.4	16.3	12.6	37.7	23.8	47.4	21.3	45.5	5.8	0	0.457

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.7	94.3	69.8	91.5	69.0	88.7	68.1	73.4	86.1	71.9	84.3	70.7	83.0	8.1	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
70.0	111.2	77.2	68.4	104.9	76.2	66.7	99.2	75.7	37.0	85.9	35.7	84.5	34.6	82.9	77.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
20.9	18.3	16.1	DB	25.2	99.4	3.3	3.6	22.9	102.1	21.0	104.2	19.1	106.2	16.8	108.9
			WB	22.8	75.7	3.4	1.2	20.3	76.6	18.3	77.3	16.4	77.9	13.9	78.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	60.0	44.9	46.3	52.3	57.3	64.2	72.4	77.2	76.4	68.6	61.5	51.5	45.9
	DBStd	12.66	5.72	5.95	5.48	5.15	5.10	5.56	4.62	4.60	5.13	5.61	6.22	5.91
	HDD50	554	175	126	38	5	0	0	0	0	0	3	55	152
	HDD65	3011	623	524	394	235	76	6	0	0	22	134	404	593
	CDD50	4194	17	22	110	225	439	671	845	820	559	360	101	25
	CDD65	1172	0	0	0	5	50	226	380	355	131	25	0	0
	CDH74	10789	0	0	6	66	442	2132	3802	3302	936	102	1	0
	CDH80	4348	0	0	0	5	89	822	1721	1441	258	12	0	0
Wind	WSAvg	7.1	6.8	7.3	7.6	7.7	7.4	7.3	7.4	7.0	6.8	6.6	6.9	6.4
Precipitation	PrecAvg	30.5	2.8	2.5	2.1	2.4	2.3	1.7	1.1	2.0	3.0	4.9	2.9	2.5
	PrecMax	46.9	8.8	8.0	8.4	5.8	6.9	5.9	4.7	5.9	9.0	16.3	8.9	6.0
	PrecMin	15.4	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.1	0.0	0.5	0.0	0.0
	PrecStd	7.5	2.1	2.1	1.8	1.6	1.7	1.3	1.0	1.3	2.3	4.1	2.1	1.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	64.1	67.1	74.5	79.8	87.0	95.9	97.2	99.1	90.8	81.2	70.0	62.9
		MCWB	53.4	53.0	55.7	61.3	66.3	71.3	70.7	71.3	67.7	63.8	59.3	54.2
	2%	DB	59.5	62.4	69.3	75.6	82.3	91.6	94.1	94.3	86.0	76.5	65.8	59.6
		MCWB	50.8	51.0	54.4	58.8	63.9	69.2	69.7	69.8	66.4	63.6	58.3	53.0
	5%	DB	56.3	58.9	65.8	71.8	78.8	87.9	91.5	90.9	82.8	73.8	63.1	57.2
		MCWB	49.4	49.5	52.9	57.0	62.1	67.9	68.8	69.0	64.9	62.7	56.5	51.5
	10%	DB	53.8	56.0	62.9	68.4	75.6	84.8	88.9	87.8	79.6	71.0	60.9	55.0
		MCWB	48.1	48.1	51.5	55.0	60.6	66.3	68.1	68.2	63.9	61.7	55.7	50.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	54.8	54.5	58.2	63.4	68.9	74.3	74.8	75.2	71.6	68.3	62.3	57.2
		MCDB	60.7	62.4	68.8	77.1	82.6	91.0	88.5	85.8	80.1	73.5	66.2	60.0
	2%	WB	52.8	52.7	55.8	60.3	65.7	71.5	72.9	73.6	70.0	66.7	60.1	54.8
		MCDB	57.3	59.4	65.6	71.7	77.9	85.6	86.5	85.2	78.6	72.4	63.6	58.0
	5%	WB	50.9	51.2	54.4	58.3	63.8	69.6	71.6	72.3	68.4	65.0	58.4	53.0
		MCDB	54.9	57.2	63.1	68.8	75.3	83.8	84.8	83.9	77.2	71.0	62.1	56.2
	10%	WB	49.2	49.2	52.9	56.6	62.2	68.0	70.2	70.9	66.6	63.1	56.4	51.0
		MCDB	53.0	55.0	60.5	65.4	72.2	81.0	83.3	82.6	75.6	69.0	60.0	54.3
Mean Daily Temperature Range	5% DB	MDBR	14.2	16.3	18.4	18.7	19.3	20.8	21.7	21.5	19.3	16.1	14.6	13.9
		MCDBR	17.5	20.8	22.8	24.0	24.5	24.9	24.8	25.8	24.0	19.4	16.4	16.1
		MCWBR	11.3	12.3	11.8	11.6	10.9	9.6	8.5	8.9	9.6	9.7	10.5	10.8
	5% WB	MCDBR	14.6	18.5	20.1	21.8	21.6	23.7	22.3	22.1	19.8	15.9	13.7	13.3
		MCWBR	10.5	11.8	11.4	11.5	10.8	10.0	8.9	9.2	9.4	9.0	9.9	9.9
Clear-Sky Solar Irradiance	taub	0.323	0.342	0.380	0.398	0.407	0.407	0.401	0.400	0.386	0.387	0.349	0.320	
	taud	2.462	2.408	2.315	2.286	2.311	2.338	2.353	2.364	2.390	2.385	2.443	2.480	
	Ebn at Noon	254	269	271	275	275	274	274	271	266	248	241	244	
	Edh at Noon	23	29	36	40	40	39	38	36	33	29	23	21	
All-Sky Solar Radiation	RadAvg	532	839	1249	1636	1969	2284	2272	1944	1481	921	589	463	
	RadStd	59	82	103	133	137	106	102	76	87	90	71	51	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		+0.56	N/A	N/A	+1.84	N/A	N/A	N/A	N/A	N/A	N/A
Regional (37 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page