

NIMES AP, France

WMO: 076460

Lat: 43.759N

Lon: 4.417E

Elev: 309

StdP: 14.53

Time Zone: 1.00 (EUC)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	28.3	30.9	11.1	9.8	35.7	16.2	12.6	35.9	30.8	43.9	27.8	43.1	10.5	10	0.492

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.5	92.6	69.4	90.0	68.3	87.4	67.4	73.4	83.8	71.9	82.3	70.5	80.9	8.9	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
70.6	114.0	76.9	69.0	107.7	75.8	67.3	101.4	74.9	37.1	83.6	35.8	82.7	34.5	80.6	79.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
26.9	23.5	20.7	25.9	98.3	3.4	3.9	23.4	101.2	21.4	103.4	19.5	105.6	17.0	108.5		
			22.8	75.6	3.7	1.9	20.1	77.0	18.0	78.2	15.9	79.3	13.2	80.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	59.4	44.4	45.7	51.8	56.9	63.5	71.5	76.2	75.2	68.6	60.8	51.1	45.6
	DBStd	12.53	5.91	6.11	5.62	5.08	5.31	5.90	5.06	4.84	5.01	5.77	5.96	5.76
	HDD50	599	191	140	45	5	0	0	0	0	0	4	57	157
	HDD65	3136	639	541	408	248	91	13	4	3	22	150	416	601
	CDD50	4016	17	19	102	212	418	645	811	781	559	340	91	21
	CDD65	1077	0	0	0	5	44	208	350	319	130	21	0	0
	CDH74	9327	0	0	3	39	347	1834	3363	2845	833	63	0	0
	CDH80	3434	0	0	0	2	64	646	1407	1111	199	5	0	0
(14) Wind	WSAvg	9.0	9.2	9.8	9.6	9.5	8.9	8.8	8.7	8.4	8.4	8.6	9.3	8.8
(15) Precipitation	PrecAvg	30.0	2.4	1.7	1.7	2.6	2.2	1.7	1.1	1.7	4.6	4.3	3.8	2.3
	PrecMax	44.5	8.7	5.4	6.9	6.1	6.4	4.7	3.1	4.4	11.7	8.8	9.7	7.6
	PrecMin	19.3	0.0	0.0	0.0	0.2	0.2	0.1	0.0	0.4	0.9	1.1	0.7	0.0
	PrecStd	6.6	2.0	1.5	1.7	1.6	1.6	1.1	0.9	1.1	2.9	2.0	2.4	2.1
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	63.5	65.7	73.0	78.4	86.2	95.1	95.2	96.9	89.0	79.5	68.9	62.2
		MCWB	53.3	52.3	55.3	61.1	66.3	71.5	70.3	70.1	67.2	63.6	58.6	54.5
	2%	DB	59.1	61.0	68.0	74.2	81.2	90.3	92.4	92.5	85.0	75.3	65.0	58.9
		MCWB	50.6	50.4	53.9	58.4	63.1	68.2	69.3	69.5	65.6	62.8	58.0	53.1
	5%	DB	55.7	57.6	64.6	70.6	77.8	86.7	90.2	89.3	81.9	72.7	62.4	56.8
		MCWB	49.5	48.7	52.5	56.7	61.7	66.9	68.5	68.2	64.7	62.1	56.4	51.7
	10%	DB	53.5	55.0	61.6	67.2	74.6	83.5	87.6	86.1	78.9	70.1	60.3	54.5
		MCWB	48.1	47.9	51.0	54.6	60.1	65.9	67.6	67.3	63.6	61.4	55.2	50.0
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	54.7	54.1	57.4	62.6	68.4	73.8	75.2	75.5	71.2	67.6	61.8	56.8
		MCDB	60.6	61.1	67.2	75.0	81.4	90.1	86.1	85.4	78.9	71.7	65.0	59.3
	2%	WB	52.8	52.2	55.4	59.8	65.5	71.0	73.2	73.6	69.7	66.0	59.7	54.8
		MCDB	57.0	57.7	64.7	70.5	77.0	83.5	84.4	82.4	77.7	71.5	63.1	57.9
	5%	WB	50.7	50.7	53.9	57.9	63.6	69.1	71.7	72.2	68.3	64.3	58.1	52.8
		MCDB	55.0	56.0	61.6	67.5	74.1	81.5	82.7	81.5	76.0	70.6	61.6	55.7
	10%	WB	48.7	48.7	52.5	56.3	61.9	67.6	70.3	70.7	66.7	62.6	56.0	50.7
		MCDB	52.9	54.0	59.2	64.5	71.1	79.8	81.3	80.4	74.8	68.3	59.5	53.9
(35) Mean Daily Temperature Range	5% DB	MDBR	13.1	15.3	17.0	17.8	18.8	20.7	21.5	21.2	18.9	15.8	13.9	13.1
		MCDBR	15.6	18.9	20.9	22.0	23.7	23.8	23.7	24.7	22.7	18.3	15.9	14.9
		MCWBR	10.3	11.4	11.0	10.7	10.5	9.5	8.7	9.2	9.4	9.2	10.3	10.3
	5% WB	MCDBR	13.9	17.0	18.5	19.6	20.9	22.0	20.8	21.0	19.2	15.3	13.6	13.0
		MCWBR	10.2	11.3	10.6	10.6	10.6	9.6	8.9	10.0	10.3	9.1	10.1	9.9
(40) Clear-Sky Solar Irradiance	taub		0.323	0.341	0.379	0.396	0.405	0.405	0.399	0.398	0.385	0.386	0.348	0.320
	taud		2.467	2.413	2.322	2.298	2.322	2.348	2.363	2.373	2.397	2.392	2.448	2.484
	Ebn at Noon		255	269	271	275	275	275	275	272	266	249	242	245
	Edh at Noon		23	29	36	39	40	39	38	36	33	29	23	21
(44) All-Sky Solar Radiation	RadAvg		539	848	1260	1655	1992	2306	2293	1961	1493	931	598	469
	RadStd		60	82	100	129	134	104	97	74	86	89	70	50

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (36 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page