

NIMES AP, France

WMO: 076460

Lat: 43.759N

Lon: 4.417E

Elev: 94

StdP: 100.20

Time Zone: 1.00 (EUC)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-2.0	-0.6	-11.6	1.4	2.0	-8.8	1.8	2.2	13.8	6.6	12.4	6.2	4.7	10	0.492

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.9	33.7	20.8	32.2	20.2	30.8	19.7	23.0	28.8	22.2	27.9	21.4	27.2	4.0	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
21.5	16.3	24.9	20.5	15.4	24.3	19.6	14.5	23.9	68.5	28.7	65.4	28.2	62.5	27.0	26.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.0	10.5	9.2	-3.4	36.9	1.9	2.2	-4.8	38.4	-5.9	39.7	-6.9	40.9	-8.3	42.5		
(5)			-5.1	24.2	2.0	1.1	-6.6	25.0	-7.8	25.7	-8.9	26.3	-10.4	27.0	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	15.2	6.9	7.6	11.0	13.8	17.5	21.9	24.5	24.0	20.3	16.0	10.6	7.6	(6)
(7)		DBStd	6.96	3.29	3.40	3.12	2.82	2.95	3.28	2.81	2.69	2.78	3.21	3.31	3.20	(7)
(8)		HDD10.0	333	106	78	25	3	0	0	0	0	0	2	32	87	(8)
(9)		HDD18.3	1742	355	301	227	138	51	7	2	2	12	83	231	334	(9)
(10)		CDD10.0	2231	9	11	57	118	232	358	451	434	311	189	51	12	(10)
(11)		CDD18.3	598	0	0	0	3	24	116	194	177	72	12	0	0	(11)
(12)		CDH23.3	5182	0	0	2	22	193	1019	1868	1581	463	35	0	0	(12)
(13)		CDH26.7	1908	0	0	0	1	36	359	782	617	111	3	0	0	(13)
(14)	Wind	WSAvg	4.0	4.1	4.4	4.3	4.2	4.0	3.9	3.9	3.8	3.7	3.9	4.2	3.9	(14)
(15)	Precipitation	PrecAvg	762	61	42	44	67	56	42	29	42	116	109	96	58	(15)
(16)		PrecMax	1130	220	136	176	156	162	120	80	111	298	223	247	193	(16)
(17)		PrecMin	491	0	0	0	6	5	2	1	9	22	28	19	0	(17)
(18)		PrecStd	168	51	37	43	41	40	28	22	29	73	51	61	53	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.5	18.7	22.8	25.8	30.1	35.1	35.1	36.1	31.7	26.4	20.5	16.8	(19)
(20)			MCWB	11.8	11.3	12.9	16.2	19.0	21.9	21.3	21.1	19.5	17.5	14.8	12.5	(20)
(21)		2%	DB	15.0	16.1	20.0	23.5	27.3	32.4	33.6	33.6	29.4	24.1	18.3	15.0	(21)
(22)			MCWB	10.3	10.2	12.2	14.7	17.3	20.1	20.7	20.8	18.7	17.1	14.4	11.7	(22)
(23)		5%	DB	13.2	14.2	18.1	21.4	25.4	30.4	32.3	31.8	27.7	22.6	16.9	13.8	(23)
(24)			MCWB	9.7	9.3	11.4	13.7	16.5	19.4	20.3	20.1	18.1	16.7	13.6	10.9	(24)
(25)		10%	DB	11.9	12.8	16.4	19.5	23.7	28.6	30.9	30.1	26.1	21.2	15.7	12.5	(25)
(26)			MCWB	8.9	8.8	10.6	12.6	15.6	18.8	19.8	19.6	17.5	16.3	12.9	10.0	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.6	12.3	14.1	17.0	20.2	23.2	24.0	24.2	21.8	19.8	16.6	13.8	(27)
(28)			MADB	15.9	16.2	19.6	23.9	27.5	32.3	30.0	29.6	26.1	22.1	18.3	15.2	(28)
(29)		2%	WB	11.5	11.2	13.0	15.4	18.6	21.7	22.9	23.1	20.9	18.9	15.4	12.7	(29)
(30)			MADB	13.9	14.3	18.2	21.4	25.0	28.6	29.1	28.0	25.4	22.0	17.3	14.4	(30)
(31)		5%	WB	10.4	10.4	12.1	14.4	17.6	20.6	22.1	22.4	20.2	18.0	14.5	11.5	(31)
(32)			MADB	12.8	13.3	16.5	19.7	23.4	27.5	28.2	27.5	24.5	21.4	16.5	13.2	(32)
(33)		10%	WB	9.3	9.3	11.4	13.5	16.6	19.8	21.3	21.5	19.3	17.0	13.4	10.4	(33)
(34)			MADB	11.6	12.2	15.1	18.1	21.7	26.5	27.4	26.9	23.8	20.2	15.3	12.1	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	7.3	8.5	9.5	9.9	10.5	11.5	11.9	11.8	10.5	8.8	7.7	7.3	(35)
(36)			MADB	8.7	10.5	11.6	12.2	13.2	13.2	13.7	12.6	10.2	8.8	8.3	(36)	
(37)			MCWBR	5.7	6.3	6.1	5.9	5.8	5.3	4.8	5.1	5.2	5.1	5.7	5.7	(37)
(38)		5% WB	MADB	7.7	9.4	10.3	10.9	11.6	12.2	11.6	11.6	10.6	8.5	7.6	7.2	(38)
(39)			MCWBR	5.7	6.3	5.9	5.9	5.9	5.3	4.9	5.6	5.7	5.1	5.6	5.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.323	0.341	0.379	0.396	0.405	0.405	0.399	0.398	0.385	0.386	0.348	0.320	(40)	
(41)		taud	2.467	2.413	2.322	2.298	2.322	2.348	2.363	2.373	2.397	2.392	2.448	2.484	(41)	
(42)		Ebn at Noon	803	848	855	868	868	867	867	856	840	784	762	771	(42)	
(43)		Edh at Noon	73	90	112	124	125	122	119	114	103	92	74	66	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.70	2.67	3.97	5.22	6.28	7.27	7.23	6.18	4.71	2.93	1.89	1.48	(44)	
(45)		RadStd	0.19	0.26	0.31	0.41	0.42	0.33	0.31	0.23	0.27	0.28	0.22	0.16	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (36 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page