

SALON-DE-PROVENCE AP, France

WMO: 076480

Lat: 43.606N

Lon: 5.109E

Elev: 195

StdP: 14.59

Time Zone: 1.00 (EUC)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	25.3	28.0	15.3	12.0	33.2	19.2	14.5	34.3	36.2	43.2	32.2	44.1	4.4	320	0.505

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	23.6	92.5	69.8	90.0	69.1	87.7	68.4	73.5	86.2	72.0	84.7	70.6	83.2	9.9	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
69.5	109.2	79.4	67.9	103.3	77.8	66.2	97.4	77.0	37.1	86.0	35.8	84.9	34.5	83.2	78.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
31.5	27.5	23.9	21.0	97.4	3.2	4.0	18.7	100.3	16.8	102.6	15.0	104.9	12.6	107.8
			19.6	75.9	3.4	1.5	17.2	77.0	15.2	77.8	13.3	78.7	10.9	79.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	58.4	43.3	44.3	50.4	55.9	62.7	70.6	74.9	74.1	67.6	60.3	50.4	44.9
	DBStd	12.47	5.86	5.94	5.31	4.67	5.01	5.44	4.60	4.57	4.80	5.73	6.32	5.78
	HDD50	707	221	170	59	6	0	0	0	0	0	5	70	176
	HDD65	3354	674	579	454	273	102	13	4	4	27	163	439	622
	CDD50	3766	13	10	71	185	395	617	773	748	529	325	81	19
	CDD65	936	0	0	0	1	32	180	312	287	106	18	0	0
	CDH74	9921	0	0	1	40	410	1986	3424	3005	956	99	0	0
	CDH80	3719	0	0	0	2	77	720	1455	1237	223	5	0	0
Wind	WSAvg	8.6	9.2	9.8	9.4	9.0	8.7	8.5	8.8	7.9	7.7	7.8	8.7	8.1
Precipitation	PrecAvg	21.2	1.5	2.0	1.9	1.7	1.5	1.1	0.6	1.5	2.2	3.0	2.4	2.0
	PrecMax	34.6	4.8	4.3	5.1	4.3	4.4	2.5	2.6	5.1	6.0	8.1	7.6	5.0
	PrecMin	9.3	0.0	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.4	0.0	0.6
	PrecStd	5.5	1.1	1.3	1.6	1.3	1.2	0.6	0.7	1.4	1.6	1.9	1.9	1.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	63.3	65.3	71.5	78.3	86.4	94.5	94.9	96.3	88.4	80.0	69.6	62.8
		MCWB	53.4	52.5	55.3	60.8	66.3	72.3	69.5	71.2	67.7	65.1	60.2	55.5
	2%	DB	59.3	61.2	67.8	74.5	81.8	90.6	92.1	92.6	85.2	76.7	66.7	60.5
		MCWB	51.8	51.0	54.4	58.9	64.2	68.9	69.5	70.1	66.7	64.9	58.9	53.9
	5%	DB	56.6	58.3	64.8	71.2	78.5	87.3	89.9	89.6	82.4	74.0	63.9	58.0
		MCWB	50.3	49.6	53.1	57.2	62.1	68.1	69.0	69.6	66.0	63.5	57.1	52.0
	10%	DB	54.2	55.6	62.3	68.1	75.5	84.2	87.7	86.7	79.7	71.5	61.3	55.7
		MCWB	48.4	48.3	51.9	55.4	61.2	66.7	68.5	68.6	65.2	62.1	55.6	50.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	55.4	54.3	58.0	62.6	68.8	74.5	75.2	75.2	72.1	68.6	62.5	57.4
		MCDB	61.0	61.5	67.5	74.2	81.9	90.7	86.6	87.3	79.9	75.9	66.4	61.5
	2%	WB	53.1	52.5	56.0	60.1	65.8	71.8	73.4	73.6	70.1	66.4	59.9	54.8
		MCDB	57.9	58.8	64.5	71.7	77.8	84.9	86.1	86.2	79.3	73.9	64.8	58.9
	5%	WB	51.1	51.0	54.5	58.3	64.0	69.9	71.8	72.0	68.5	64.9	58.3	53.0
		MCDB	55.9	56.8	62.6	69.1	75.2	83.0	85.0	84.9	78.2	72.1	63.2	57.2
	10%	WB	49.0	48.9	52.9	56.7	62.3	68.0	70.4	70.5	66.9	63.1	56.3	51.0
		MCDB	53.4	55.0	60.6	66.0	73.1	81.8	83.6	83.2	76.9	69.9	60.5	55.1
Mean Daily Temperature Range	5% DB	MDBR	16.8	18.8	20.8	21.3	22.0	23.3	23.6	24.1	22.0	19.1	17.0	17.1
		MCDBR	19.8	23.8	25.3	26.6	27.4	27.9	26.8	28.2	25.8	22.3	20.1	19.9
		MCWBR	13.7	15.2	14.4	13.9	12.7	11.7	10.5	11.4	11.6	12.1	13.1	14.0
	5% WB	MCDBR	17.6	21.9	22.6	24.9	25.0	26.5	24.7	26.2	23.1	20.2	17.8	17.6
		MCWBR	13.0	15.1	13.7	14.1	13.0	12.0	11.4	12.8	12.4	12.1	12.4	13.2
Clear-Sky Solar Irradiance	taub	0.319	0.337	0.373	0.393	0.403	0.403	0.396	0.394	0.383	0.380	0.345	0.316	
	taud	2.484	2.432	2.352	2.314	2.333	2.360	2.380	2.389	2.408	2.420	2.466	2.499	
	Ebn at Noon	257	272	274	277	276	276	276	273	267	252	244	247	
	Edh at Noon	23	28	35	39	39	38	37	36	32	29	23	21	
All-Sky Solar Radiation	RadAvg	564	872	1293	1688	2035	2349	2347	2014	1531	968	620	489	
	RadStd	58	84	98	117	142	96	91	64	86	84	70	49	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (33 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page