

SALON-DE-PROVENCE AP, France

WMO: 076480

Lat: 43.606N

Lon: 5.109E

Elev: 59

StdP: 100.61

Time Zone: 1.00 (EUC)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-3.7	-2.2	-9.3	1.7	0.7	-7.1	2.1	1.3	16.2	6.2	14.4	6.7	2.0	320	0.505

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.1	33.6	21.0	32.2	20.6	30.9	20.2	23.1	30.1	22.2	29.3	21.5	28.4	4.4	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.8	15.6	26.3	20.0	14.8	25.4	19.0	13.9	25.0	68.5	30.0	65.4	29.4	62.5	28.5	25.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
14.1	12.3	10.7	-6.1	36.3	1.8	2.2	-7.4	37.9	-8.4	39.2	-9.5	40.5	-10.8	42.1		
			-6.9	24.4	1.9	0.8	-8.2	25.0	-9.3	25.5	-10.4	25.9	-11.7	26.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	14.7	6.3	6.8	10.2	13.3	17.1	21.4	23.9	23.4	19.8	15.7	10.2	7.2
	DBStd	6.93	3.25	3.30	2.95	2.59	2.79	3.02	2.56	2.54	2.67	3.18	3.51	3.21
	HDD10.0	393	123	94	33	3	0	0	0	0	0	3	39	98
	HDD18.3	1863	374	322	252	152	57	7	2	2	15	91	244	346
	CDD10.0	2092	7	6	39	103	219	343	429	416	294	181	45	11
	CDD18.3	520	0	0	0	1	18	100	173	159	59	10	0	0
	CDH23.3	5512	0	0	1	22	228	1103	1902	1669	531	55	0	0
	CDH26.7	2066	0	0	0	1	43	400	808	687	124	3	0	0
Wind	WSAvg	3.9	4.1	4.4	4.2	4.0	3.9	3.8	3.9	3.5	3.5	3.5	3.9	3.6
Precipitation	PrecAvg	539	39	50	48	42	37	29	15	37	57	77	62	50
	PrecMax	879	122	108	130	109	112	63	65	129	153	205	193	126
	PrecMin	237	0	4	0	0	0	1	0	0	0	11	0	15
	PrecStd	140	29	33	40	32	30	14	19	35	40	48	48	26
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.4	18.5	22.0	25.7	30.2	34.7	34.9	35.7	31.3	26.7	20.9	17.1
		MCWB	11.9	11.4	12.9	16.0	19.0	22.4	20.8	21.8	19.8	18.4	15.7	13.0
	2%	DB	15.1	16.2	19.9	23.6	27.7	32.5	33.4	33.7	29.6	24.8	19.3	15.8
		MCWB	11.0	10.5	12.5	14.9	17.9	20.5	20.8	21.1	19.3	18.3	14.9	12.2
	5%	DB	13.7	14.6	18.2	21.8	25.8	30.7	32.2	32.0	28.0	23.4	17.7	14.5
		MCWB	10.2	9.8	11.7	14.0	16.7	20.0	20.6	20.9	18.9	17.5	14.0	11.1
	10%	DB	12.3	13.1	16.8	20.1	24.2	29.0	31.0	30.4	26.5	22.0	16.3	13.2
		MCWB	9.1	9.0	11.1	13.0	16.2	19.3	20.3	20.3	18.5	16.7	13.1	10.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.0	12.4	14.5	17.0	20.4	23.6	24.0	24.0	22.3	20.3	17.0	14.1
		MCDB	16.1	16.4	19.7	23.4	27.7	32.6	30.4	30.7	26.6	24.4	19.1	16.4
	2%	WB	11.7	11.4	13.4	15.6	18.8	22.1	23.0	23.1	21.1	19.1	15.5	12.7
		MCDB	14.4	14.9	18.1	22.1	25.5	29.4	30.0	30.1	26.3	23.3	18.2	14.9
	5%	WB	10.6	10.5	12.5	14.6	17.8	21.0	22.1	22.2	20.3	18.3	14.6	11.7
		MCDB	13.3	13.8	17.0	20.6	24.0	28.3	29.5	29.4	25.7	22.3	17.3	14.0
	10%	WB	9.4	9.4	11.6	13.7	16.8	20.0	21.3	21.4	19.4	17.3	13.5	10.6
		MCDB	11.9	12.8	15.9	18.9	22.8	27.7	28.7	28.4	24.9	21.1	15.9	12.8
Mean Daily Temperature Range	5% DB	MDBR	9.3	10.4	11.5	11.9	12.2	12.9	13.1	13.4	12.2	10.6	9.5	9.5
		MCDBR	11.0	13.2	14.1	14.8	15.2	15.5	14.9	15.6	14.3	12.4	11.2	11.1
		MCWBR	7.6	8.4	8.0	7.7	7.0	6.5	5.8	6.4	6.4	6.7	7.3	7.8
	5% WB	MCDBR	9.8	12.2	12.5	13.9	13.9	14.7	13.7	14.6	12.9	11.2	9.9	9.8
		MCWBR	7.2	8.4	7.6	7.8	7.2	6.7	6.3	7.1	6.9	6.7	6.9	7.4
Clear-Sky Solar Irradiance	taub	0.319	0.337	0.373	0.393	0.403	0.403	0.396	0.394	0.383	0.380	0.345	0.316	
	taud	2.484	2.432	2.352	2.314	2.333	2.360	2.380	2.389	2.408	2.420	2.466	2.499	
	Ebn at Noon	811	856	863	872	871	869	871	861	842	793	770	780	
	Edh at Noon	72	89	109	122	124	121	117	112	102	90	73	65	
All-Sky Solar Radiation	RadAvg	1.78	2.75	4.08	5.32	6.41	7.41	7.40	6.35	4.83	3.05	1.96	1.54	
	RadStd	0.18	0.27	0.31	0.37	0.45	0.30	0.29	0.20	0.27	0.26	0.22	0.15	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (33 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page