

CAP POMEgues, France

WMO: 076520

Lat: 43.2651N

Lon: 5.2897E

Elev: 230

StdP: 14.57

Time Zone: 1.00 (EUC)

Period: 82-91

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	29.4	35.2	22.7	17.2	35.4	25.8	20.0	38.0	59.2	40.6	57.8	43.1	21.1	0	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.3	83.5	71.6	81.1	71.5	79.3	70.7	75.5	79.6	74.2	78.3	72.9	77.1	12.2	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
74.2	128.9	78.0	72.8	122.6	77.0	71.5	117.2	75.8	39.1	80.0	37.8	78.4	36.7	77.3	80.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 52.5	46.3	40.0	DB	27.5	88.2	8.0	3.6	21.7	90.8	17.0	92.9	12.5	94.9	6.7	97.6	(4)
(5)			WB	25.1	77.7	7.4	1.7	19.8	78.9	15.5	79.9	11.3	80.9	6.0	82.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	59.7	48.2	47.1	50.9	55.5	61.6	67.5	74.4	72.9	69.2	63.3	54.9	50.5
	DBStd	10.47	6.05	6.41	4.62	3.69	4.67	3.98	3.67	3.86	3.80	4.48	5.70	4.55
	HDD50	333	92	118	44	6	0	0	0	0	0	0	23	50
	HDD65	2741	522	502	436	286	126	21	0	1	10	85	302	450
	CDD50	3887	35	36	73	170	359	525	756	709	576	412	171	65
	CDD65	823	0	0	0	0	20	96	291	246	136	33	1	0
	CDH74	2804	0	0	0	0	17	149	1419	992	216	11	0	0
	CDH80	331	0	0	0	0	0	8	215	102	6	0	0	0
Wind	WSAvg	15.7	16.3	17.4	18.3	18.3	14.0	15.1	13.6	13.9	13.9	15.1	17.0	15.7
Precipitation	PrecAvg	22.0	1.9	1.9	1.6	2.0	1.6	1.1	0.5	1.1	2.6	3.1	2.6	1.9
	PrecMax	34.0	5.4	8.9	4.1	6.2	4.8	3.8	3.3	5.2	9.1	12.1	7.6	5.4
	PrecMin	10.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	6.0	1.4	1.6	1.1	1.4	1.3	0.9	0.7	1.1	2.4	2.6	1.9	1.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	58.8	61.5	65.5	67.2	76.1	81.3	89.5	85.1	82.0	75.4	68.6	62.6
		MCWB	53.8	55.2	56.6	56.8	63.6	71.5	73.9	72.2	68.7	66.1	58.2	58.4
	2%	DB	57.4	59.0	61.6	64.7	72.9	78.3	85.4	82.8	78.7	72.9	64.8	59.7
		MCWB	53.1	53.7	54.6	55.6	63.3	69.3	72.0	72.3	69.7	65.9	58.7	55.8
	5%	DB	56.1	56.6	59.4	62.6	70.7	75.3	82.0	80.7	76.7	71.4	63.5	58.2
		MCWB	52.4	52.1	53.6	54.6	63.0	67.2	71.2	72.4	68.3	65.5	58.1	54.6
	10%	DB	54.9	54.9	57.3	60.8	68.8	73.4	79.9	78.8	74.9	69.6	61.9	57.0
		MCWB	51.4	51.3	52.7	53.9	62.0	65.3	70.8	71.0	68.1	64.4	57.3	53.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	56.1	56.7	58.2	59.7	69.5	75.0	78.3	77.7	73.5	70.1	62.0	59.3
		MCDB	57.6	61.1	63.1	63.7	71.7	78.2	80.9	81.1	76.3	72.7	64.4	62.0
	2%	WB	54.6	54.9	55.7	57.8	66.5	71.5	75.7	75.6	72.3	68.3	60.6	57.2
		MCDB	56.5	58.1	59.6	61.5	70.1	76.4	79.8	79.7	75.1	70.9	63.4	59.1
	5%	WB	53.1	53.2	54.5	56.8	64.6	69.2	74.4	74.3	71.2	66.7	59.1	55.3
		MCDB	55.5	55.7	58.1	60.2	68.7	73.3	79.0	78.3	74.1	69.9	62.2	57.5
	10%	WB	51.7	52.0	53.4	55.7	62.8	67.5	73.1	72.9	70.0	65.4	57.7	53.9
		MCDB	54.3	54.6	56.9	59.0	67.4	71.8	78.0	76.8	73.4	69.0	61.5	56.6
Mean Daily Temperature Range	5% DB	MDBR	7.5	7.9	8.4	8.8	8.9	9.1	9.3	8.9	8.7	8.1	6.9	6.8
		MCDBR	8.4	8.9	10.7	11.0	11.9	11.0	11.7	11.1	10.7	8.7	7.0	7.6
		MCWBR	7.2	6.8	7.0	7.4	7.4	6.8	7.0	7.6	7.0	5.7	5.6	6.2
	5% WB	MCDBR	7.5	8.6	9.0	8.8	9.9	9.1	8.5	8.9	8.0	6.9	6.0	7.0
		MCWBR	7.1	7.3	6.9	6.9	7.5	7.0	7.3	7.8	6.7	5.9	6.3	7.1
Clear-Sky Solar Irradiance	taub	0.321	0.337	0.370	0.395	0.405	0.404	0.399	0.397	0.386	0.378	0.345	0.317	
	taud	2.499	2.455	2.382	2.325	2.344	2.374	2.392	2.402	2.418	2.445	2.484	2.513	
	Ebn at Noon	259	272	275	276	276	275	276	272	267	253	246	249	
	Edh at Noon	23	28	34	38	39	38	37	35	32	28	23	21	
All-Sky Solar Radiation	RadAvg	579	883	1314	1716	2067	2379	2368	2043	1551	992	638	503	
	RadStd	57	85	98	109	142	88	82	65	82	81	67	49	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (29 neighbors)	+0.54	N/A	N/A	+1.17	N/A	N/A	N/A	N/A	N/A	+90

Nomenclature: See separate page