

CAP COURONNE, France

WMO: 076530

Lat: 43.332N

Lon: 5.053E

Elev: 89

StdP: 14.65

Time Zone: 1.00 (EUC)

Period: 82-07

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 27.3	(c) 32.7	(d) 18.1	(e) 13.7	(f) 29.6	(g) 23.0	(h) 17.4	(i) 35.2	(j) 46.2	(k) 37.4	(l) 41.7	(m) 40.7	(n) 17.8	(o) 340	(p) 0.559

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.3	87.3	72.7	85.0	72.2	83.0	71.3	76.7	83.7	75.3	82.1	73.7	80.3	13.2	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
74.5	129.6	81.4	73.1	123.3	79.9	71.5	116.8	78.1	40.2	83.8	38.7	82.0	37.3	80.5	83.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
38.1	33.6	29.8		DB	25.4	93.3	6.7	2.7	20.5	95.3	16.6	96.9	12.8	98.4	7.9	100.4
				WB	22.2	80.1	7.4	1.3	16.8	81.0	12.5	81.8	8.3	82.5	2.9	83.5

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	60.1	46.4	46.7	51.8	56.1	63.2	69.6	76.4	74.1	70.3	63.3	53.5	48.4
	DBStd	11.64	6.97	6.53	4.95	3.98	4.89	4.45	3.66	4.02	4.04	4.53	6.72	5.81
	HDD50	455	142	125	39	5	0	0	0	0	0	0	44	100
	HDD65	2822	576	511	408	267	94	11	0	0	8	85	347	515
	CDD50	4129	30	34	96	189	408	587	819	748	608	412	148	50
	CDD65	1021	0	0	0	1	37	148	354	283	166	31	1	0
	CDH74	5704	0	0	0	4	105	623	2631	1724	594	23	0	0
	CDH80	1301	0	0	0	0	10	96	711	407	77	0	0	0
(14) Wind	WSAvg	13.4	14.1	13.9	14.7	15.2	11.7	12.0	11.6	12.8	12.0	13.7	14.9	14.1
(15) Precipitation	PrecAvg	19.7	1.8	1.3	1.0	1.9	1.5	1.0	0.4	0.9	3.0	2.8	2.6	1.6
	PrecMax	28.9	5.4	4.6	2.8	5.4	3.5	4.3	2.6	2.9	8.3	5.6	6.4	5.9
	PrecMin	9.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.9	0.2	0.0
	PrecStd	5.4	1.5	1.2	0.8	1.3	1.1	1.1	0.6	0.8	2.2	1.3	1.7	1.6
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	61.2	63.2	67.7	72.0	81.0	86.4	93.0	91.3	86.2	76.3	67.6	62.9
		MCWB	52.5	56.0	59.1	60.8	67.2	71.1	73.3	75.1	69.0	68.1	60.0	57.8
	2%	DB	58.0	59.1	64.2	67.9	76.7	83.0	88.1	86.9	81.9	73.9	65.6	60.3
		MCWB	54.0	53.5	55.7	57.7	66.2	68.8	73.0	73.0	69.1	66.5	59.7	56.6
	5%	DB	56.6	57.1	61.4	65.5	74.0	80.0	85.5	84.3	79.4	71.9	64.2	58.5
		MCWB	52.9	52.6	54.2	56.8	64.4	67.4	72.9	72.1	68.9	65.5	59.0	55.4
	10%	DB	55.2	55.4	59.3	63.4	71.6	77.6	83.7	81.8	77.4	70.1	62.6	56.9
		MCWB	51.7	51.9	53.0	56.0	63.3	66.8	72.4	71.3	68.4	64.6	58.4	53.8
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	55.9	57.8	60.3	62.1	69.4	74.3	78.3	79.8	74.4	70.1	63.0	59.5
		MCDB	57.4	62.7	67.8	70.3	76.0	82.7	85.9	86.6	80.1	74.6	65.1	60.9
	2%	WB	54.6	55.3	57.4	59.7	67.4	71.8	76.7	77.2	72.8	68.4	61.2	57.5
		MCDB	56.4	57.8	62.6	65.4	74.3	78.3	83.7	84.2	78.0	71.6	63.3	58.7
	5%	WB	53.3	53.7	55.7	58.4	65.8	69.9	75.5	75.5	71.6	67.3	59.4	55.5
		MCDB	55.6	56.5	59.6	63.5	72.3	76.4	82.6	82.0	77.3	70.4	62.7	57.7
	10%	WB	51.3	52.2	54.4	57.1	64.3	68.4	74.3	73.7	70.3	65.9	57.9	54.0
		MCDB	54.4	55.3	58.1	61.6	70.3	74.6	81.2	79.9	75.6	69.3	61.9	56.5
(35) Mean Daily Temperature Range	5% DB	MDBR	9.9	10.5	11.9	12.8	13.2	13.6	14.3	13.9	13.2	10.6	9.2	9.1
		MCDBR	9.2	10.9	14.4	16.1	16.5	16.7	16.7	17.5	16.2	12.6	8.7	8.6
		MCWBR	7.5	8.2	10.2	10.7	10.0	9.0	9.4	10.0	9.3	8.5	7.2	7.4
	5% WB	MCDBR	8.2	10.3	12.9	14.2	15.4	14.2	14.7	14.5	13.4	10.5	8.4	8.4
		MCWBR	7.7	8.1	9.7	10.2	9.8	8.6	9.7	10.4	8.9	7.8	7.7	8.0
(40) Clear-Sky Solar Irradiance	taub		0.326	0.343	0.378	0.400	0.409	0.409	0.403	0.401	0.390	0.386	0.351	0.322
	taud		2.485	2.437	2.354	2.313	2.333	2.363	2.382	2.392	2.410	2.419	2.464	2.499
	Ebn at Noon		256	270	272	275	274	274	271	266	250	243	246	246
	Edh at Noon		23	28	35	39	39	38	37	36	33	29	23	21
(44) All-Sky Solar Radiation	RadAvg		574	881	1309	1714	2064	2375	2364	2033	1544	983	634	499
(45)	RadStd		58	85	96	112	138	90	83	66	83	82	68	49

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (32 neighbors)	+0.52	N/A	N/A	+1.17	N/A	N/A	N/A	N/A	N/A	+88

Nomenclature: See separate page