

TOULON LA MITRE, France

WMO: 076600

Lat: 43.1038N

Lon: 5.9314E

Elev: 82

StdP: 14.65

Time Zone: 1.00 (EUC)

Period: 99-17

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 35.5	(c) 38.0	(d) 16.6	(e) 12.8	(f) 41.8	(g) 20.9	(h) 15.7	(i) 42.7	(j) 39.9	(k) 47.6	(l) 34.2	(m) 53.1	(n) 8.5	(o) 300	(p) 0.502

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 15.8	(c) 89.4	(d) 71.3	(e) 86.9	(f) 70.6	(g) 84.6	(h) 70.2	(i) 76.1	(j) 83.3	(k) 74.6	(l) 82.1	(m) 73.3	(n) 81.1	(o) 10.3	(p) 280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
73.8	126.3	80.8	72.2	119.4	79.6	70.6	113.1	78.4	39.5	83.2	38.1	82.1	36.9	81.4	80.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
38.7	31.8	26.4	33.1	94.6	3.0	1.6	30.9	95.7	29.1	96.7	27.4	97.6	25.2	98.7		
			28.5	77.6	2.9	1.8	26.5	78.9	24.8	80.0	23.2	81.0	21.1	82.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	62.0	49.2	50.0	53.8	58.5	64.9	72.1	76.2	76.1	71.0	63.9	56.2	50.9		
	DBStd	10.64	4.53	4.29	4.30	3.78	4.13	4.20	4.08	3.56	3.93	4.54	5.16	4.88		
	HDD50	189	69	46	15	0	0	0	0	0	0	0	12	47		
	HDD65	2283	489	419	348	197	51	2	0	0	3	73	265	436		
	CDD50	4563	45	47	133	256	463	663	811	810	630	430	198	77		
	CDD65	1179	0	0	1	2	49	215	346	345	183	38	0	0		
	CDH74	7421	0	0	1	7	172	1261	2663	2474	794	49	0	0		
	CDH80	1974	0	0	0	0	18	286	828	718	123	1	0	0		
(14) Wind	WSAvg	10.6	9.9	11.4	12.1	12.6	12.2	10.0	10.0	8.7	9.0	10.4	10.8	10.3		
(15) Precipitation	PrecAvg	26.5	3.0	3.5	2.4	2.2	1.7	0.9	0.3	1.2	2.0	3.7	2.8	3.0		
	PrecMax	42.8	11.5	12.0	6.3	7.1	7.4	4.0	1.1	7.0	6.1	12.8	10.2	5.8		
	PrecMin	13.0	0.0	0.0	0.0	0.3	0.0	0.1	0.0	0.0	0.0	0.2	0.0	0.6		
	PrecStd	6.8	2.4	2.6	1.5	1.7	1.7	0.8	0.3	1.5	1.6	3.3	2.2	1.7		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	63.1	62.8	70.2	74.4	82.3	90.0	93.0	92.6	86.3	78.3	69.5	63.6		
		MCWB	53.3	52.3	55.9	60.5	65.9	70.4	72.3	72.9	70.4	67.0	61.3	56.0		
	2%	DB	59.5	60.3	65.7	71.0	78.4	86.0	89.9	89.0	83.3	75.1	66.7	61.2		
		MCWB	52.3	51.9	55.1	58.8	64.1	69.9	71.7	71.1	69.0	65.9	60.3	55.4		
	5%	DB	57.7	58.3	63.1	68.3	75.3	83.2	87.3	86.5	80.9	72.9	65.1	59.5		
		MCWB	52.2	51.0	54.1	57.9	62.4	68.5	71.0	70.5	67.4	64.8	59.4	54.6		
	10%	DB	56.1	56.5	60.7	65.9	73.0	80.8	84.7	84.1	78.6	70.9	63.5	58.0		
		MCWB	51.2	50.4	52.8	56.5	62.0	67.7	70.5	70.7	67.1	64.0	58.4	53.5		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	56.5	55.5	58.5	63.6	69.1	75.4	78.2	78.1	74.3	70.2	63.8	59.3		
		MCDB	59.0	59.2	65.5	71.1	75.8	83.3	87.1	84.2	80.9	74.9	67.0	61.4		
	2%	WB	55.2	54.0	56.9	61.1	67.0	73.5	76.3	76.2	72.5	68.3	62.2	57.1		
		MCDB	58.0	57.4	63.1	68.1	74.4	81.0	84.2	82.7	79.2	72.6	65.2	59.6		
	5%	WB	53.7	52.9	55.6	59.3	65.2	71.8	74.7	74.7	71.0	66.7	60.8	55.6		
		MCDB	56.7	56.5	60.6	65.7	72.4	79.1	82.5	82.0	77.5	71.1	63.9	58.4		
	10%	WB	51.9	51.5	54.3	57.9	63.7	70.1	73.3	73.3	69.3	65.2	59.3	54.2		
		MCDB	55.5	55.7	59.1	63.7	70.6	77.8	81.1	81.4	75.8	69.7	63.0	57.5		
(35) Mean Daily Temperature Range	5% DB	MDBR	10.9	12.1	13.2	13.6	14.1	15.6	15.8	15.6	15.0	12.3	11.2	10.7		
		MCDBR	11.8	14.1	16.6	17.7	18.1	19.0	19.1	19.3	17.8	15.0	12.5	11.4		
		MCWBR	8.8	10.0	10.4	10.8	10.2	9.8	9.6	10.3	10.3	9.5	8.8	8.6		
	5% WB	MCDBR	9.0	11.8	14.2	16.0	15.6	16.0	15.6	15.0	14.3	12.5	10.0	8.9		
		MCWBR	8.1	9.5	9.8	10.6	10.2	9.8	10.3	10.7	9.6	8.8	8.1	7.8		
(40) Clear-Sky Solar Irradiance	taub		0.329	0.346	0.381	0.407	0.416	0.415	0.409	0.406	0.397	0.389	0.355	0.325		
	taud		2.482	2.432	2.349	2.294	2.312	2.350	2.370	2.386	2.396	2.409	2.452	2.496		
	Ebn at Noon		255	269	272	273	272	272	270	264	249	242	242	246		
	Edh at Noon		23	29	35	40	40	39	38	36	33	29	24	21		
(44) All-Sky Solar Radiation	RadAvg		585	876	1315	1708	2050	2364	2357	2048	1549	999	640	508		
	RadStd		56	86	105	109	148	89	88	68	81	79	66	51		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (26 neighbors)	+0.52	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+90

Nomenclature: See separate page