

TOULON LA MITRE, France

WMO: 076600

Lat: 43.1038N

Lon: 5.9314E

Elev: 25

StdP: 101.03

Time Zone: 1.00 (EUC)

Period: 99-17

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	1.9	3.3	-8.6	1.8	5.5	-6.2	2.2	6.0	17.8	8.7	15.3	11.7	3.8	300	0.502

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.8	31.9	21.8	30.5	21.4	29.2	21.2	24.5	28.5	23.7	27.8	22.9	27.3	4.6	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.2	18.0	27.1	22.3	17.1	26.5	21.5	16.2	25.8	74.0	28.4	70.8	27.8	67.9	27.4	27.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.3	14.2	11.8	0.6	34.8	1.7	0.9	-0.6	35.4	-1.6	35.9	-2.5	36.4	-3.8	37.1
			-1.9	25.3	1.6	1.0	-3.1	26.1	-4.0	26.7	-4.9	27.2	-6.1	28.0

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	16.7	9.6	10.0	12.1	14.7	18.3	22.3	24.5	24.5	21.7	17.7	13.4	10.5
	DBStd	5.91	2.52	2.38	2.39	2.10	2.29	2.34	2.27	1.98	2.18	2.52	2.87	2.71
	HDD10.0	105	38	26	8	0	0	0	0	0	0	7	26	
	HDD18.3	1268	272	233	193	109	28	1	0	2	41	147	242	
	CDD10.0	2535	25	26	74	142	257	368	451	450	350	239	110	43
	CDD18.3	655	0	0	1	1	27	119	192	192	102	21	0	0
	CDH23.3	4123	0	0	1	4	96	701	1479	1374	441	27	0	0
	CDH26.7	1097	0	0	0	0	10	159	460	399	68	1	0	0
Wind	WSAvg	4.7	4.4	5.1	5.4	5.6	5.5	4.5	4.5	3.9	4.0	4.7	4.8	4.6
Precipitation	PrecAvg	673	76	88	60	55	44	22	7	30	50	95	70	75
	PrecMax	1086	292	305	159	180	188	101	27	178	155	326	260	148
	PrecMin	331	0	0	0	8	0	2	0	0	0	4	0	16
	PrecStd	172	60	66	39	42	43	21	8	37	41	84	57	43
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.3	17.1	21.2	23.6	27.9	32.2	33.9	33.7	30.2	25.7	20.8	17.6
		MCWB	11.8	11.3	13.3	15.8	18.8	21.3	22.4	22.7	21.3	19.4	16.3	13.3
	2%	DB	15.3	15.7	18.7	21.6	25.8	30.0	32.2	31.7	28.5	24.0	19.3	16.2
		MCWB	11.3	11.0	12.8	14.9	17.8	21.1	22.1	21.7	20.5	18.8	15.7	13.0
	5%	DB	14.3	14.6	17.3	20.1	24.1	28.5	30.7	30.3	27.1	22.7	18.4	15.3
		MCWB	11.2	10.5	12.3	14.4	16.9	20.3	21.7	21.4	19.7	18.2	15.2	12.6
	10%	DB	13.4	13.6	16.0	18.8	22.8	27.1	29.3	29.0	25.9	21.6	17.5	14.5
		MCWB	10.6	10.2	11.6	13.6	16.7	19.9	21.4	21.5	19.5	17.8	14.6	11.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.6	13.1	14.7	17.6	20.6	24.1	25.7	25.6	23.5	21.2	17.7	15.2
		MCDB	15.0	15.1	18.6	21.7	24.3	28.5	30.6	29.0	27.2	23.8	19.5	16.3
	2%	WB	12.9	12.2	13.8	16.1	19.4	23.1	24.6	24.5	22.5	20.1	16.8	13.9
		MCDB	14.4	14.1	17.3	20.1	23.6	27.2	29.0	28.2	26.2	22.6	18.5	15.3
	5%	WB	12.0	11.6	13.1	15.2	18.4	22.1	23.7	23.7	21.7	19.3	16.0	13.1
		MCDB	13.7	13.6	15.9	18.7	22.4	26.2	28.0	27.8	25.3	21.7	17.7	14.7
	10%	WB	11.1	10.9	12.4	14.4	17.6	21.1	22.9	23.0	20.7	18.4	15.2	12.3
		MCDB	13.1	13.2	15.1	17.6	21.4	25.4	27.3	27.5	24.3	21.0	17.2	14.2
Mean Daily Temperature Range	5% DB	MDBR	6.0	6.7	7.3	7.5	7.8	8.7	8.8	8.7	8.4	6.8	6.2	5.9
		MCDBR	6.5	7.8	9.2	9.8	10.1	10.6	10.6	10.7	9.9	8.3	6.9	6.4
		MCWBR	4.9	5.5	5.8	6.0	5.7	5.5	5.4	5.7	5.7	5.3	4.9	4.8
	5% WB	MCDBR	5.0	6.6	7.9	8.9	8.6	8.9	8.7	8.3	8.0	7.0	5.6	5.0
		MCWBR	4.5	5.3	5.4	5.9	5.7	5.4	5.7	5.9	5.3	4.9	4.5	4.4
Clear-Sky Solar Irradiance	taub	0.329	0.346	0.381	0.407	0.416	0.415	0.409	0.406	0.397	0.389	0.355	0.325	
	taud	2.482	2.432	2.349	2.294	2.312	2.350	2.370	2.386	2.396	2.409	2.452	2.496	
	Ebn at Noon	805	849	857	860	859	859	859	851	831	786	762	774	
	Edh at Noon	73	90	110	125	127	122	119	113	104	92	75	67	
All-Sky Solar Radiation	RadAvg	1.84	2.76	4.14	5.38	6.46	7.45	7.43	6.46	4.88	3.15	2.02	1.60	
	RadStd	0.18	0.27	0.33	0.34	0.47	0.28	0.28	0.21	0.25	0.25	0.21	0.16	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (26 neighbors)	+0.29	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+50

Nomenclature: See separate page