

CAP CEPET, France

WMO: 076610

Lat: 43.079N

Lon: 5.941E

Elev: 134

StdP: 99.73

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	1.9	3.3	-8.4	1.9	4.9	-6.2	2.3	5.9	21.9	10.6	19.9	10.2	6.5	330	0.582

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.5	30.4	21.3	29.2	21.2	28.1	20.9	24.2	27.6	23.4	26.8	22.6	26.2	5.4	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.2	18.3	26.4	22.2	17.2	25.7	21.3	16.2	25.0	73.8	27.5	70.3	26.8	67.1	26.2	28.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
18.3	16.2	14.3	DB	0.7	32.9	1.8	1.3	-0.6	33.8	-1.6	34.6	-2.6	35.3	-3.9	36.3	(4)
			WB	-2.0	25.0	1.8	1.4	-3.3	26.0	-4.3	26.8	-5.3	27.5	-6.6	28.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	15.9	9.1	9.2	11.5	13.9	17.4	21.4	23.9	24.1	20.3	17.1	12.7	10.1	(6)
(7)		DBStd	5.88	2.50	2.57	2.30	2.33	2.36	2.44	2.14	2.05	2.29	2.40	2.74	2.68	(7)
(8)		HDD10.0	141	46	40	12	2	0	0	0	0	1	9	32	(8)	
(9)		HDD18.3	1424	286	257	213	134	46	3	0	8	51	170	256	(9)	
(10)		CDD10.0	2305	18	16	57	118	228	343	432	438	311	221	89	34	(10)
(11)		CDD18.3	547	0	0	0	1	16	96	173	180	68	13	0	0	(11)
(12)		CDH23.3	3016	0	0	0	1	36	439	1139	1192	203	5	0	0	(12)
(13)		CDH26.7	619	0	0	0	0	2	71	252	279	14	0	0	0	(13)
(14)	Wind	WSAvg	6.1	6.5	6.3	6.8	6.4	6.1	5.4	6.0	5.4	5.7	6.0	6.5	6.5	(14)
(15)	Precipitation	PrecAvg	670	70	49	39	62	42	31	10	16	79	101	102	69	(15)
(16)		PrecMax	1077	196	144	120	154	102	109	45	67	182	248	268	198	(16)
(17)		PrecMin	332	0	0	0	8	0	0	0	3	30	29	3	(17)	
(18)		PrecStd	169	58	41	33	41	32	33	10	19	51	53	64	53	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	16.3	16.2	19.8	22.5	26.6	30.9	32.1	32.4	28.2	24.1	19.7	16.7	(19)
(20)			MCWB	11.3	10.7	12.1	14.5	17.5	20.8	21.1	21.7	20.1	17.9	15.5	12.4	(20)
(21)		2%	DB	14.6	14.7	17.4	20.6	24.1	28.4	30.4	30.6	26.7	22.8	18.2	15.4	(21)
(22)			MCWB	10.8	10.3	11.6	14.0	16.6	20.2	21.3	21.4	19.8	17.9	15.2	12.4	(22)
(23)		5%	DB	13.5	13.6	16.2	19.2	22.6	27.0	29.2	29.3	25.6	21.7	17.3	14.5	(23)
(24)			MCWB	10.7	10.1	11.4	13.3	16.1	19.8	21.3	21.3	19.3	17.5	14.7	12.0	(24)
(25)		10%	DB	12.7	12.7	15.1	17.8	21.4	25.8	28.0	28.2	24.4	20.6	16.5	13.7	(25)
(26)			MCWB	10.3	9.7	10.9	12.8	15.7	19.3	20.9	21.1	18.6	17.0	14.0	11.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.1	12.7	13.8	16.5	19.6	23.6	25.4	25.8	22.9	20.5	17.3	14.5	(27)
(28)			MADB	14.2	13.9	16.7	20.0	22.9	27.8	28.6	28.7	25.6	22.2	18.2	15.4	(28)
(29)		2%	WB	12.3	11.9	13.1	15.2	18.5	22.2	24.2	24.5	21.9	19.5	16.2	13.5	(29)
(30)			MADB	13.6	13.1	15.7	18.6	21.9	25.9	27.8	27.5	24.6	21.2	17.4	14.5	(30)
(31)		5%	WB	11.6	11.2	12.4	14.5	17.6	21.3	23.4	23.6	21.0	18.7	15.5	12.7	(31)
(32)			MADB	12.9	12.7	14.8	17.6	20.9	25.1	27.0	26.8	24.0	20.6	16.7	13.9	(32)
(33)		10%	WB	10.7	10.4	11.8	13.7	16.8	20.5	22.6	22.8	20.1	17.9	14.6	11.9	(33)
(34)			MADB	12.3	12.3	14.0	16.5	20.0	24.3	26.2	26.4	22.9	19.8	16.0	13.3	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.8	5.5	6.1	6.4	6.7	7.2	7.5	7.5	6.8	5.7	5.0	4.7	(35)
(36)			MCDBR	5.1	6.2	7.3	7.9	8.2	8.6	8.7	8.5	7.8	6.5	5.5	5.1	(36)
(37)			MCWBR	4.1	4.7	4.7	4.7	4.7	4.6	4.8	5.2	4.8	4.2	4.2	4.0	(37)
(38)		5% WB	MCDBR	4.2	5.3	6.3	7.0	6.9	7.4	7.4	7.2	6.8	5.5	4.4	4.2	(38)
(39)			MCWBR	4.0	4.5	4.5	4.7	4.7	4.8	5.2	5.4	4.9	4.0	4.1	4.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.323	0.340	0.374	0.398	0.408	0.406	0.401	0.398	0.389	0.382	0.348	0.320	(40)	
(41)		taud	2.493	2.447	2.369	2.317	2.333	2.370	2.387	2.403	2.413	2.427	2.467	2.506	(41)	
(42)		Ebn at Noon	813	857	865	868	867	867	867	859	839	795	771	782	(42)	
(43)		Edh at Noon	72	89	108	123	124	120	117	111	103	90	74	66	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.85	2.76	4.15	5.39	6.47	7.46	7.43	6.46	4.89	3.15	2.02	1.60	(44)	
(45)		RadStd	0.18	0.27	0.33	0.34	0.47	0.28	0.28	0.21	0.25	0.25	0.21	0.16	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (26 neighbors)	+0.29	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+50

Nomenclature: See separate page