

CAP LEUCATE, France

WMO: 076660

Lat: 42.917N

Lon: 3.060E

Elev: 50

StdP: 100.73

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	0.0	1.7	-8.2	1.9	3.8	-6.1	2.3	4.2	25.0	10.8	20.8	10.5	10.7	320	0.630

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.9	31.2	20.2	29.5	20.0	28.1	19.8	23.7	26.1	23.0	25.7	22.3	24.9	7.0	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
23.1	18.0	25.1	22.2	17.0	24.3	21.5	16.2	23.7	71.4	25.9	68.3	25.8	65.6	25.0	26.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
19.4	16.5	14.4	-0.7	34.3	2.3	2.3	-2.4	36.0	-3.7	37.3	-5.0	38.6	-6.6	40.3	
			DB												
			WB	-2.8	24.4	2.2	1.1	-4.4	25.2	-5.7	25.8	-6.9	26.5	-8.5	27.3

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	15.9	8.8	9.1	11.7	14.2	17.1	21.5	24.0	23.7	20.7	17.4	12.6	9.7
	DBStd	6.11	3.28	3.37	2.82	2.52	2.66	2.88	2.35	2.31	2.41	2.89	3.25	3.11
	HDD10.0	182	62	47	14	1	0	0	0	0	0	1	14	42
	HDD18.3	1438	296	257	206	127	54	5	0	0	6	49	171	267
	CDD10.0	2346	24	23	67	127	222	344	435	426	321	230	93	34
	CDD18.3	561	0	0	1	2	17	99	177	167	77	21	1	0
	CDH23.3	2838	0	0	1	7	49	467	1113	947	226	28	0	0
	CDH26.7	661	0	0	0	1	8	112	278	222	37	3	0	0
Wind	WSAvg	6.8	7.4	7.5	7.3	7.0	7.0	6.2	6.2	5.7	5.9	6.8	7.3	6.8
Precipitation	PrecAvg	546	56	41	37	49	46	23	14	26	52	79	73	53
	PrecMax	945	198	115	158	141	123	97	51	92	206	228	227	219
	PrecMin	324	0	0	0	3	7	3	3	1	10	3	8	3
	PrecStd	163	52	34	34	38	30	23	11	20	43	56	66	58
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	18.2	18.2	21.8	24.4	27.3	32.2	33.5	33.2	30.1	26.2	20.6	17.8
		MCWB	12.9	11.7	13.1	15.0	17.9	20.6	20.1	21.1	18.3	18.0	15.3	12.7
	2%	DB	16.1	15.6	18.7	21.4	24.6	29.6	31.2	30.9	27.5	23.6	18.8	15.9
		MCWB	11.9	10.8	12.2	14.1	16.8	20.1	20.0	20.9	18.3	17.9	15.5	12.2
	5%	DB	14.6	14.2	16.9	19.5	22.7	27.6	29.5	29.0	25.7	22.1	17.9	14.8
		MCWB	10.9	10.2	11.5	13.6	16.0	19.7	20.1	20.4	18.0	17.5	15.4	12.2
	10%	DB	13.2	13.1	15.5	18.0	21.1	25.9	28.1	27.5	24.3	20.8	17.1	14.0
		MCWB	10.2	10.2	10.9	13.3	15.5	19.0	19.9	20.1	18.1	17.3	14.6	11.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.7	12.9	14.2	17.0	19.4	23.0	24.9	24.9	22.5	21.0	17.4	14.2
		MCDB	17.1	16.1	18.7	20.4	24.1	26.8	27.1	27.1	24.0	22.2	18.8	15.9
	2%	WB	12.5	12.0	13.2	15.9	18.4	22.1	23.7	24.0	21.7	19.7	16.7	13.4
		MCDB	15.2	13.8	16.4	19.4	21.8	25.8	25.9	26.3	23.1	21.1	18.1	15.0
	5%	WB	11.6	11.4	12.6	14.9	17.7	21.4	23.0	23.2	21.1	19.1	16.0	12.6
		MCDB	13.9	13.3	15.1	17.8	20.7	24.9	25.5	25.8	22.6	20.4	17.4	14.4
	10%	WB	10.7	10.7	12.0	14.2	17.0	20.6	22.2	22.5	20.4	18.6	15.1	11.7
		MCDB	12.8	12.7	14.1	16.6	19.7	24.1	25.0	25.1	22.3	20.0	16.6	13.7
Mean Daily Temperature Range	5% DB	MDBR	5.2	5.4	5.8	5.8	6.0	6.5	6.9	6.6	6.2	5.2	5.0	5.0
		MCDBR	6.2	6.9	7.7	7.8	8.3	8.9	8.8	8.7	8.0	6.6	5.3	5.6
		MCWBR	4.1	4.4	4.2	3.9	4.1	3.7	3.8	3.9	3.6	3.8	3.9	3.9
	5% WB	MCDBR	5.4	5.7	6.1	6.1	6.0	6.4	5.7	5.9	4.8	4.4	4.2	4.8
		MCWBR	4.1	4.2	3.9	3.8	3.7	3.4	3.8	4.0	3.4	3.2	3.6	3.9
Clear-Sky Solar Irradiance	taub	0.316	0.330	0.371	0.398	0.409	0.415	0.413	0.412	0.391	0.375	0.339	0.314	
	taud	2.513	2.473	2.379	2.310	2.333	2.348	2.361	2.370	2.411	2.459	2.503	2.523	
	Ebn at Noon	826	871	870	869	866	859	856	846	838	806	787	794	
	Edh at Noon	71	86	107	123	124	123	120	115	103	87	72	65	
All-Sky Solar Radiation	RadAvg	1.73	2.66	3.85	4.94	5.81	6.69	6.70	5.85	4.51	2.97	1.94	1.54	
	RadStd	0.18	0.27	0.32	0.43	0.41	0.36	0.34	0.31	0.26	0.28	0.21	0.16	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (27 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page