

ILES DE PORQUEROLLES, France

WMO: 076700

Lat: 43.0003N

Lon: 6.2271E

Elev: 482

StdP: 14.44

Time Zone: 1.00 (EUC)

Period: 86-11

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	36.0	38.9	18.8	14.4	40.6	23.1	17.7	42.9	53.0	45.8	48.0	47.2	17.2	280	0.591

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	12.2	85.9	72.6	83.7	72.1	81.8	71.6	76.9	81.6	75.4	80.3	74.0	79.0	11.9	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
75.5	135.8	79.5	73.9	128.8	78.2	72.5	122.6	77.0	40.6	81.7	39.2	80.3	37.9	79.2	82.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4) 46.7	39.8	33.6	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(5)			WB	27.4	77.7	6.7	2.4	22.6	79.4	18.7	80.8	14.9	82.2	10.1	83.9	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	60.9	49.8	49.8	53.0	56.5	63.4	68.3	74.8	75.1	69.6	63.4	55.7	50.6
	DBStd	10.10	4.17	4.90	4.31	4.25	4.51	4.42	3.86	3.75	3.80	4.37	4.77	4.63
	HDD50	194	50	56	23	3	1	0	0	0	0	0	14	47
	HDD65	2441	471	426	373	258	81	17	0	1	8	81	279	446
	CDD50	4175	45	50	114	197	416	549	770	777	589	416	185	67
	CDD65	945	0	0	0	2	32	116	305	313	146	31	0	0
	CDH74	4382	0	0	0	2	62	380	1775	1804	346	13	0	0
	CDH80	822	0	0	0	0	3	40	405	355	19	0	0	0
Wind	WSAvg	14.8	16.3	16.4	16.8	15.5	13.6	13.0	12.3	12.1	13.5	16.3	15.7	15.9
Precipitation	PrecAvg	28.3	3.0	2.1	1.8	2.5	1.7	1.4	0.4	0.7	3.0	4.2	4.4	3.0
	PrecMax	45.5	8.8	5.9	5.9	6.3	4.0	5.5	1.8	3.1	7.7	10.0	13.0	8.4
	PrecMin	15.2	0.0	0.0	0.0	0.3	0.0	0.0	0.0	0.0	0.2	1.1	0.9	0.2
	PrecStd	7.5	2.6	1.8	1.5	1.7	1.2	1.4	0.5	0.7	2.0	2.2	2.9	2.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	61.5	62.4	66.1	73.0	81.4	83.9	89.8	88.9	82.3	75.6	67.0	61.7
		MCWB	53.4	52.9	55.7	59.4	65.1	69.7	73.3	73.4	71.9	65.9	59.4	55.9
	2%	DB	58.1	59.6	63.0	69.1	76.0	80.7	86.8	85.8	79.9	73.3	64.8	59.5
		MCWB	52.4	53.1	54.7	58.8	63.6	69.7	73.1	72.6	70.5	65.0	59.2	55.3
	5%	DB	56.3	57.6	60.9	66.2	73.0	78.2	84.3	83.8	78.0	71.1	63.0	57.7
		MCWB	51.8	51.9	53.8	56.9	62.5	67.7	72.1	72.8	69.8	64.1	58.2	54.4
	10%	DB	54.9	55.9	59.2	63.7	70.7	75.9	82.1	82.0	75.9	68.9	61.3	56.5
		MCWB	51.3	50.9	52.9	55.6	61.7	66.2	71.4	72.6	68.6	63.4	57.3	53.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	55.7	56.4	58.5	62.1	68.4	73.4	77.9	79.8	76.4	69.0	62.8	58.7
		MCDB	57.7	59.4	62.9	69.1	75.0	79.9	84.2	83.6	78.9	72.6	65.1	60.1
	2%	WB	54.4	54.5	56.7	59.9	66.2	71.1	76.3	77.5	74.1	67.6	61.0	57.2
		MCDB	56.3	57.5	60.8	66.5	72.6	77.8	82.3	81.9	77.6	70.7	62.9	58.1
	5%	WB	53.4	53.2	55.4	58.2	64.6	69.8	74.9	76.2	72.2	66.2	59.8	55.6
		MCDB	55.3	56.0	59.3	64.0	70.4	75.5	80.7	80.5	75.6	68.7	61.6	57.1
	10%	WB	52.2	52.1	53.9	56.8	63.2	68.3	73.6	74.7	70.5	64.8	58.6	54.0
		MCDB	54.4	55.0	57.5	61.9	68.7	73.8	79.4	79.2	73.6	67.6	60.4	55.7
Mean Daily Temperature Range	5% DB	MDBR	7.9	9.3	10.3	10.5	11.5	12.0	12.3	12.2	11.4	9.2	8.4	7.9
		MCDBR	9.2	10.7	12.1	13.5	14.3	13.9	14.7	14.3	13.2	10.8	9.8	8.8
		MCWBR	6.7	7.3	7.9	7.6	7.8	7.2	7.2	7.9	7.9	6.8	7.1	7.3
	5% WB	MCDBR	7.3	9.6	11.4	11.9	12.5	12.6	12.8	12.4	11.6	8.8	8.1	6.9
MCWBR		6.5	7.1	7.8	7.5	7.8	7.4	7.8	8.2	8.7	6.4	6.5	7.1	
Clear-Sky Solar Irradiance	taub	0.324	0.341	0.375	0.395	0.405	0.404	0.399	0.395	0.387	0.383	0.350	0.322	
	taud	2.492	2.445	2.367	2.330	2.346	2.382	2.398	2.415	2.424	2.423	2.462	2.504	
	Ebn at Noon	258	272	274	276	276	276	276	273	267	252	244	247	
	Edh at Noon	23	28	34	38	39	38	36	35	32	29	24	21	
All-Sky Solar Radiation	RadAvg	587	871	1315	1708	2045	2360	2354	2051	1549	1002	643	509	
	RadStd	56	87	108	109	149	88	91	70	79	80	64	53	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (25 neighbors)	+0.52	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+79

Nomenclature: See separate page