

ILES DE PORQUEROLLES, France

WMO: 076700

Lat: 43.0003N

Lon: 6.2271E

Elev: 147

StdP: 99.57

Time Zone: 1.00 (EUC)

Period: 86-11

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	2.2	3.8	-7.3	2.1	4.8	-4.9	2.5	6.0	23.7	7.7	21.5	8.4	7.7	280	0.591

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.8	30.0	22.5	28.7	22.3	27.7	22.0	24.9	27.5	24.1	26.8	23.4	26.1	5.3	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.1	19.4	26.4	23.3	18.4	25.7	22.5	17.5	25.0	76.5	27.6	73.3	26.8	70.3	26.2	28.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.9	17.8	15.0	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			-2.6	25.4	3.7	1.3	-5.2	26.3	-7.4	27.1	-9.5	27.9	-12.2	28.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	16.1	9.9	9.9	11.6	13.6	17.4	20.2	23.8	23.9	20.9	17.4	13.2	10.3		
	DBStd	5.61	2.32	2.72	2.39	2.36	2.51	2.46	2.15	2.09	2.11	2.43	2.65	2.57		
	HDD10.0	108	28	31	13	2	1	0	0	0	0	0	8	26		
	HDD18.3	1356	262	237	207	143	45	9	0	1	4	45	155	248		
	CDD10.0	2319	25	28	63	109	231	305	428	432	327	231	103	37		
	CDD18.3	525	0	0	0	1	18	64	169	174	81	17	0	0		
	CDH23.3	2434	0	0	0	1	34	211	986	1002	192	7	0	0		
	CDH26.7	457	0	0	0	0	2	22	225	197	11	0	0	0		
(14) Wind	WSAvg	6.6	7.3	7.3	7.5	6.9	6.1	5.8	5.5	5.4	6.0	7.3	7.0	7.1		
(15) Precipitation	PrecAvg	718	77	54	45	64	43	35	11	17	77	106	112	77		
	PrecMax	1156	223	149	150	159	101	139	45	80	196	253	331	214		
	PrecMin	387	0	0	0	8	0	1	1	0	4	29	24	4		
	PrecStd	190	66	46	38	44	30	36	12	18	52	56	74	55		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	16.4	16.9	19.0	22.8	27.4	28.8	32.1	31.6	28.0	24.2	19.4	16.5		
		MCWB	11.9	11.6	13.2	15.2	18.4	21.0	22.9	23.0	22.2	18.8	15.2	13.3		
	2%	DB	14.5	15.4	17.2	20.6	24.4	27.1	30.4	29.9	26.6	22.9	18.2	15.3		
		MCWB	11.3	11.7	12.6	14.9	17.5	20.9	22.8	22.5	21.4	18.3	15.1	12.9		
	5%	DB	13.5	14.2	16.0	19.0	22.8	25.7	29.1	28.8	25.5	21.7	17.2	14.3		
		MCWB	11.0	11.0	12.1	13.8	16.9	19.8	22.3	22.7	21.0	17.9	14.5	12.5		
	10%	DB	12.7	13.3	15.1	17.6	21.5	24.4	27.9	27.8	24.4	20.5	16.3	13.6		
		MCWB	10.7	10.5	11.6	13.1	16.5	19.0	21.9	22.5	20.4	17.5	14.1	11.8		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.2	13.5	14.7	16.7	20.2	23.0	25.5	26.5	24.6	20.6	17.1	14.8		
		MCDB	14.3	15.2	17.1	20.6	23.9	26.6	29.0	28.6	26.1	22.5	18.4	15.6		
	2%	WB	12.5	12.5	13.7	15.5	19.0	21.7	24.6	25.3	23.4	19.8	16.1	14.0		
		MCDB	13.5	14.2	16.0	19.1	22.5	25.4	28.0	27.7	25.3	21.5	17.2	14.5		
	5%	WB	11.9	11.8	13.0	14.5	18.1	21.0	23.8	24.5	22.3	19.0	15.5	13.1		
		MCDB	12.9	13.3	15.2	17.8	21.3	24.2	27.1	27.0	24.2	20.4	16.4	14.0		
	10%	WB	11.2	11.1	12.2	13.8	17.4	20.2	23.1	23.7	21.4	18.2	14.8	12.2		
		MCDB	12.4	12.8	14.2	16.6	20.4	23.2	26.3	26.2	23.1	19.8	15.8	13.2		
(35) Mean Daily Temperature Range	5% DB	MDBR	4.4	5.2	5.7	5.8	6.4	6.7	6.8	6.8	6.3	5.1	4.7	4.4		
		MCDBR	5.1	6.0	6.7	7.5	7.9	7.7	8.2	7.9	7.3	6.0	5.4	4.9		
	5% WB	MCWBR	3.7	4.1	4.4	4.2	4.3	4.0	4.0	4.4	4.4	3.8	3.9	4.1		
		MCWBR	4.0	5.3	6.3	6.6	7.0	7.1	6.9	6.4	6.4	4.9	4.5	3.8		
(40) Clear-Sky Solar Irradiance	taub		0.324	0.341	0.375	0.395	0.405	0.404	0.399	0.395	0.387	0.383	0.350	0.322		
	taud		2.492	2.445	2.367	2.330	2.346	2.382	2.398	2.415	2.424	2.423	2.462	2.504		
	Ebn at Noon		812	856	864	871	870	869	869	862	842	794	770	780		
	Edh at Noon		73	89	108	121	122	119	115	110	102	90	75	66		
(44) All-Sky Solar Radiation	RadAvg		1.85	2.75	4.15	5.38	6.45	7.44	7.42	6.47	4.88	3.16	2.03	1.60		
	RadStd		0.18	0.27	0.34	0.34	0.47	0.28	0.29	0.22	0.25	0.25	0.20	0.17		

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (25 neighbors)	+0.29	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+44

Nomenclature: See separate page