

LE LUC LE CANNET AP, France

WMO: 076750

Lat: 43.3831N

Lon: 6.3861E

Elev: 265

StdP: 14.56

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	25.6	28.1	13.7	11.1	39.2	17.6	13.5	39.4	31.9	52.9	27.9	52.7	0.9	260	0.468

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	25.2	94.9	69.5	92.3	69.2	89.9	68.4	73.5	87.7	72.0	85.9	70.8	84.7	10.2	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
69.2	108.3	79.9	67.6	102.5	78.1	66.2	97.5	77.1	37.2	87.4	35.8	85.6	34.7	84.9	78.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
26.6	22.9	19.8	21.2	100.3	3.0	2.7	19.0	102.3	17.3	103.8	15.6	105.4	13.4	107.3	DB
			20.0	76.4	3.0	1.5	17.9	77.4	16.1	78.3	14.5	79.2	12.3	80.3	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	59.9	45.4	46.9	51.8	56.9	63.9	71.6	77.0	76.1	68.4	61.3	51.9	46.2	(6)
(7)		DBStd	12.25	5.69	5.42	5.08	4.59	4.73	4.85	4.03	3.98	4.81	5.32	6.14	5.72	(7)
(8)		HDD50	516	164	111	38	4	0	0	0	0	2	51	146		(8)
(9)		HDD65	2984	607	506	410	244	77	5	0	21	136	393	584		(9)
(10)		CDD50	4122	22	25	94	211	431	649	838	810	553	354	108	27	(10)
(11)		CDD65	1113	0	0	1	1	43	204	373	346	123	22	0	0	(11)
(12)		CDH74	12791	0	0	9	67	509	2384	4457	3923	1267	174	1	0	(12)
(13)		CDH80	5490	0	0	0	3	95	929	2190	1884	371	18	0	0	(13)
(14)	Wind	WSAvg	6.6	6.1	6.4	7.5	7.3	7.1	6.5	7.6	6.6	6.0	5.5	6.1	5.9	(14)
(15)	Precipitation	PrecAvg	35.1	3.5	2.3	2.2	3.0	2.4	2.0	0.7	1.2	3.6	4.9	5.6	3.7	(15)
(16)		PrecMax	54.5	13.8	7.4	8.1	8.5	5.7	9.5	3.1	3.9	9.3	9.3	17.4	9.1	(16)
(17)		PrecMin	19.4	0.1	0.0	0.2	0.5	0.2	0.2	0.0	0.0	0.3	1.4	1.2	0.4	(17)
(18)		PrecStd	9.1	3.3	2.0	1.9	2.0	1.5	2.0	0.7	0.9	2.5	2.4	4.0	2.4	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	65.4	68.2	74.8	79.8	87.2	95.3	98.1	98.6	90.1	82.4	71.3	63.9	(19)
MCWB			52.2	52.9	55.4	61.6	65.2	68.7	69.4	70.3	67.3	63.8	58.6	53.5	(20)	
2%		DB	60.9	64.1	70.4	75.7	82.5	91.9	95.2	94.7	87.0	78.4	67.5	60.6	(21)	
		MCWB	50.9	51.1	54.1	58.7	63.0	69.0	69.6	69.7	66.6	63.3	57.4	52.6	(22)	
5%		DB	58.2	60.9	67.1	72.8	79.5	88.5	92.5	91.8	84.3	75.3	64.6	58.3	(23)	
		MCWB	49.6	49.8	53.0	56.9	61.7	67.8	69.3	69.0	65.4	62.2	56.1	51.2	(24)	
10%		DB	55.6	58.0	63.9	69.2	76.6	85.5	90.3	89.3	81.5	72.3	62.0	56.0	(25)	
		MCWB	48.3	48.6	51.6	55.4	60.6	66.7	68.8	68.2	64.3	61.2	55.0	50.0	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	54.8	54.8	58.2	63.1	68.4	73.8	75.5	75.4	71.8	68.3	61.7	56.6	(27)
MCD B			59.9	63.7	69.8	75.9	81.0	89.9	90.0	89.5	83.5	76.0	66.3	60.2	(28)	
2%		WB	53.0	52.9	55.8	60.5	65.7	71.3	73.7	73.5	70.0	66.3	59.8	54.7	(29)	
		MCD B	58.0	60.7	65.6	72.8	77.9	86.1	88.0	86.9	80.7	73.4	64.5	58.1	(30)	
5%		WB	51.5	51.4	54.5	58.5	63.8	69.7	72.2	72.0	68.4	64.7	58.4	53.0	(31)	
		MCD B	56.1	58.3	64.1	69.5	75.1	84.6	86.6	85.2	79.0	71.8	62.7	56.5	(32)	
10%		WB	49.7	49.8	53.0	56.7	62.2	68.1	70.8	70.7	66.6	63.0	56.7	51.2	(33)	
		MCD B	54.1	55.9	62.0	66.0	72.9	81.9	85.5	84.3	77.0	69.7	60.5	54.7	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	18.8	20.7	22.4	22.0	22.0	24.4	25.2	25.6	24.0	20.7	18.3	17.7	(35)
MCDBR			22.2	26.3	28.3	28.5	27.1	28.7	28.0	29.7	28.4	25.2	21.6	20.3	(36)	
MCWBR			14.3	16.0	15.3	14.2	12.2	11.4	10.6	11.2	12.3	12.7	13.5	13.7	(37)	
5% WB		MCD BR	16.9	23.3	24.5	25.9	23.8	26.0	25.9	26.1	24.1	20.6	16.5	15.2	(38)	
		MCWBR	12.0	15.3	14.1	13.8	11.9	11.5	11.2	11.1	11.4	11.3	11.4	11.4	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.323	0.343	0.380	0.408	0.419	0.419	0.412	0.405	0.397	0.388	0.351	0.320	(40)	
taud		2.478	2.418	2.334	2.274	2.291	2.324	2.349	2.371	2.379	2.394	2.447	2.495	(41)		
Ebn at Noon		256	269	272	272	272	271	272	270	263	249	242	246	(42)		
Edh at Noon		23	29	35	41	41	40	38	36	34	29	24	21	(43)		
(44)	All-Sky Solar Radiation	RadAvg	586	866	1296	1654	1989	2297	2321	2021	1515	977	623	505	(44)	
(45)		RadStd	57	91	115	115	155	104	107	70	86	79	70	53	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	+0.83	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (26 neighbors)	+0.52	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+85

Nomenclature: See separate page