

NICE COTE D'AZUR AP, France

WMO: 076900

Lat: 43.6489N

Lon: 7.2089E

Elev: 12

StdP: 14.69

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	35.8	38.0	12.5	10.4	43.3	17.2	13.1	43.9	30.2	56.9	27.5	54.2	11.3	330	0.440

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	11.4	85.5	72.8	83.8	72.4	82.2	71.9	76.0	82.7	74.7	81.5	73.6	80.4	8.7	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
73.6	125.2	81.5	72.2	119.4	80.5	71.0	114.4	79.5	39.4	82.9	38.2	81.6	37.1	80.5	80.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
26.9	23.0	19.0	DB	33.1	91.6	2.8	3.6	31.0	94.2	29.4	96.3	27.8	98.3	25.7	100.9
			WB	27.5	77.3	2.2	1.6	25.9	78.4	24.6	79.4	23.3	80.3	21.7	81.5

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	61.3	48.8	49.4	53.1	57.3	63.8	70.6	75.5	75.9	70.0	63.8	55.8	50.5
	DBStd	10.41	3.57	3.84	3.58	3.76	3.92	4.29	3.57	3.32	3.84	3.96	4.51	4.14
	HDD50	181	64	49	14	1	0	0	0	0	0	9	44	
	HDD65	2416	502	437	370	231	69	4	0	6	69	277	451	
	CDD50	4296	27	32	109	221	428	619	790	804	599	427	182	58
	CDD65	1059	0	0	0	1	32	174	325	339	156	31	1	0
	CDH74	6253	0	0	0	1	57	769	2348	2487	564	27	0	0
	CDH80	972	0	0	0	0	2	86	394	453	37	0	0	0
Wind	WSAvg	9.0	10.4	9.8	9.3	8.9	7.9	7.4	7.5	7.6	8.4	9.1	10.4	11.0
Precipitation	PrecAvg	31.2	3.2	2.6	2.5	2.5	1.7	1.4	0.6	1.0	2.7	4.6	4.8	3.2
	PrecMax	49.9	11.4	9.1	9.6	7.2	9.7	5.4	2.9	6.8	8.4	16.5	22.2	8.3
	PrecMin	12.6	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	8.9	2.8	2.2	2.1	1.7	1.6	1.3	0.7	1.1	2.4	4.0	3.9	2.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	62.4	63.7	67.3	71.9	78.8	85.6	88.6	89.5	83.6	76.7	69.5	64.0
		MCWB	51.6	51.2	53.3	58.3	63.5	71.8	69.3	71.4	68.4	66.4	59.1	53.4
	2%	DB	59.4	59.7	63.4	68.3	75.3	82.5	85.3	86.0	80.6	74.4	67.0	61.4
		MCWB	51.0	51.1	52.8	57.7	64.3	71.8	72.8	73.7	69.3	65.7	58.8	53.3
	5%	DB	57.5	58.1	61.2	66.1	72.8	80.3	83.7	84.0	78.9	72.7	65.3	59.4
		MCWB	50.4	50.8	53.1	57.1	62.9	70.4	72.7	72.6	68.7	64.5	57.7	51.8
	10%	DB	55.7	56.7	59.8	64.2	70.8	78.3	82.2	82.4	77.2	71.0	63.3	57.4
		MCWB	49.1	50.0	52.7	56.4	62.3	69.1	72.0	72.3	67.4	63.1	56.4	50.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	55.4	55.1	57.2	62.0	68.3	75.7	77.4	78.2	73.6	69.4	63.0	57.6
		MCDB	58.6	59.5	62.1	67.2	74.2	82.9	83.9	84.4	79.6	74.4	67.1	61.2
	2%	WB	53.4	53.5	55.8	60.1	66.2	73.7	75.9	76.2	71.8	67.5	60.8	55.2
		MCDB	58.1	57.8	60.5	65.4	72.3	80.3	82.6	82.9	78.2	72.7	64.9	59.7
	5%	WB	51.6	52.1	54.8	58.7	64.7	72.0	74.6	75.0	70.4	65.9	59.1	53.0
		MCDB	56.4	56.9	59.5	64.1	70.7	78.5	81.5	81.7	77.2	71.2	63.8	57.9
	10%	WB	49.7	50.8	53.9	57.5	63.4	70.3	73.5	73.9	68.8	64.2	57.4	51.1
		MCDB	54.7	55.9	58.7	62.8	69.3	76.8	80.4	80.8	75.7	69.8	62.1	56.1
Mean Daily Temperature Range	5% DB	MDBR	13.0	12.8	12.3	11.3	10.8	10.9	11.1	11.4	12.2	12.1	12.7	12.7
		MCDBR	14.8	14.4	14.0	12.9	12.6	11.9	12.6	12.6	12.9	13.0	13.8	14.2
		MCWBR	11.6	11.2	10.5	8.7	8.7	8.7	9.8	10.6	9.7	9.7	10.2	11.0
	5% WB	MCDBR	13.4	13.1	12.3	10.9	10.9	10.5	10.7	11.0	11.3	11.8	11.7	12.6
		MCWBR	11.1	11.0	10.0	8.5	8.3	8.9	9.7	10.3	9.5	9.3	9.5	10.5
Clear-Sky Solar Irradiance	taub	0.324	0.347	0.386	0.424	0.432	0.440	0.433	0.424	0.412	0.394	0.354	0.321	
	taud	2.470	2.407	2.319	2.234	2.263	2.284	2.314	2.343	2.352	2.382	2.447	2.491	
	Ebn at Noon	255	267	269	267	267	265	266	264	258	246	240	245	
	Edh at Noon	23	29	36	42	42	42	40	37	34	30	24	21	
All-Sky Solar Radiation	RadAvg	563	842	1259	1608	1922	2218	2251	1962	1475	959	600	489	
	RadStd	56	95	122	120	144	109	106	75	86	83	64	55	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
Station Only	+0.83	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+218	+126
Regional (28 neighbors)	+0.54	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page