

CAP FERRAT, France

WMO: 076950

Lat: 43.6829N

Lon: 7.3281E

Elev: 472

StdP: 14.45

Time Zone: 1.00 (EUC)

Period: 86-08

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	39.3	41.4	9.6	9.1	45.4	16.1	12.6	47.7	34.3	54.7	28.4	51.5	8.1	80	0.386

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	8.6	84.4	72.3	82.6	72.3	80.9	71.8	76.3	81.2	75.1	80.1	73.8	78.8	7.4	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
74.7	132.0	79.8	73.4	126.5	78.7	72.0	120.6	77.5	40.0	81.1	38.9	80.0	37.7	79.2	82.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
27.2	22.1	18.0	DB	35.9	88.8	5.0	3.2	32.3	91.1	29.4	93.0	26.6	94.8	23.0	97.1	(4)
			WB	29.3	77.6	3.3	2.0	26.9	79.1	25.0	80.3	23.2	81.4	20.8	82.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	61.5	50.1	50.4	52.5	56.5	63.9	69.6	74.9	75.1	70.2	64.2	57.2	52.4	(6)
		DBStd	9.89	3.76	4.34	4.24	3.93	4.22	4.80	3.31	3.60	3.38	4.11	4.37	3.84	(7)
		HDD50	136	44	41	25	2	0	0	0	0	0	5	19		(8)
		HDD65	2286	463	409	387	255	70	11	0	5	62	235	389		(9)
		CDD50	4331	46	51	103	199	431	588	771	779	607	440	221	95	(10)
		CDD65	1008	0	0	0	1	36	149	306	314	163	38	1	0	(11)
		CDH74	4066	0	0	0	0	53	526	1583	1648	250	6	0	0	(12)
		CDH80	502	0	0	0	0	1	37	222	238	4	0	0	0	(13)
(14)	Wind	WSAvg	7.3	7.8	7.8	7.7	8.2	7.9	6.9	6.8	6.9	6.2	7.4	7.2	7.3	(14)
(15)	Precipitation	PrecAvg	31.9	3.2	2.2	1.9	2.6	1.8	1.3	0.6	0.9	3.3	4.8	5.6	3.7	(15)
(16)		PrecMax	55.9	13.5	6.5	9.6	5.9	5.0	4.4	2.1	3.4	9.3	12.7	22.5	8.3	(16)
(17)		PrecMin	13.7	0.0	0.0	0.0	0.2	0.2	0.0	0.0	0.0	1.0	0.1	0.1		(17)
(18)		PrecStd	9.2	3.0	1.8	2.0	1.8	1.3	1.2	0.6	0.8	2.5	3.2	4.6	2.6	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	60.9	63.3	65.7	70.1	78.8	84.1	86.3	88.7	80.5	74.8	69.6	63.5		(19)
(20)		0.4% MCWB	50.6	56.2	56.7	56.2	63.8	70.2	70.7	68.4	70.0	65.8	59.4	51.9		(20)
(21)		2% DB	58.3	59.4	62.2	67.2	74.9	81.3	84.2	85.1	78.8	72.7	65.7	60.9		(21)
(22)		2% MCWB	50.3	53.2	53.1	56.3	64.0	71.5	72.0	72.3	69.6	65.6	57.6	52.8		(22)
(23)		5% DB	56.4	57.1	60.2	64.7	72.6	79.7	82.6	83.0	77.1	71.0	63.8	59.0		(23)
(24)		5% MCWB	49.9	50.4	52.8	55.0	63.0	71.0	71.8	73.2	68.6	64.3	57.0	52.1		(24)
(25)		10% DB	55.0	55.3	58.2	62.5	70.1	77.6	80.8	81.2	75.4	69.4	62.3	57.5		(25)
(26)		10% MCWB	49.3	49.8	51.7	55.0	61.4	69.7	71.3	72.7	67.1	63.1	56.5	51.2		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% WB	54.9	58.3	60.2	61.7	68.6	75.2	77.4	78.4	73.5	69.4	62.1	58.5		(27)
(28)		0.4% MCDB	57.7	62.9	64.3	65.4	74.1	80.7	82.2	83.1	77.8	72.9	66.2	59.6		(28)
(29)		2% WB	53.2	55.1	57.0	59.4	66.9	73.7	76.1	76.8	72.1	67.4	60.3	56.4		(29)
(30)		2% MCDB	56.0	58.2	60.1	63.1	72.0	79.1	81.0	81.5	76.2	70.4	63.5	58.3		(30)
(31)		5% WB	52.0	52.8	54.7	57.7	64.8	72.5	74.9	75.6	71.1	66.1	59.0	54.2		(31)
(32)		5% MCDB	55.2	55.3	57.2	61.8	69.9	77.7	79.9	80.5	75.0	69.0	62.5	57.5		(32)
(33)		10% WB	50.7	51.3	53.4	56.4	63.3	71.0	73.6	74.4	69.8	64.9	57.5	52.5		(33)
(34)		10% MCDB	53.9	54.2	56.4	60.6	67.9	76.2	78.3	79.4	73.6	68.0	61.5	56.2		(34)
(35)	Mean Daily Temperature Range	MDBR	7.0	7.4	8.1	7.9	8.4	8.6	9.0	8.6	7.9	7.1	7.0	6.9		(35)
(36)		5% DB MCDBR	8.1	8.8	10.3	9.8	10.5	9.8	10.5	10.2	9.3	7.6	7.7	8.1		(36)
(37)		5% DB MCWBR	6.4	6.9	7.2	6.2	6.1	5.7	7.9	7.3	6.7	5.7	6.0	6.9		(37)
(38)		5% WB MCDBR	7.0	8.7	8.7	8.9	9.2	8.8	9.4	8.8	8.8	7.0	6.9	7.0		(38)
(39)		5% WB MCWBR	5.7	7.1	6.9	6.1	6.3	5.4	7.1	6.7	6.1	5.6	5.8	6.2		(39)
(40)	Clear-Sky Solar Irradiance	taub	0.316	0.338	0.375	0.411	0.418	0.427	0.420	0.412	0.400	0.383	0.344	0.313		(40)
(41)		taud	2.485	2.429	2.350	2.271	2.299	2.315	2.341	2.369	2.379	2.411	2.470	2.506		(41)
(42)		Ebn at Noon	259	271	273	271	272	269	269	268	261	250	244	249		(42)
(43)		Edh at Noon	23	28	35	41	41	40	39	36	33	29	23	20		(43)
(44)	All-Sky Solar Radiation	RadAvg	559	836	1252	1599	1911	2204	2239	1951	1467	955	596	485		(44)
(45)		RadStd	56	95	123	121	143	110	106	75	85	84	63	55		(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (27 neighbors)		+0.56	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page