

PERPIGNAN SUD DE FRANCE AP, France

WMO: 077470

Lat: 42.7372N

Lon: 2.8728E

Elev: 144

StdP: 14.62

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	31.3	34.0	13.9	11.2	42.5	18.6	14.1	42.5	37.7	47.4	34.1	48.2	8.9	310	0.510

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.6	91.1	69.0	88.2	68.6	86.0	68.0	74.0	82.8	72.7	81.6	71.4	80.4	10.9	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
71.6	117.3	77.8	70.0	111.0	77.1	68.4	105.1	76.1	37.6	82.5	36.4	81.5	35.3	80.4	79.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
31.8	28.3	25.2	DB	26.4	96.2	2.8	3.4	24.4	98.6	22.8	100.6	21.2	102.5	19.1	105.0
			WB	24.3	76.2	3.0	1.4	22.1	77.2	20.3	78.0	18.6	78.8	16.4	79.9

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	60.8	47.7	48.4	53.4	57.5	63.7	71.7	76.2	75.8	69.3	62.9	53.9	48.5
	DBStd	11.50	5.63	5.75	5.46	4.93	5.08	5.36	4.46	4.26	4.85	5.41	5.77	5.55
	HDD50	351	112	86	27	3	0	0	0	0	0	1	29	93
	HDD65	2651	537	466	359	231	84	7	1	1	15	103	335	512
	CDD50	4299	39	41	133	228	424	650	812	801	579	401	145	46
	CDD65	1123	0	0	1	6	42	207	348	337	143	38	1	0
	CDH74	8700	0	0	10	33	249	1570	3097	2794	808	137	2	0
	CDH80	2742	0	0	0	3	46	477	1091	933	169	23	0	0
Wind	WSAvg	10.5	10.9	11.9	11.4	11.7	10.6	10.3	10.4	9.6	9.3	9.1	10.6	10.1
Precipitation	PrecAvg	22.6	1.8	1.7	1.9	2.1	1.9	1.1	0.7	1.1	1.8	3.3	2.6	2.2
	PrecMax	42.7	7.0	9.6	6.6	11.3	9.2	3.5	2.4	4.2	12.0	29.4	13.0	10.8
	PrecMin	12.2	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.1	0.0	0.1	0.1	0.0
	PrecStd	6.8	1.7	1.7	1.7	2.0	1.6	0.9	0.6	0.9	2.2	4.3	3.1	2.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	66.9	67.9	75.1	77.7	85.2	93.2	94.0	95.6	88.8	83.0	72.4	66.4
		MCWB	54.2	54.0	55.8	58.8	65.3	69.1	69.9	71.5	66.0	64.2	58.8	55.4
	2%	DB	62.7	63.4	69.1	73.3	79.8	88.7	90.9	90.7	84.5	77.4	68.1	62.8
		MCWB	53.2	52.1	54.2	57.8	62.8	68.6	69.1	69.3	66.3	63.9	58.7	53.7
	5%	DB	59.6	60.4	65.8	70.1	76.4	85.2	88.4	87.5	81.4	74.2	65.5	60.2
		MCWB	50.9	50.7	53.3	57.0	61.7	67.5	68.9	68.9	65.5	62.9	57.0	52.4
	10%	DB	57.1	57.7	62.8	67.1	73.4	82.2	86.0	84.9	78.7	71.5	63.2	57.8
		MCWB	49.7	49.6	51.8	55.2	60.7	66.3	68.4	68.3	64.7	62.2	55.9	50.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	56.6	55.6	58.2	62.5	67.5	73.3	75.6	76.0	72.6	69.0	63.1	57.4
		MCDB	64.2	62.8	68.9	72.6	80.3	84.8	85.2	83.7	79.3	74.2	67.2	62.9
	2%	WB	54.4	53.7	56.3	60.0	65.3	71.5	73.8	74.4	70.6	67.2	61.1	55.4
		MCDB	60.0	60.1	65.2	69.2	75.2	82.1	83.2	82.4	77.1	72.0	65.8	60.5
	5%	WB	52.6	52.3	54.8	58.4	63.8	70.0	72.3	73.2	69.1	65.7	59.2	53.8
		MCDB	58.0	58.4	62.1	66.6	72.6	80.2	81.9	81.5	75.7	70.5	63.5	58.8
	10%	WB	50.7	50.8	53.7	57.0	62.4	68.4	71.0	72.0	67.6	64.3	57.2	51.9
		MCDB	56.1	56.7	60.0	64.7	70.6	78.7	80.8	80.2	74.6	69.4	62.4	56.9
Mean Daily Temperature Range	5% DB	MDBR	13.7	14.4	15.3	15.5	15.7	16.4	16.6	16.6	16.3	14.7	14.1	14.2
		MCDBR	17.2	19.1	19.5	19.8	20.4	20.3	19.5	20.0	19.4	17.8	17.0	17.3
		MCWBR	10.4	11.1	10.1	9.7	9.2	7.6	7.2	7.8	8.1	8.6	10.2	10.7
	5% WB	MCDBR	15.2	17.4	16.8	18.0	17.6	17.5	17.0	16.6	15.9	14.4	14.8	15.2
		MCWBR	10.2	11.3	9.9	10.2	9.0	7.6	8.2	8.7	8.6	8.2	10.2	10.3
Clear-Sky Solar Irradiance	taub	0.315	0.329	0.372	0.400	0.413	0.421	0.420	0.417	0.394	0.375	0.339	0.313	
	taud	2.518	2.476	2.375	2.305	2.321	2.332	2.346	2.356	2.406	2.461	2.506	2.525	
	Ebn at Noon	263	277	276	275	274	271	270	267	265	256	251	253	
	Edh at Noon	23	27	34	39	40	40	39	37	33	28	23	21	
All-Sky Solar Radiation	RadAvg	564	855	1229	1553	1811	2084	2090	1837	1429	960	631	503	
	RadStd	58	87	102	138	133	115	108	99	79	87	66	52	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+81
Regional (21 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page