

PERPIGNAN SUD DE FRANCE AP, France

WMO: 077470

Lat: 42.7372N

Lon: 2.8728E

Elev: 44

StdP: 100.80

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-0.4	1.1	-10.1	1.6	5.8	-7.4	2.0	5.8	16.9	8.6	15.2	9.0	4.0	310	0.510

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.2	32.9	20.6	31.2	20.3	30.0	20.0	23.3	28.2	22.6	27.6	21.9	26.9	4.9	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.0	16.8	25.4	21.1	15.9	25.1	20.2	15.0	24.5	69.6	28.0	66.8	27.5	64.2	26.9	26.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.2	12.6	11.3	-3.1	35.7	1.6	1.9	-4.2	37.0	-5.1	38.1	-6.0	39.2	-7.1	40.6
			-4.3	24.5	1.7	0.8	-5.5	25.1	-6.5	25.6	-7.4	26.0	-8.7	26.6
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	16.0	8.7	9.1	11.9	14.2	17.6	22.0	24.6	24.4	20.7	17.2	12.2	9.2
	DBStd	6.39	3.13	3.19	3.03	2.74	2.82	2.98	2.48	2.37	2.69	3.01	3.21	3.08
	HDD10.0	195	62	48	15	2	0	0	0	0	0	1	16	52
	HDD18.3	1473	298	259	199	128	47	4	1	1	8	57	186	284
	CDD10.0	2388	22	23	74	127	236	361	451	445	322	223	81	26
	CDD18.3	624	0	0	1	3	23	115	193	187	79	21	1	0
	CDH23.3	4833	0	0	6	18	138	872	1721	1552	449	76	1	0
	CDH26.7	1523	0	0	0	2	26	265	606	518	94	13	0	0
Wind	WSAvg	4.7	4.9	5.3	5.1	5.2	4.8	4.6	4.6	4.3	4.1	4.1	4.8	4.5
Precipitation	PrecAvg	574	45	44	49	53	47	27	17	28	45	85	67	56
	PrecMax	1084	179	243	168	287	234	89	61	107	305	748	330	274
	PrecMin	311	0	1	0	3	1	1	0	2	0	2	2	0
	PrecStd	172	43	44	43	51	40	23	14	24	55	108	78	60
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	19.4	20.0	24.0	25.4	29.5	34.0	34.5	35.4	31.5	28.3	22.5	19.1
		MCWB	12.3	12.2	13.2	14.9	18.5	20.6	21.0	21.9	18.9	17.9	14.9	13.0
	2%	DB	17.1	17.5	20.6	22.9	26.6	31.5	32.7	32.6	29.2	25.2	20.1	17.1
		MCWB	11.8	11.2	12.4	14.3	17.1	20.4	20.6	20.7	19.1	17.7	14.8	12.1
	5%	DB	15.3	15.8	18.8	21.2	24.7	29.6	31.3	30.8	27.4	23.5	18.6	15.6
		MCWB	10.5	10.4	11.8	13.9	16.5	19.7	20.5	20.5	18.6	17.2	13.9	11.3
	10%	DB	13.9	14.3	17.1	19.5	23.0	27.9	30.0	29.4	25.9	21.9	17.3	14.3
		MCWB	9.8	9.8	11.0	12.9	16.0	19.0	20.2	20.2	18.2	16.8	13.3	10.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.7	13.1	14.6	16.9	19.7	23.0	24.2	24.4	22.6	20.6	17.3	14.1
		MCDB	17.9	17.1	20.5	22.6	26.9	29.3	29.6	28.7	26.3	23.5	19.5	17.2
	2%	WB	12.4	12.1	13.5	15.6	18.5	21.9	23.2	23.6	21.5	19.6	16.2	13.0
		MCDB	15.6	15.6	18.5	20.6	24.0	27.8	28.5	28.0	25.1	22.2	18.8	15.8
	5%	WB	11.4	11.3	12.7	14.6	17.7	21.1	22.4	22.9	20.6	18.7	15.1	12.1
		MCDB	14.5	14.7	16.7	19.2	22.5	26.8	27.7	27.5	24.3	21.4	17.5	14.9
	10%	WB	10.4	10.4	12.0	13.9	16.9	20.2	21.7	22.2	19.8	17.9	14.0	11.1
		MCDB	13.4	13.7	15.6	18.1	21.4	26.0	27.1	26.8	23.7	20.8	16.9	13.8
Mean Daily Temperature Range	5% DB	MDBR	7.6	8.0	8.5	8.6	8.7	9.1	9.2	9.2	9.1	8.2	7.8	7.9
		MCDBR	9.6	10.6	10.8	11.0	11.4	11.3	10.8	11.1	10.8	9.9	9.5	9.6
		MCWBR	5.8	6.2	5.6	5.4	5.1	4.2	4.0	4.4	4.5	4.8	5.7	5.9
	5% WB	MCDBR	8.4	9.7	9.3	10.0	9.8	9.7	9.4	9.2	8.9	8.0	8.2	8.4
		MCWBR	5.7	6.3	5.5	5.7	5.0	4.2	4.6	4.8	4.8	4.6	5.7	5.7
Clear-Sky Solar Irradiance	taub	0.315	0.329	0.372	0.400	0.413	0.421	0.420	0.417	0.394	0.375	0.339	0.313	
	taud	2.518	2.476	2.375	2.305	2.321	2.332	2.346	2.356	2.406	2.461	2.506	2.525	
	Ebn at Noon	829	874	869	868	863	854	851	841	836	807	790	797	
	Edh at Noon	71	86	108	124	126	125	122	117	104	87	72	65	
All-Sky Solar Radiation	RadAvg	1.78	2.69	3.87	4.90	5.71	6.57	6.59	5.79	4.50	3.02	1.99	1.59	
	RadStd	0.18	0.27	0.32	0.43	0.42	0.36	0.34	0.31	0.25	0.27	0.21	0.16	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+45
(47)	Regional (21 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page