

ILE ROUSSE, France

WMO: 077530

Lat: 42.6331N

Lon: 8.9228E

Elev: 476

StdP: 14.45

Time Zone: 1.00 (EUC)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	38.2	40.9	17.2	13.3	45.2	21.2	16.2	46.2	43.6	53.4	40.3	54.4	16.8	80	0.464

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.8	86.2	70.6	83.8	71.0	82.0	70.3	75.6	81.8	74.4	80.5	73.1	79.3	11.3	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
73.5	127.0	80.2	72.3	121.6	79.1	70.9	116.0	78.0	39.4	82.1	38.2	80.5	37.1	79.4	80.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 39.9	34.1	29.5	DB	35.5	93.7	2.4	3.2	33.8	95.9	32.4	97.8	31.1	99.6	29.4	101.9	(4)
(5)			WB	30.4	77.2	1.9	1.8	29.1	78.5	28.0	79.6	26.9	80.6	25.6	81.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	62.6	50.7	50.4	54.1	58.5	64.6	71.6	76.2	76.2	71.3	65.5	58.3	53.4	(6)	
	DBStd	10.20	4.67	4.81	4.50	4.13	4.55	4.70	3.79	3.49	3.64	4.27	4.89	4.81	(7)	
	HDD50	138	46	47	16	1	0	0	0	0	0	0	4	24	(8)	
	HDD65	2066	442	409	340	200	62	4	0	0	3	44	204	358	(9)	
	CDD50	4753	69	58	142	255	452	648	813	811	640	480	254	131	(10)	
	CDD65	1206	0	0	1	4	49	202	348	346	193	59	4	0	(11)	
	CDH74	5814	0	0	1	14	114	848	2238	2057	478	63	1	0	(12)	
	CDH80	951	0	0	0	2	12	139	412	349	33	4	0	0	(13)	
(14) Wind	WSAvg	11.2	12.8	12.2	13.7	11.7	10.1	9.4	10.1	9.4	10.4	9.7	11.5	12.9	(14)	
(15) Precipitation	PrecAvg	24.6	2.1	1.8	2.2	2.2	1.5	1.3	0.4	0.9	2.2	3.1	4.3	2.7	(15)	
	PrecMax	33.6	5.1	5.3	4.3	4.6	4.2	4.6	1.5	4.3	7.3	8.8	7.7	5.0	(16)	
	PrecMin	16.2	0.1	0.1	0.0	0.3	0.2	0.0	0.0	0.0	0.1	0.1	0.9	0.2	(17)	
	PrecStd	4.6	1.2	1.3	1.1	1.1	1.1	1.2	0.4	0.9	1.5	2.0	1.9	1.4	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	65.4	63.4	70.3	74.9	81.3	88.3	89.7	90.2	83.5	79.1	72.4	66.5	(19)	
		MCWB	54.0	51.9	55.3	59.3	62.7	67.9	69.3	68.7	68.1	64.7	59.5	55.2	(20)	
	2%	DB	62.2	60.4	65.2	69.6	77.0	83.5	86.1	85.9	80.2	75.5	68.4	63.4	(21)	
		MCWB	52.6	50.9	53.2	56.6	61.8	68.8	71.0	71.2	68.7	64.2	58.7	54.1	(22)	
	5%	DB	59.1	58.1	62.3	66.7	73.9	80.7	83.9	83.5	78.4	73.1	66.3	61.3	(23)	
		MCWB	51.4	50.3	51.9	55.9	61.7	68.7	72.0	71.3	67.8	64.1	58.2	53.4	(24)	
	10%	DB	56.8	56.2	59.9	64.5	71.1	78.6	82.1	81.6	76.6	71.1	64.4	59.3	(25)	
		MCWB	49.8	49.4	51.5	55.5	61.2	67.9	70.8	70.8	66.7	62.8	57.2	52.4	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	55.6	54.7	56.9	62.0	67.3	75.1	77.0	77.3	73.4	68.7	63.5	57.5	(27)	
		MCDB	62.3	60.1	65.1	68.8	74.2	81.1	83.8	83.7	79.7	74.3	67.5	63.1	(28)	
	2%	WB	53.7	53.0	55.4	59.8	65.4	73.1	75.7	75.8	71.7	67.0	61.1	55.8	(29)	
		MCDB	60.0	57.9	61.4	65.8	72.1	79.1	82.2	81.9	77.5	72.2	65.7	60.8	(30)	
	5%	WB	52.2	51.7	54.3	58.3	63.8	71.5	74.6	74.5	70.2	65.6	59.6	54.6	(31)	
		MCDB	58.1	56.4	59.7	64.0	70.5	77.5	80.9	80.4	75.7	70.6	64.3	59.6	(32)	
	10%	WB	50.8	50.4	53.2	57.0	62.7	69.9	73.4	73.2	68.8	64.4	58.3	53.4	(33)	
		MCDB	56.0	55.1	58.2	62.3	69.0	76.3	79.5	79.3	74.5	69.5	63.2	58.4	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	7.2	8.0	8.6	9.5	9.9	10.2	9.8	9.5	9.1	8.4	7.7	7.0	(35)	
		MCDBR	9.0	9.7	11.1	12.6	13.3	12.7	11.8	11.2	10.5	10.3	9.1	8.5	(36)	
	5% WB	MCWBR	7.0	7.5	7.2	8.0	8.2	9.0	9.1	9.9	8.2	7.6	6.8	6.6	(37)	
		MCWBR	8.2	8.8	9.4	10.8	11.0	10.4	10.2	10.0	9.4	9.0	8.0	7.5	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.317	0.333	0.360	0.396	0.405	0.401	0.399	0.396	0.386	0.366	0.345	0.319	(40)	
		taud	2.535	2.487	2.427	2.330	2.346	2.395	2.400	2.420	2.439	2.493	2.503	2.537	(41)	
	Edn at Noon	Edn at Noon	263	276	280	277	276	277	276	273	268	260	248	251	(42)	
		Edh at Noon	22	27	32	38	39	37	36	35	32	27	23	21	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	539	823	1228	1664	2007	2279	2320	2010	1510	1000	609	475	(44)	
	RadStd	RadStd	50	86	123	102	143	106	88	91	66	80	54	53	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (21 neighbors)	+0.43	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+133	N/A	N/A

Nomenclature: See separate page