

CALVI ST CATHERINE AP, France

WMO: 077540

Lat: 42.529N

Lon: 8.791E

Elev: 209

StdP: 14.59

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	33.6	35.9	17.3	13.3	44.5	21.4	16.2	43.4	26.4	55.1	24.2	54.7	6.1	210	0.453

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.9	91.4	69.0	88.7	69.3	86.3	69.1	74.8	84.3	73.5	83.4	72.0	82.2	11.3	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
71.5	117.3	82.0	69.9	110.9	80.8	68.3	104.9	79.3	38.4	84.2	37.1	83.4	35.8	82.3	79.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
23.5	20.9	18.7		DB	29.4	97.5	2.3	3.4	27.7	99.9	26.4	101.9	25.1	103.8	23.4	106.3
				WB	26.4	76.6	2.2	1.2	24.9	77.5	23.6	78.2	22.4	78.9	20.8	79.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	61.4	49.1	48.9	52.5	57.1	63.9	71.1	76.1	76.0	70.0	63.8	56.1	51.0	(6)
	DBStd	10.83	5.03	4.95	4.86	4.02	4.44	5.04	4.19	3.85	4.29	4.52	5.25	5.09	(7)
	HDD50	234	76	71	26	1	0	0	0	0	0	0	12	48	(8)
	HDD65	2438	492	452	388	239	75	7	0	0	8	75	269	433	(9)
	CDD50	4386	48	39	104	214	430	632	808	807	601	428	195	80	(10)
	CDD65	1115	0	0	1	1	40	189	343	342	159	38	2	0	(11)
	CDH74	9908	0	0	2	15	293	1616	3482	3291	1034	170	5	0	(12)
	CDH80	3117	0	0	0	1	44	451	1263	1153	192	13	0	0	(13)
(14) Wind	WSAvg	8.1	8.3	8.2	8.9	8.1	7.8	7.9	8.5	8.0	8.0	7.2	7.6	8.3	(14)
(15) Precipitation	PrecAvg	24.6	2.1	1.8	2.2	2.2	1.5	1.3	0.4	0.9	2.2	3.1	4.3	2.7	(15)
	PrecMax	33.6	5.1	5.3	4.3	4.6	4.2	4.6	1.5	4.3	7.3	8.8	7.7	5.0	(16)
	PrecMin	16.2	0.1	0.1	0.0	0.3	0.2	0.0	0.0	0.0	0.1	0.1	0.9	0.2	(17)
	PrecStd	4.6	1.2	1.3	1.1	1.1	1.1	1.2	0.4	0.9	1.5	2.0	1.9	1.4	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	66.7	66.2	71.9	76.3	84.6	92.6	94.5	95.6	88.1	81.8	73.8	67.6	(19)
		MCWB	54.8	53.8	55.6	58.9	63.4	68.1	69.2	69.0	67.4	65.6	60.5	56.1	(20)
	2%	DB	62.9	62.7	67.4	72.4	80.5	88.1	91.4	91.3	84.5	78.2	69.8	64.4	(21)
		MCWB	53.2	52.2	54.1	57.7	62.3	68.5	68.9	69.6	67.6	65.3	59.6	54.9	(22)
	5%	DB	60.5	60.3	64.5	69.5	77.1	84.7	88.9	88.2	81.9	75.5	67.4	62.3	(23)
		MCWB	52.1	51.0	53.2	57.0	61.6	68.0	69.3	70.0	67.0	64.3	58.7	54.3	(24)
	10%	DB	58.1	58.3	62.0	66.7	74.3	82.1	86.4	85.9	79.7	73.1	65.1	60.3	(25)
		MCWB	50.5	50.1	52.2	55.9	61.0	67.4	69.4	69.8	66.5	63.0	57.2	52.9	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	56.4	55.6	58.0	62.8	67.4	74.6	76.4	76.8	72.6	68.8	63.9	58.3	(27)
		MCDB	63.7	62.0	67.2	70.4	77.0	84.2	86.0	85.8	81.9	76.2	69.8	64.7	(28)
	2%	WB	54.4	53.7	56.3	60.3	65.4	72.7	74.8	75.0	71.0	67.2	61.2	56.5	(29)
		MCDB	61.2	60.6	64.0	68.3	74.8	82.3	84.5	84.3	79.9	75.0	67.2	62.9	(30)
	5%	WB	52.8	52.2	55.0	58.7	63.9	70.7	73.5	73.6	69.6	65.8	59.6	54.9	(31)
		MCDB	59.3	58.9	61.9	66.4	73.4	80.8	83.5	83.6	78.6	73.4	65.7	61.2	(32)
	10%	WB	51.3	50.9	53.7	57.3	62.6	68.9	72.0	72.1	68.1	64.2	58.0	53.4	(33)
		MCDB	57.3	57.4	60.5	64.7	71.7	79.3	82.4	82.4	77.2	71.6	64.0	59.3	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	15.0	16.0	16.7	17.5	18.1	18.6	18.9	18.7	17.7	16.6	15.0	14.8	(35)
		MCDBR	16.4	17.9	19.9	21.9	22.4	22.3	22.4	21.9	20.3	19.3	17.3	16.2	(36)
	5% WB	MCWBR	10.9	11.6	11.7	11.8	11.2	11.0	11.3	11.7	10.7	11.2	10.7	10.8	(37)
		MCWBR	14.9	16.9	17.8	19.4	19.7	20.2	19.6	19.6	18.3	17.6	16.0	15.0	(38)
(40) Clear-Sky Solar Irradiance	taub		0.327	0.344	0.374	0.410	0.421	0.415	0.412	0.409	0.399	0.379	0.357	0.328	(40)
		taud	2.508	2.450	2.379	2.281	2.298	2.358	2.364	2.385	2.404	2.452	2.459	2.508	(41)
	Ebn at Noon		259	271	275	272	272	273	272	270	264	255	243	247	(42)
		Edh at Noon	23	28	34	40	41	39	38	36	33	28	24	21	(43)
(44) All-Sky Solar Radiation	RadAvg		543	829	1235	1676	2017	2294	2335	2020	1518	1010	615	478	(44)
	RadStd		51	87	121	104	143	106	86	92	65	79	54	53	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	+2.38	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (21 neighbors)	+0.45	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+137	+81

Nomenclature: See separate page