

CALVI ST CATHERINE AP, France

WMO: 077540

Lat: 42.529N

Lon: 8.791E

Elev: 64

StdP: 100.56

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	0.9	2.2	-8.1	1.9	6.9	-5.9	2.3	6.4	11.8	12.9	10.8	12.6	2.7	210	0.453

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.5	33.0	20.5	31.5	20.7	30.2	20.6	23.8	29.1	23.0	28.6	22.2	27.9	5.1	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
22.0	16.8	27.8	21.1	15.8	27.1	20.2	15.0	26.3	71.4	29.0	68.4	28.6	65.5	28.0	26.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10.5	9.4	8.4	-1.4	36.4	1.3	1.9	-2.4	37.7	-3.1	38.8	-3.9	39.9	-4.8	41.3
			-3.1	24.8	1.2	0.7	-4.0	25.3	-4.7	25.7	-5.3	26.1	-6.2	26.5
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	16.3	9.5	9.4	11.4	13.9	17.7	21.7	24.5	24.5	21.1	17.7	13.4	10.6
	DBStd	6.02	2.79	2.75	2.70	2.24	2.46	2.80	2.33	2.14	2.38	2.51	2.92	2.83
	HDD10.0	130	42	39	14	1	0	0	0	0	0	0	7	27
	HDD18.3	1354	273	251	216	133	42	4	0	0	4	42	149	241
	CDD10.0	2437	27	22	58	119	239	351	449	448	334	238	108	44
	CDD18.3	619	0	0	1	1	22	105	191	190	88	21	1	0
	CDH23.3	5504	0	0	1	8	163	898	1934	1828	574	94	3	0
	CDH26.7	1732	0	0	0	1	24	251	702	641	107	7	0	0
(14) Wind	WSAvg	3.6	3.7	3.7	4.0	3.6	3.5	3.5	3.8	3.6	3.6	3.2	3.4	3.7
(15) Precipitation	PrecAvg	625	54	46	56	55	38	32	9	22	55	79	110	69
	PrecMax	854	130	135	109	117	107	117	38	110	185	223	196	126
	PrecMin	411	2	2	0	8	5	0	0	1	3	2	22	4
	PrecStd	116	30	32	28	29	29	30	9	24	39	50	47	35
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	19.3	19.0	22.2	24.6	29.2	33.6	34.7	35.3	31.2	27.7	23.2	19.8
		MCWB	12.7	12.1	13.1	15.0	17.4	20.1	20.7	20.5	19.6	18.7	15.8	13.4
	2%	DB	17.2	17.0	19.6	22.4	26.9	31.2	33.0	33.0	29.2	25.7	21.0	18.0
		MCWB	11.8	11.2	12.3	14.3	16.8	20.3	20.5	20.9	19.8	18.5	15.3	12.7
	5%	DB	15.8	15.7	18.1	20.8	25.1	29.3	31.6	31.2	27.7	24.2	19.7	16.8
		MCWB	11.1	10.6	11.8	13.9	16.5	20.0	20.7	21.1	19.4	17.9	14.9	12.4
	10%	DB	14.5	14.6	16.7	19.3	23.5	27.8	30.2	29.9	26.5	22.8	18.4	15.7
		MCWB	10.3	10.1	11.2	13.3	16.1	19.7	20.8	21.0	19.1	17.2	14.0	11.6
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.6	13.1	14.5	17.1	19.7	23.7	24.6	24.9	22.6	20.4	17.7	14.6
		MCDB	17.6	16.7	19.5	21.3	25.0	29.0	30.0	29.9	27.7	24.5	21.0	18.2
	2%	WB	12.5	12.0	13.5	15.7	18.6	22.6	23.8	23.9	21.7	19.6	16.2	13.6
		MCDB	16.2	15.9	17.8	20.2	23.8	27.9	29.2	29.1	26.6	23.9	19.6	17.2
	5%	WB	11.6	11.2	12.8	14.8	17.7	21.5	23.0	23.1	20.9	18.8	15.4	12.7
		MCDB	15.1	14.9	16.6	19.1	23.0	27.1	28.6	28.7	25.9	23.0	18.7	16.2
	10%	WB	10.7	10.5	12.0	14.1	17.0	20.5	22.2	22.3	20.0	17.9	14.4	11.9
		MCDB	14.1	14.1	15.9	18.2	22.0	26.3	28.0	28.0	25.1	22.0	17.8	15.2
(35) Mean Daily Temperature Range	5% DB	MDBR	8.3	8.9	9.3	9.7	10.0	10.3	10.5	10.4	9.8	9.2	8.4	8.2
		MCDBR	9.1	9.9	11.1	12.2	12.4	12.4	12.4	12.2	11.3	10.7	9.6	9.0
		MCWBR	6.1	6.5	6.5	6.5	6.2	6.1	6.3	6.5	5.9	6.2	5.9	6.0
	5% WB	MCDBR	8.3	9.4	9.9	10.8	10.9	11.2	10.9	10.9	10.2	9.8	8.9	8.3
		MCWBR	5.9	6.5	6.6	6.5	6.3	6.5	6.6	6.9	6.2	6.2	6.0	5.8
(40) Clear-Sky Solar Irradiance	taub		0.327	0.344	0.374	0.410	0.421	0.415	0.412	0.409	0.399	0.379	0.357	0.328
	taud		2.508	2.450	2.379	2.281	2.298	2.358	2.364	2.385	2.404	2.452	2.459	2.508
	Ebn at Noon		816	855	868	858	856	860	858	850	832	804	767	778
	Edh at Noon		72	89	107	127	129	122	120	114	104	89	76	67
(44) All-Sky Solar Radiation	RadAvg		1.71	2.61	3.89	5.28	6.36	7.23	7.36	6.37	4.78	3.18	1.94	1.51
	RadStd		0.16	0.27	0.38	0.33	0.45	0.33	0.27	0.29	0.21	0.25	0.17	0.17

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)
(46) Station Only		N/A	N/A	+1.32	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (21 neighbors)		+0.25	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+76	+45	

Nomenclature: See separate page