

AJACCIO BONAPARTE AP, France

WMO: 077610

Lat: 41.9181N

Lon: 8.7928E

Elev: 6

StdP: 101.26

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	0.3	1.8	-6.5	2.2	4.2	-4.1	2.7	4.5	11.9	12.0	10.0	11.8	3.6	50	0.442

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	10.7	31.2	22.7	30.0	22.8	29.0	22.6	24.7	29.3	24.0	28.6	23.2	27.9	4.5	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.1	17.9	28.5	22.3	17.0	27.8	21.5	16.2	27.2	74.9	29.5	71.8	28.6	69.0	28.0	27.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.3	7.6	6.5	-1.9	35.5	1.3	2.0	-2.8	37.0	-3.6	38.1	-4.3	39.2	-5.2	40.7		
			DB	WB	DB	WB	DB	WB	DB	WB	DB	WB	DB	WB		
			-3.4	25.6	1.3	0.7	-4.3	26.1	-5.0	26.5	-5.8	27.0	-6.7	27.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	15.7	9.2	9.1	10.8	13.3	16.9	20.6	23.2	23.4	20.5	17.6	13.4	10.4
	DBStd	5.64	2.28	2.26	2.07	2.19	2.27	2.52	2.18	2.06	2.21	2.39	2.80	2.56
	HDD10.0	128	41	38	14	2	0	0	0	0	0	0	6	26
	HDD18.3	1433	282	258	233	151	57	7	1	1	7	41	149	247
	CDD10.0	2224	17	13	39	101	213	319	408	416	316	236	108	38
	CDD18.3	489	0	0	0	1	12	76	150	158	72	19	1	0
	CDH23.3	4245	0	0	2	11	73	598	1433	1521	509	93	4	0
Wind	WSAvg	3.3	3.1	3.3	3.3	3.3	3.3	3.4	3.5	3.4	3.4	3.1	3.2	3.2
	PrecAvg	633	67	61	57	52	38	19	8	18	51	87	100	74
	PrecMax	985	153	176	161	141	142	101	49	101	137	246	222	207
	PrecMin	377	0	3	0	7	1	0	0	0	1	2	10	5
	PrecStd	148	39	40	35	32	33	19	12	23	35	62	58	42
	DB	17.9	17.6	20.4	24.2	28.5	31.8	33.2	33.4	29.8	27.6	23.7	19.2	19.2
	MCWB	13.0	12.0	13.2	14.5	17.6	20.5	21.9	21.8	21.4	19.1	15.9	13.8	13.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	2% DB	15.9	15.7	17.7	21.1	25.0	29.1	31.1	31.2	28.3	25.4	21.4	17.4	17.4
	2% MCWB	12.3	12.0	13.2	15.3	18.2	22.1	23.0	23.3	21.5	19.7	16.2	13.4	13.4
	5% DB	14.9	15.0	16.8	19.7	23.5	27.8	29.9	30.0	27.2	24.2	20.0	16.3	16.3
	5% MCWB	11.6	11.5	12.9	14.8	17.9	21.7	23.2	23.2	21.1	19.0	15.6	12.8	12.8
	10% DB	13.9	14.1	15.9	18.6	22.3	26.5	28.8	29.0	26.2	23.1	18.7	15.1	15.1
	10% MCWB	10.8	10.8	12.4	14.4	17.4	21.2	22.8	22.8	20.5	18.2	14.8	12.1	12.1
	WB	14.2	13.7	14.9	17.4	20.6	24.5	25.6	25.7	23.7	21.7	18.3	15.1	15.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	MCDB	16.1	16.3	17.8	20.9	24.7	28.4	30.2	30.1	27.8	25.1	21.1	17.1	17.1
	2% WB	13.0	12.8	14.0	16.2	19.4	23.5	24.7	24.9	22.7	20.5	16.9	14.2	14.2
	2% MCDB	15.2	15.1	16.8	19.5	23.5	27.6	29.4	29.6	27.1	24.2	20.1	16.5	16.5
	5% WB	12.1	12.1	13.4	15.5	18.5	22.4	24.0	24.1	21.9	19.6	16.0	13.4	13.4
	5% MCDB	14.4	14.5	16.1	18.7	22.5	26.6	28.6	28.8	26.4	23.4	19.4	15.8	15.8
	10% WB	11.2	11.2	12.8	14.7	17.8	21.4	23.2	23.3	21.0	18.7	15.1	12.4	12.4
	10% MCDB	13.7	13.7	15.5	17.9	21.5	25.8	27.9	28.2	25.5	22.5	18.3	14.8	14.8
Mean Daily Temperature Range	MDBR	9.0	9.4	9.8	9.7	9.8	10.2	10.4	10.7	10.4	10.1	9.3	9.0	9.0
	5% DB	9.5	10.2	10.9	11.4	11.6	11.9	11.9	12.0	11.4	10.9	10.3	9.7	9.7
	5% MCWB	6.9	7.5	7.8	7.4	7.1	7.5	7.8	8.4	7.5	7.2	6.8	6.7	6.7
	5% WB	8.7	9.4	9.9	10.1	10.3	10.5	10.6	11.2	10.7	10.1	9.7	8.6	8.6
	5% MCWB	6.8	7.3	7.4	7.0	7.0	7.5	7.6	8.4	7.5	7.1	6.8	6.4	6.4
Clear-Sky Solar Irradiance	taub	0.335	0.354	0.385	0.420	0.433	0.421	0.422	0.418	0.409	0.389	0.367	0.337	0.337
	taud	2.484	2.419	2.342	2.245	2.251	2.331	2.333	2.353	2.369	2.408	2.411	2.476	2.476
	Ebn at Noon	809	847	858	850	846	855	850	842	823	794	756	771	771
	Edh at Noon	75	93	112	133	135	125	124	118	108	93	81	70	70
All-Sky Solar Radiation	RadAvg	1.75	2.66	3.99	5.33	6.41	7.33	7.44	6.41	4.82	3.27	1.99	1.55	1.55
	RadStd	0.17	0.27	0.36	0.34	0.48	0.32	0.26	0.30	0.19	0.26	0.16	0.16	0.16

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		+0.30	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+96	+58
Regional (14 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page