

CAP PERTUSATO, France

WMO: 077700

Lat: 41.3747N

Lon: 9.1783E

Elev: 381

StdP: 14.49

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	38.7	41.3	22.0	16.7	43.8	26.6	20.9	44.7	57.9	53.0	52.5	53.3	14.0	40	0.640

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	10.2	87.3	73.0	84.6	72.7	82.2	72.6	76.7	82.1	75.5	80.8	74.4	79.5	11.8	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
75.2	134.1	79.6	73.9	128.0	78.6	72.7	123.0	77.7	40.4	82.1	39.2	80.9	38.1	79.6	85.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 47.6	41.1	34.7	DB	35.5	92.0	3.6	3.1	33.0	94.2	30.8	96.1	28.8	97.8	26.2	100.1	(4)
(5)			WB	30.7	78.7	2.3	2.3	29.0	80.3	27.7	81.7	26.4	83.0	24.7	84.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	62.3	51.1	50.7	53.6	57.5	63.3	69.9	75.2	76.4	71.1	65.7	58.6	53.4
	DBStd	9.82	3.99	4.09	3.57	3.48	3.95	4.31	3.82	3.67	3.83	4.10	4.58	4.42
	HDD50	112	35	38	13	1	0	0	0	0	0	0	4	21
	HDD65	2094	431	401	353	226	80	7	0	0	3	38	195	360
	CDD50	4593	69	56	125	225	411	598	781	819	633	488	261	127
	CDD65	1103	0	0	0	1	27	155	316	354	186	62	2	0
	CDH74	5024	0	0	0	2	73	527	1692	2142	544	44	0	0
	CDH80	1072	0	0	0	0	12	99	392	509	59	1	0	0
Wind	WSAvg	15.2	15.3	16.0	17.3	15.9	14.9	14.3	14.9	13.7	13.8	14.4	15.2	16.5
Precipitation	PrecAvg	23.7	2.4	1.9	2.2	2.1	1.5	0.7	0.3	0.5	2.0	3.2	3.6	3.0
	PrecMax	35.8	6.6	5.0	6.6	4.6	8.6	2.1	1.3	2.6	4.9	7.2	9.1	7.2
	PrecMin	15.0	0.2	0.4	0.1	0.4	0.2	0.0	0.0	0.0	0.2	0.0	0.7	0.2
	PrecStd	5.6	1.4	1.3	1.6	1.1	1.6	0.6	0.4	0.6	1.2	1.9	1.8	1.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	60.8	60.2	65.3	72.0	80.9	87.5	90.7	91.8	84.7	77.7	70.7	63.7
		MCWB	55.1	53.0	54.8	60.0	65.7	69.8	72.9	73.8	70.8	69.2	62.7	57.9
	2%	DB	58.9	58.1	61.6	68.1	75.2	83.0	87.2	87.8	81.5	74.9	68.0	61.7
		MCWB	54.7	52.8	54.7	58.5	63.3	69.8	72.9	74.0	70.5	68.0	62.2	57.0
	5%	DB	57.6	56.9	59.7	65.0	71.7	79.5	84.2	85.0	79.1	72.9	66.1	60.3
		MCWB	53.8	52.5	54.0	57.8	63.0	69.4	73.1	73.5	69.8	66.9	61.3	56.2
	10%	DB	56.5	55.8	58.2	62.6	69.2	76.7	81.5	82.7	77.1	71.3	64.5	59.1
		MCWB	52.7	51.7	53.3	56.9	62.1	69.2	72.7	73.5	69.0	66.0	60.1	55.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	57.1	55.7	57.6	62.5	68.4	75.0	77.9	79.4	75.1	71.5	65.8	59.6
		MCDB	59.3	58.0	61.7	68.8	74.7	81.6	83.7	84.3	79.6	74.6	68.2	61.8
	2%	WB	55.8	54.6	56.2	60.2	66.1	73.1	76.4	77.3	73.4	69.7	63.7	58.3
		MCDB	58.1	56.8	59.6	65.2	71.3	78.1	81.9	82.6	77.6	73.2	66.7	60.7
	5%	WB	54.7	53.6	55.2	58.9	64.4	71.6	75.3	76.1	72.0	68.3	62.2	57.2
		MCDB	57.1	56.1	58.1	63.1	69.6	76.6	80.7	81.3	76.5	71.7	65.0	59.6
	10%	WB	53.4	52.6	54.4	57.7	63.2	70.1	74.2	74.9	70.8	67.1	60.8	56.1
		MCDB	55.9	55.3	57.2	61.2	67.8	74.9	79.2	80.2	75.4	70.4	63.7	58.8
Mean Daily Temperature Range	5% DB	MDBR	7.3	7.8	8.0	8.8	9.2	9.8	10.0	10.2	9.8	8.6	7.8	7.4
		MCDBR	7.6	8.2	10.1	12.8	14.4	15.3	15.4	15.2	13.0	10.3	9.3	7.8
		MCWBR	5.9	6.3	6.6	7.2	7.1	6.8	6.8	7.4	6.7	5.9	6.3	6.1
	5% WB	MCDBR	6.5	6.9	8.2	11.1	12.1	12.1	12.6	12.5	10.9	9.1	8.2	6.6
		MCWBR	5.6	6.1	5.9	6.9	6.8	6.6	6.6	7.1	6.5	5.5	6.0	5.8
Clear-Sky Solar Irradiance	taub	0.331	0.348	0.376	0.407	0.419	0.405	0.409	0.406	0.400	0.384	0.362	0.334	
	taud	2.498	2.441	2.374	2.296	2.301	2.380	2.378	2.395	2.407	2.431	2.433	2.486	
	Ebn at Noon	260	272	276	274	273	276	274	272	265	255	244	248	
	Edh at Noon	24	29	35	40	41	38	38	36	33	29	25	23	
All-Sky Solar Radiation	RadAvg	567	849	1266	1669	2007	2303	2341	2023	1518	1045	642	507	
	RadStd	56	82	117	107	155	102	84	101	63	85	49	51	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	+1.93	N/A	N/A	N/A	N/A	N/A	N/A
Regional (16 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page