

CAP PERTUSATO, France

WMO: 077700

Lat: 41.3747N

Lon: 9.1783E

Elev: 116

StdP: 99.94

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	3.7	5.2	-5.6	2.4	6.6	-3.0	3.0	7.0	25.9	11.7	23.5	11.8	6.3	40	0.640

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.7	30.7	22.8	29.2	22.6	27.9	22.5	24.8	27.8	24.2	27.1	23.5	26.4	5.3	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.0	19.2	26.4	23.3	18.3	25.9	22.6	17.6	25.4	76.1	27.8	73.4	27.2	70.8	26.4	29.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.3	18.4	15.5	2.0	33.3	2.0	1.7	0.5	34.6	-0.6	35.6	-1.8	36.6	-3.2	37.8
			-0.7	25.9	1.3	1.3	-1.6	26.8	-2.4	27.6	-3.1	28.3	-4.0	29.2
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	16.8	10.6	10.4	12.0	14.2	17.4	21.1	24.0	24.7	21.7	18.7	14.8	11.9
	DBStd	5.46	2.22	2.27	1.99	1.93	2.19	2.39	2.12	2.04	2.13	2.28	2.54	2.45
	HDD10.0	62	19	21	7	1	0	0	0	0	0	0	2	12
	HDD18.3	1163	239	223	196	126	44	4	0	0	2	21	108	200
	CDD10.0	2552	38	31	69	125	228	332	434	455	352	271	145	71
	CDD18.3	613	0	0	0	1	15	86	176	197	103	34	1	0
	CDH23.3	2791	0	0	0	1	41	293	940	1190	302	24	0	0
	CDH26.7	596	0	0	0	0	7	55	218	283	33	1	0	0
Wind	WSAvg	6.8	6.8	7.1	7.7	7.1	6.6	6.4	6.7	6.1	6.2	6.4	6.8	7.4
Precipitation	PrecAvg	602	62	49	57	54	39	19	8	13	52	81	91	77
	PrecMax	910	167	126	167	118	219	53	34	66	125	183	231	182
	PrecMin	382	6	10	3	9	4	0	0	0	5	1	17	6
	PrecStd	141	36	32	40	27	41	15	9	14	31	48	46	39
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	16.0	15.6	18.5	22.2	27.2	30.8	32.6	33.2	29.3	25.4	21.5	17.6
		MCWB	12.8	11.7	12.7	15.5	18.7	21.0	22.7	23.2	21.5	20.7	17.0	14.4
	2%	DB	14.9	14.5	16.5	20.1	24.0	28.3	30.7	31.0	27.5	23.9	20.0	16.5
		MCWB	12.6	11.6	12.6	14.7	17.4	21.0	22.7	23.3	21.4	20.0	16.8	13.9
	5%	DB	14.2	13.8	15.4	18.3	22.1	26.4	29.0	29.5	26.2	22.7	18.9	15.7
		MCWB	12.1	11.4	12.2	14.3	17.2	20.8	22.8	23.1	21.0	19.4	16.3	13.4
	10%	DB	13.6	13.2	14.5	17.0	20.6	24.8	27.5	28.2	25.0	21.9	18.1	15.1
		MCWB	11.5	11.0	11.8	13.8	16.7	20.7	22.6	23.0	20.6	18.9	15.6	12.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.0	13.2	14.2	16.9	20.2	23.9	25.5	26.3	23.9	21.9	18.8	15.3
		MCDB	15.1	14.5	16.5	20.4	23.7	27.5	28.7	29.1	26.5	23.7	20.1	16.6
	2%	WB	13.2	12.5	13.5	15.7	18.9	22.8	24.7	25.2	23.0	20.9	17.6	14.6
		MCDB	14.5	13.8	15.3	18.4	21.8	25.6	27.7	28.1	25.3	22.9	19.3	15.9
	5%	WB	12.6	12.0	12.9	14.9	18.0	22.0	24.0	24.5	22.2	20.2	16.8	14.0
		MCDB	13.9	13.4	14.5	17.3	20.9	24.8	27.0	27.4	24.7	22.0	18.3	15.4
	10%	WB	11.9	11.4	12.5	14.3	17.3	21.2	23.4	23.9	21.5	19.5	16.0	13.4
		MCDB	13.3	13.0	14.0	16.2	19.9	23.8	26.2	26.8	24.1	21.4	17.6	14.9
Mean Daily Temperature Range	5% DB	MDBR	4.1	4.3	4.5	4.9	5.1	5.5	5.5	5.7	5.5	4.8	4.4	4.1
		MCDBR	4.2	4.5	5.6	7.1	8.0	8.5	8.5	8.5	7.2	5.7	5.1	4.4
		MCWBR	3.3	3.5	3.7	4.0	4.0	3.8	3.8	4.1	3.7	3.3	3.5	3.4
	5% WB	MCDBR	3.6	3.9	4.6	6.2	6.7	6.7	7.0	6.9	6.0	5.0	4.5	3.7
		MCWBR	3.1	3.4	3.3	3.8	3.8	3.6	3.7	4.0	3.6	3.1	3.4	3.2
Clear-Sky Solar Irradiance	taub	0.331	0.348	0.376	0.407	0.419	0.405	0.409	0.406	0.400	0.384	0.362	0.334	
	taud	2.498	2.441	2.374	2.296	2.301	2.380	2.378	2.395	2.407	2.431	2.433	2.486	
	Ebn at Noon	821	858	870	865	860	871	863	856	836	805	770	783	
	Edh at Noon	75	92	109	126	129	119	119	113	105	92	80	71	
All-Sky Solar Radiation	RadAvg	1.79	2.68	3.99	5.26	6.33	7.26	7.38	6.38	4.79	3.29	2.02	1.60	
	RadStd	0.18	0.26	0.37	0.34	0.49	0.32	0.27	0.32	0.20	0.27	0.16	0.16	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	+1.07	N/A	N/A	N/A	N/A	N/A	N/A
Regional (16 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page