

FIGARI SUD CORSE AP, France

WMO: 077800

Lat: 41.5053N

Lon: 9.1036E

Elev: 27

StdP: 101.01

Time Zone: 1.00 (EUC)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-2.0	-0.5	-5.7	2.3	3.0	-3.7	2.8	2.7	13.9	12.3	12.5	11.9	1.2	40	0.522

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.3	34.5	21.8	33.0	21.7	31.6	21.6	24.3	30.7	23.6	29.8	22.9	29.0	5.0	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.3	17.0	27.7	21.6	16.3	27.3	20.8	15.5	26.7	73.3	30.8	70.4	30.0	67.7	29.0	26.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.0	10.5	9.4	-4.9	38.2	1.3	1.9	-5.9	39.6	-6.7	40.7	-7.4	41.8	-8.4	43.2		
(5)			-5.4	25.4	1.4	0.8	-6.4	26.0	-7.2	26.5	-7.9	26.9	-8.9	27.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	16.0	8.8	8.8	11.0	13.7	17.4	21.6	24.4	24.2	20.9	17.7	13.2	10.0		
	DBStd	6.27	2.96	2.92	2.94	2.39	2.71	2.94	2.44	2.53	2.74	2.94	3.18	3.15		
	HDD10.0	188	59	53	24	2	1	0	0	0	0	0	9	39		
	HDD18.3	1452	295	267	227	138	49	7	1	1	8	47	156	257		
	CDD10.0	2387	22	19	56	114	230	348	448	441	326	238	104	41		
	CDD18.3	612	0	0	0	1	21	105	190	184	84	27	1	0		
	CDH23.3	6538	0	0	1	9	200	1086	2180	2172	771	118	1	0		
	CDH26.7	2558	0	0	1	0	37	375	971	989	179	7	0	0		
(14) Wind	WSAvg	4.2	4.1	4.2	4.8	4.7	4.5	4.3	4.4	3.9	3.8	3.9	3.9	4.2		
(15) Precipitation	PrecAvg	751	74	62	66	68	53	24	10	18	62	102	118	94		
	PrecMax	1105	185	175	213	126	227	71	34	94	140	249	268	212		
	PrecMin	512	5	12	0	13	8	1	0	0	9	0	28	6		
	PrecStd	161	42	40	45	30	44	17	10	20	35	57	60	47		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.8	17.5	21.1	24.6	30.2	34.7	36.3	37.3	31.9	27.8	22.8	18.7		
		MCWB	13.3	12.2	13.6	16.2	19.1	20.7	21.8	21.3	20.7	20.0	17.2	14.2		
	2%	DB	16.1	16.1	18.9	22.5	27.3	32.2	34.3	35.0	30.1	25.9	21.1	17.4		
		MCWB	12.5	11.8	12.9	15.3	17.7	20.8	22.0	22.1	20.7	19.7	16.7	13.7		
	5%	DB	15.2	15.2	17.7	20.9	25.6	30.5	32.9	33.1	28.7	24.6	19.8	16.5		
		MCWB	12.0	11.5	12.7	14.7	17.4	20.8	21.8	22.0	20.4	19.1	16.1	13.2		
	10%	DB	14.3	14.3	16.6	19.4	23.8	28.9	31.5	31.6	27.4	23.4	18.7	15.6		
		MCWB	11.3	10.9	12.3	14.0	16.9	20.2	21.7	22.0	19.9	18.4	15.3	12.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.4	13.7	15.1	17.5	20.3	24.1	25.1	25.3	23.5	21.8	18.6	15.6		
		MCDB	16.4	16.5	19.3	22.8	26.5	30.3	32.0	31.9	28.4	25.2	21.2	17.3		
	2%	WB	13.4	12.8	14.1	16.2	19.1	23.0	24.3	24.5	22.5	20.8	17.5	14.6		
		MCDB	15.5	15.0	17.3	20.9	24.5	29.0	30.9	30.8	27.3	24.1	20.1	16.6		
	5%	WB	12.6	12.2	13.5	15.4	18.3	22.0	23.6	23.7	21.8	20.0	16.6	13.9		
		MCDB	14.8	14.4	16.4	19.6	23.5	27.7	30.0	30.0	26.8	23.2	19.1	16.0		
	10%	WB	11.7	11.5	12.8	14.6	17.6	21.1	22.8	23.0	21.0	19.2	15.7	13.0		
		MCDB	14.0	13.9	15.6	18.4	22.6	26.9	29.2	29.2	25.9	22.6	18.2	15.1		
(35) Mean Daily Temperature Range	5% DB	MDBR	9.5	9.9	10.2	10.7	11.5	12.9	13.3	14.1	12.4	10.6	9.6	9.7		
		MCDBR	10.2	10.7	11.9	13.6	15.2	15.7	16.5	17.0	14.3	11.9	10.9	10.3		
	5% WB	MCWBR	7.5	7.6	7.7	8.1	7.7	7.2	7.6	7.8	7.5	7.0	7.3	7.5		
		MCWBR	8.4	9.5	9.7	12.3	12.8	14.0	14.5	15.6	12.8	9.8	9.3	8.0		
(40) Clear-Sky Solar Irradiance	taub	taub	0.336	0.354	0.384	0.417	0.430	0.415	0.418	0.415	0.409	0.391	0.369	0.339		
		taud	2.489	2.430	2.359	2.272	2.277	2.361	2.361	2.379	2.389	2.417	2.418	2.477		
	Edn at Noon	Edn at Noon	812	850	861	854	850	861	854	846	826	796	759	774		
		Edh at Noon	76	92	111	129	132	122	121	115	107	93	81	71		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1.78	2.68	4.00	5.29	6.36	7.28	7.39	6.38	4.79	3.29	2.01	1.59		
	RadStd	RadStd	0.17	0.26	0.35	0.33	0.48	0.33	0.26	0.31	0.20	0.27	0.15	0.16		

Historical Trends

		Heating		Cooling		Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD18.3
(46) Station Only	DBAvg	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(m)
(47) Regional (15 neighbors)	DBAvg	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page