

CAP CORSE, France

WMO: 077850

Lat: 43.005N

Lon: 9.358E

Elev: 371

StdP: 14.50

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	39.2	41.8	21.2	16.1	45.3	24.7	19.1	46.2	58.4	55.0	53.3	53.7	19.7	90	0.590

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	11.2	88.9	72.5	86.7	72.6	84.6	72.1	76.7	84.4	75.5	83.1	74.3	81.9	10.1	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
74.3	130.1	81.8	73.0	124.0	81.1	71.6	118.4	80.0	40.4	84.6	39.2	83.2	38.0	81.9	82.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
52.1	46.1	40.4	36.0	95.5	3.2	2.8	33.7	97.5	31.9	99.2	30.1	100.7	27.8	102.8
			32.0	78.1	3.2	1.7	29.7	79.4	27.8	80.4	26.0	81.4	23.7	82.6
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	63.8	51.7	51.1	54.6	59.7	65.8	73.0	78.2	78.4	72.6	66.8	59.4	53.9
	DBStd	10.58	4.30	4.72	4.06	4.11	4.52	4.81	3.58	3.32	4.04	4.34	5.30	4.47
	HDD50	106	33	39	12	0	0	0	0	0	0	0	4	18
	HDD65	1885	412	388	321	167	42	2	0	0	2	30	176	345
	CDD50	5160	86	71	156	290	490	689	875	879	679	522	285	138
	CDD65	1463	0	0	0	7	67	240	410	414	231	87	7	0
	CDH74	8985	0	0	0	6	187	1327	3337	3179	855	94	0	0
	CDH80	2161	0	0	0	0	26	303	906	821	103	2	0	0
(14) Wind	WSAvg	15.8	17.9	17.9	18.5	15.8	14.5	13.4	13.7	13.2	14.8	14.6	17.0	18.5
(15) Precipitation	PrecAvg	21.7	1.7	1.7	1.7	1.9	1.2	0.9	0.4	0.5	2.0	3.0	4.3	2.3
	PrecMax	29.4	4.6	5.2	4.9	4.3	4.9	2.8	2.9	1.6	5.3	12.5	10.6	5.0
	PrecMin	13.2	0.1	0.2	0.1	0.1	0.1	0.0	0.0	0.0	0.1	0.3	0.4	0.2
	PrecStd	5.0	1.1	1.2	1.1	1.1	1.1	0.7	0.6	0.5	1.5	2.4	2.8	1.3
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	64.1	62.7	66.5	74.2	83.3	90.8	92.9	92.0	86.0	79.6	71.6	64.7
		MCWB	56.5	54.0	54.9	58.2	64.4	70.1	72.3	73.6	72.7	68.9	62.8	57.4
	2%	DB	60.4	60.0	64.0	70.7	78.4	86.5	89.0	88.6	82.6	76.4	69.1	62.4
		MCWB	53.6	52.8	54.5	58.5	64.0	69.8	72.5	73.7	70.5	67.3	61.6	56.1
	5%	DB	58.9	58.2	61.9	68.3	75.4	83.1	86.7	86.4	80.5	74.3	67.2	60.9
		MCWB	52.9	51.7	53.7	58.1	62.9	69.8	72.8	73.3	69.7	66.0	60.6	55.0
	10%	DB	57.2	56.7	60.1	65.8	72.8	80.5	84.6	84.3	78.5	72.2	65.6	59.4
		MCWB	52.1	50.9	52.8	57.0	62.0	68.9	72.4	72.6	68.6	64.8	59.6	54.0
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	56.6	56.0	58.2	63.7	69.1	75.9	79.1	78.0	75.1	70.7	65.6	58.9
		MCDB	60.9	60.3	63.5	69.6	78.0	84.3	85.3	86.1	82.3	76.4	68.9	63.0
	2%	WB	55.1	54.2	56.5	61.2	66.7	73.8	77.1	76.6	73.1	68.9	63.5	57.3
		MCDB	58.8	58.3	61.4	67.2	74.6	81.6	84.4	84.5	80.0	74.6	67.3	60.9
	5%	WB	54.0	53.0	55.3	59.7	65.0	71.9	75.7	75.5	71.6	67.5	61.7	56.2
		MCDB	57.6	56.9	60.0	65.4	72.5	79.7	83.1	83.3	78.0	73.0	66.4	60.0
	10%	WB	52.7	51.9	54.1	58.3	63.6	70.2	74.4	74.4	70.3	66.0	60.1	54.8
		MCDB	56.4	55.9	58.6	63.8	70.7	78.4	82.0	82.0	76.4	71.1	64.9	58.9
(35) Mean Daily Temperature Range	5% DB	MDBR	6.8	7.3	8.3	9.5	10.4	11.3	11.3	11.2	9.6	8.2	7.1	6.5
		MCDBR	8.7	9.0	10.6	12.5	13.7	14.5	14.4	13.6	11.8	10.3	8.8	7.7
		MCWBR	6.5	6.8	7.7	8.5	9.5	9.6	9.8	9.6	8.3	6.7	6.5	6.1
	5% WB	MCDBR	7.4	8.1	9.6	11.1	12.4	13.0	12.0	12.2	11.0	9.6	7.8	6.7
		MCWBR	6.3	6.6	7.3	8.3	9.5	9.4	9.1	9.1	7.8	6.6	6.5	5.7
(40) Clear-Sky Solar Irradiance	taub	0.315	0.330	0.356	0.393	0.402	0.401	0.398	0.395	0.384	0.364	0.341	0.316	(40)
	taud	2.548	2.506	2.451	2.355	2.375	2.414	2.420	2.440	2.458	2.515	2.526	2.551	(41)
	Ebn at Noon	263	277	281	278	277	277	276	273	268	260	249	252	(42)
	Edh at Noon	22	27	32	37	38	36	36	34	31	26	22	20	(43)
(44) All-Sky Solar Radiation	RadAvg	525	802	1213	1643	1997	2257	2297	1997	1499	971	590	461	(44)
	RadStd	48	84	130	98	145	109	94	90	65	84	54	54	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (21 neighbors)	+0.45	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+128	+56

Nomenclature: See separate page