

BASTIA-PORETTA AP, FranceWMO: **077900**Lat: **42.5406N**Lon: **9.4853E**Elev: **26**StdP: **14.68**Time Zone: **1.00 (EUC)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	35.1	37.3	19.6	14.7	45.7	23.1	17.5	44.9	29.9	55.4	26.2	51.9	7.4	220	0.401

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	16.9	88.4	72.8	86.6	72.4	85.0	72.0	76.5	84.6	75.3	83.6	74.2	82.6	8.1	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
73.8	126.1	82.4	72.5	120.3	81.5	71.2	115.0	80.5	39.9	84.9	38.7	83.8	37.7	82.6	82.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 21.8	17.8	14.7	31.6	92.3	2.2	3.0	30.1	94.5	28.8	96.3	27.6	98.0	26.0	100.2		
(5)			28.8	78.0	2.1	1.5	27.4	79.1	26.1	80.0	25.0	80.8	23.5	81.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	61.2	49.0	48.9	52.3	56.5	63.3	70.6	75.7	76.3	70.0	63.6	56.2	50.9
	DBStd	10.56	4.14	4.42	3.86	3.52	3.84	4.27	3.48	3.16	3.72	4.01	4.71	4.54
	HDD50	205	65	64	22	1	0	0	0	0	0	0	9	44
	HDD65	2458	495	450	395	254	78	6	1	0	5	71	265	438
	CDD50	4290	35	33	92	198	412	619	797	815	601	423	194	71
	CDD65	1069	0	0	0	0	25	174	333	350	157	30	0	0
	CDH74	8815	0	0	3	1	156	1345	3167	3187	880	76	0	0
	CDH80	2425	0	0	0	0	13	278	990	1031	111	2	0	0
Wind	WSAvg	6.5	7.1	7.2	7.1	6.5	5.9	5.8	6.1	6.0	6.3	6.2	6.8	7.2
Precipitation	PrecAvg	29.7	2.3	3.3	2.8	2.4	1.8	1.3	0.5	1.5	1.8	4.2	3.9	3.7
	PrecMax	48.6	7.4	9.1	8.0	10.2	5.9	4.3	2.7	6.1	5.0	15.2	9.3	12.3
	PrecMin	14.6	0.3	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.2	0.0	0.2
	PrecStd	8.6	1.8	2.4	2.2	2.3	1.5	1.2	0.6	1.6	1.3	3.7	2.5	2.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	66.0	64.5	68.7	72.9	81.8	88.4	90.4	92.2	85.0	78.9	71.4	68.0
		MCWB	53.6	51.5	54.7	61.0	64.9	71.5	71.8	72.2	70.0	67.1	61.9	54.2
	2%	DB	61.0	61.3	64.6	70.0	78.2	85.5	88.2	89.0	82.8	76.0	68.3	63.0
		MCWB	52.7	52.2	54.2	59.5	64.9	71.4	73.0	73.2	69.7	66.7	60.6	55.1
	5%	DB	58.9	59.5	62.7	67.5	75.3	83.3	86.6	86.9	81.0	73.9	66.5	61.0
		MCWB	52.2	51.7	54.2	58.2	63.4	70.4	72.8	72.6	69.0	65.7	59.9	54.3
	10%	DB	57.0	57.8	60.9	65.4	73.0	80.9	85.1	85.1	79.0	72.0	64.5	59.0
		MCWB	50.6	50.9	53.5	57.0	62.5	69.3	72.3	72.2	67.8	64.5	58.7	52.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	57.3	56.5	58.9	63.7	69.6	75.6	78.1	78.4	75.2	71.1	65.7	59.5
		MCDB	61.0	60.6	64.3	70.6	77.1	84.3	86.5	86.2	81.2	75.0	68.7	62.4
	2%	WB	55.4	54.8	57.3	61.3	67.1	73.9	76.5	76.9	73.0	69.2	63.1	57.5
		MCDB	59.3	59.0	61.8	67.5	74.7	82.5	85.1	84.6	79.5	73.5	66.2	61.2
	5%	WB	53.5	53.4	56.1	59.8	65.5	72.2	75.2	75.6	71.5	67.8	61.4	55.7
		MCDB	57.7	57.9	60.5	65.5	72.8	80.7	83.9	83.7	78.2	72.3	65.0	59.8
	10%	WB	51.6	51.7	54.9	58.5	64.1	70.6	74.1	74.4	69.9	65.9	59.7	53.9
		MCDB	55.9	56.6	59.3	63.6	70.9	78.8	82.7	82.9	76.7	70.6	63.7	57.7
Mean Daily Temperature Range	5% DB	MDBR	14.2	15.0	15.6	16.1	16.8	17.1	17.2	16.9	16.0	15.2	14.3	14.4
		MCDBR	16.6	17.1	18.3	18.7	19.9	19.0	18.5	18.5	17.6	16.5	15.5	16.4
		MCWBR	11.9	12.0	12.4	11.8	11.2	10.3	10.7	11.0	10.6	10.9	10.6	11.5
	5% WB	MCDBR	15.1	16.1	16.3	16.9	17.4	17.3	17.1	16.7	16.1	14.8	14.0	14.9
		MCWBR	11.7	12.1	12.0	11.7	11.1	10.3	10.7	10.8	10.6	10.7	10.7	11.2
Clear-Sky Solar Irradiance	taub		0.322	0.339	0.367	0.406	0.416	0.410	0.409	0.406	0.396	0.375	0.352	0.325
	taud		2.529	2.476	2.411	2.305	2.321	2.375	2.381	2.401	2.420	2.478	2.489	2.531
	Ebn at Noon		261	274	278	274	273	274	273	271	265	257	246	249
	Edh at Noon		23	28	33	39	40	38	37	36	32	27	23	21
All-Sky Solar Radiation	RadAvg		544	825	1205	1621	1959	2213	2257	1968	1483	982	607	480
	RadStd		50	79	128	96	146	111	94	95	68	84	57	53

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (18 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page