

BASTIA-PORETTA AP, FranceWMO: **077900**Lat: **42.5406N**Lon: **9.4853E**Elev: **8**StdP: **101.23**Time Zone: **1.00 (EUC)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	1.7	3.0	-6.9	2.1	7.6	-4.9	2.5	7.1	13.3	13.0	11.7	11.1	3.3	220	0.401

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.4	31.3	22.7	30.4	22.5	29.5	22.2	24.7	29.2	24.1	28.7	23.4	28.1	3.6	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.2	18.0	28.0	22.5	17.2	27.5	21.8	16.4	27.0	75.0	29.4	72.2	28.8	69.7	28.1	27.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
9.7	8.0	6.6		-0.2	33.5	1.2	1.7	-1.1	34.7	-1.8	35.7	-2.5	36.7	-3.3	37.9	
				DB												
				WB	-1.8	25.6	1.1	0.8	-2.6	26.2	-3.3	26.7	-3.9	27.1	-4.7	27.7

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	16.2	9.5	9.4	11.3	13.6	17.4	21.5	24.3	24.6	21.1	17.6	13.4	10.5
	DBStd	5.87	2.30	2.46	2.14	1.95	2.13	2.37	1.94	1.76	2.07	2.23	2.62	2.52
	HDD10.0	114	36	36	12	1	0	0	0	0	0	0	5	24
	HDD18.3	1366	275	250	219	141	43	3	1	0	3	39	147	243
	CDD10.0	2383	19	18	51	110	229	344	443	453	334	235	108	39
	CDD18.3	594	0	0	0	0	14	97	185	194	87	17	0	0
	CDH23.3	4897	0	0	2	1	87	747	1759	1771	489	42	0	0
CDH26.7	1347	0	0	0	0	7	154	550	573	62	1	0	0	
Wind	WSAvg	2.9	3.2	3.2	3.2	2.9	2.6	2.6	2.7	2.7	2.8	2.8	3.0	3.2
Precipitation	PrecAvg	755	58	84	72	62	45	34	12	38	46	106	98	95
	PrecMax	1234	187	232	204	259	150	109	68	154	127	387	236	312
	PrecMin	372	8	0	3	1	0	1	0	0	0	6	1	5
	PrecStd	218	46	62	55	58	39	31	16	40	32	94	64	73
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	18.9	18.1	20.4	22.7	27.7	31.3	32.4	33.5	29.5	26.0	21.9	20.0
		MCWB	12.0	10.8	12.6	16.1	18.3	22.0	22.1	22.3	21.1	19.5	16.6	12.4
	2%	DB	16.1	16.3	18.1	21.1	25.7	29.7	31.2	31.7	28.2	24.5	20.1	17.2
		MCWB	11.5	11.2	12.4	15.3	18.3	21.9	22.8	22.9	21.0	19.3	15.9	12.8
	5%	DB	14.9	15.3	17.0	19.7	24.0	28.5	30.4	30.5	27.2	23.3	19.2	16.1
		MCWB	11.2	10.9	12.4	14.6	17.4	21.3	22.7	22.5	20.5	18.7	15.5	12.4
	10%	DB	13.9	14.3	16.1	18.5	22.8	27.2	29.5	29.5	26.1	22.2	18.1	15.0
		MCWB	10.4	10.5	12.0	13.9	17.0	20.7	22.4	22.3	19.9	18.1	14.8	11.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.0	13.6	15.0	17.6	20.9	24.2	25.6	25.8	24.0	21.7	18.7	15.3
		MCDB	16.1	15.9	18.0	21.4	25.1	29.1	30.3	30.1	27.3	23.9	20.4	16.9
	2%	WB	13.0	12.6	14.1	16.3	19.5	23.3	24.7	24.9	22.8	20.7	17.3	14.2
		MCDB	15.2	15.0	16.6	19.7	23.7	28.0	29.5	29.2	26.4	23.1	19.0	16.2
	5%	WB	11.9	11.9	13.4	15.5	18.6	22.4	24.0	24.2	22.0	19.9	16.3	13.2
		MCDB	14.3	14.4	15.8	18.6	22.7	27.1	28.8	28.7	25.7	22.4	18.3	15.4
	10%	WB	10.9	11.0	12.7	14.7	17.8	21.5	23.4	23.6	21.1	18.8	15.4	12.1
		MCDB	13.3	13.6	15.2	17.6	21.6	26.0	28.2	28.3	24.8	21.4	17.6	14.3
Mean Daily Temperature Range	5% DB	MDBR	7.9	8.3	8.7	8.9	9.3	9.5	9.6	9.4	8.9	8.4	7.9	8.0
		MCDBR	9.2	9.5	10.2	10.4	11.1	10.5	10.3	10.3	9.8	9.2	8.6	9.1
		MCWBR	6.6	6.7	6.9	6.6	6.2	5.7	5.9	6.1	5.9	6.0	5.9	6.4
	5% WB	MCDBR	8.4	8.9	9.0	9.4	9.7	9.6	9.5	9.3	8.9	8.2	7.8	8.3
		MCWBR	6.5	6.7	6.6	6.5	6.2	5.7	6.0	6.0	5.9	6.0	6.0	6.2
Clear-Sky Solar Irradiance	taub	0.322	0.339	0.367	0.406	0.416	0.410	0.409	0.406	0.396	0.375	0.352	0.325	
	taud	2.529	2.476	2.411	2.305	2.321	2.375	2.381	2.401	2.420	2.478	2.489	2.531	
	Ebn at Noon	823	863	876	863	861	864	861	853	835	810	775	785	
	Edh at Noon	71	87	104	124	126	120	118	112	102	86	74	66	
All-Sky Solar Radiation	RadAvg	1.71	2.60	3.80	5.11	6.18	6.98	7.12	6.20	4.67	3.10	1.91	1.51	
	RadStd	0.16	0.25	0.40	0.30	0.46	0.35	0.30	0.30	0.21	0.27	0.18	0.17	