

LA CORUNA, Spain

WMO: 080010

Lat: 43.3658N

Lon: 8.4214W

Elev: 67

StdP: 100.52

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	4.6	5.8	-1.3	3.4	7.1	0.3	3.9	7.8	11.3	11.1	10.3	11.8	2.7	150	0.439

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.3	25.9	19.2	24.2	18.6	22.9	18.1	20.2	24.1	19.5	22.8	18.9	21.7	3.2	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.8	13.7	21.6	18.2	13.2	21.0	17.7	12.8	20.5	58.0	24.1	55.7	23.0	53.9	21.8	24.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.6	8.4	7.5	2.2	30.2	2.1	2.1	0.7	31.7	-0.5	32.9	-1.6	34.1	-3.2	35.6		
			0.8	22.2	1.9	0.9	-0.6	22.9	-1.7	23.4	-2.7	23.9	-4.1	24.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	15.0	11.0	11.1	12.4	13.2	15.1	17.6	19.1	19.6	18.6	16.6	13.3	11.7
	DBStd	3.75	2.33	2.33	2.36	2.14	2.15	2.02	1.58	1.50	1.82	2.23	2.36	2.46
	HDD10.0	49	16	13	6	1	0	0	0	0	0	2	11	
	HDD18.3	1360	226	202	185	154	102	37	8	4	18	64	153	206
	CDD10.0	1859	48	44	79	97	159	227	281	298	257	203	100	64
	CDD18.3	129	0	0	1	1	3	15	31	43	26	9	1	0
	CDH23.3	250	0	0	1	4	13	53	62	64	39	13	0	0
Wind	WSAvg	3.4	3.8	3.9	3.9	3.7	3.4	3.3	3.2	3.0	2.9	3.0	3.6	3.6
	PrecAvg	1014	126	101	88	84	73	48	29	34	61	115	136	121
Precipitation	PrecMax	1399	292	250	262	232	173	133	100	98	160	308	297	400
	PrecMin	673	3	10	0	5	9	1	1	1	3	16	2	21
	PrecStd	179	66	58	61	46	38	34	26	26	41	73	67	64
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.4	19.7	21.6	22.2	25.0	27.9	28.3	27.3	26.5	24.9	21.0	18.5
		MCWB	13.5	13.2	13.8	15.3	17.7	20.3	20.6	20.1	19.1	18.0	16.3	14.1
	2%	DB	16.1	16.8	18.7	19.7	21.8	24.6	24.8	25.0	24.2	22.5	19.2	17.1
		MCWB	13.3	12.3	13.2	14.3	16.1	18.2	19.2	19.5	18.8	17.4	16.0	13.8
	5%	DB	15.2	15.4	17.1	17.9	19.8	22.3	23.0	23.5	22.9	21.1	17.7	16.2
		MCWB	12.7	12.2	12.8	13.6	15.5	17.2	18.5	18.9	18.2	17.0	14.9	13.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	10%	DB	14.4	14.4	15.9	16.5	18.4	20.7	21.7	22.3	21.6	20.0	16.6	15.3
		MCWB	12.0	11.6	12.4	13.0	14.8	16.7	18.0	18.4	17.6	16.6	14.2	12.8
	0.4%	WB	15.0	14.2	15.4	16.1	18.2	20.7	21.0	21.5	20.4	19.5	17.7	15.5
		MCDB	16.4	16.8	18.5	20.3	23.2	26.7	26.3	25.5	24.3	22.0	19.7	17.0
	2%	WB	14.0	13.5	14.3	14.9	17.0	18.9	19.7	20.2	19.5	18.5	16.4	14.6
		MCDB	15.6	15.7	17.2	18.4	20.7	23.2	23.8	23.6	22.9	21.1	18.4	16.3
Mean Daily Temperature Range	5%	WB	13.1	12.7	13.5	14.2	16.1	17.9	19.0	19.5	18.8	17.7	15.5	13.8
		MCDB	14.6	14.8	16.4	17.0	18.9	21.0	22.1	22.4	21.7	20.3	17.3	15.7
	10%	WB	12.3	12.0	12.7	13.5	15.3	17.2	18.4	19.0	18.2	17.0	14.5	13.1
		MCDB	13.9	14.0	15.3	16.0	17.8	19.8	21.1	21.4	20.8	19.3	16.3	15.0
	5% DB	MDBR	4.1	4.8	5.3	5.2	5.1	5.2	5.1	5.3	5.6	5.3	4.2	4.3
		MCDBR	4.3	6.5	7.4	7.8	7.5	8.2	7.3	7.2	7.5	7.0	5.2	4.9
Clear-Sky Solar Irradiance	taub	taud	0.340	0.345	0.376	0.383	0.385	0.389	0.379	0.377	0.370	0.366	0.346	0.333
		Ebn at Noon	2.468	2.448	2.368	2.359	2.383	2.392	2.429	2.446	2.462	2.475	2.466	2.479
	Edh at Noon		787	848	862	883	888	882	887	878	858	814	770	758
			74	88	108	117	118	117	112	106	97	85	74	68
All-Sky Solar Radiation	RadAvg		1.43	2.33	3.49	4.75	5.69	6.18	6.19	5.54	4.43	2.79	1.68	1.31
	RadStd		0.16	0.33	0.50	0.47	0.48	0.41	0.37	0.41	0.27	0.32	0.24	0.17

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	N/A	+0.45	+0.27	N/A	N/A	N/A	N/A	N/A
Regional (6 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page