

ALBACETE AP, Spain

WMO: 082800

Lat: 38.952N

Lon: 1.863W

Elev: 702

StdP: 93.18

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-4.9	-3.0	-9.0	1.9	2.8	-6.8	2.3	2.7	14.1	10.9	12.7	9.3	1.6	170	0.518

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.4	36.1	19.2	34.9	18.9	33.2	18.5	21.6	31.1	20.6	29.5	19.9	28.4	4.6	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.2	15.2	23.5	18.2	14.3	22.6	17.3	13.5	22.2	66.1	31.3	62.5	29.5	60.0	28.3	29.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
11.3	9.7	8.4	-8.8	38.8	2.9	1.4	-10.9	39.8	-12.6	40.6	-14.3	41.4	-16.4	42.3		
			-9.2	23.3	2.9	1.8	-11.3	24.6	-13.0	25.7	-14.7	26.7	-16.8	28.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	14.6	5.6	6.9	9.9	12.5	16.5	21.8	25.3	25.0	20.3	15.6	9.2	6.2	(6)
(7)		DBStd	7.57	3.05	3.09	3.14	3.05	3.45	3.35	2.35	2.30	3.02	3.16	3.34	3.06	(7)
(8)		HDD10.0	459	138	91	41	11	1	0	0	0	3	53	122		(8)
(9)		HDD18.3	1994	394	319	262	176	76	9	0	16	93	274	376		(9)
(10)		CDD10.0	2144	3	6	37	85	204	354	473	464	308	177	29	4	(10)
(11)		CDD18.3	638	0	0	0	1	21	113	216	206	73	9	0	0	(11)
(12)		CDH23.3	7865	0	0	9	41	340	1471	2746	2392	741	124	1	0	(12)
(13)		CDH26.7	3784	0	0	1	3	88	681	1496	1242	254	19	0	0	(13)
(14)	Wind	WSAvg	3.6	3.7	4.0	4.0	4.0	3.6	3.6	3.7	3.6	3.2	3.0	3.5	3.3	(14)
(15)	Precipitation	PrecAvg	357	23	27	28	46	44	37	10	13	27	40	36	31	(15)
(16)		PrecMax	548	71	89	109	115	160	136	41	54	103	167	116	100	(16)
(17)		PrecMin	189	0	0	0	3	1	0	0	0	0	0	0	0	(17)
(18)		PrecStd	97	18	20	24	31	33	33	12	14	25	35	25	23	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	16.9	19.9	24.8	26.8	31.8	36.9	38.1	37.8	34.1	28.9	21.2	16.8	(19)
(20)		MCWB	10.2	10.8	13.0	14.6	17.7	18.8	19.5	19.2	18.3	15.7	13.2	11.3		(20)
(21)		2%	DB	14.5	17.4	21.8	24.3	29.0	34.3	36.2	35.8	31.2	26.5	18.9	14.7	(21)
(22)		MCWB	9.4	9.7	11.7	13.7	16.1	18.6	19.2	19.3	17.7	15.3	12.3	10.7		(22)
(23)		5%	DB	12.9	15.2	19.3	22.3	27.0	32.5	35.1	34.2	29.6	24.3	16.9	13.0	(23)
(24)		MCWB	8.8	9.0	10.8	12.9	15.4	18.3	18.9	18.9	17.3	15.0	11.7	9.8		(24)
(25)		10%	DB	11.2	13.1	17.1	20.1	25.0	30.8	33.8	32.9	27.7	22.2	15.0	11.7	(25)
(26)		MCWB	8.0	8.3	10.1	12.0	14.9	17.7	18.7	18.7	17.0	14.7	11.1	8.9		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.0	12.1	14.2	16.0	18.7	22.4	23.5	23.7	20.9	18.6	15.1	13.0	(27)
(28)		MCDWB	14.9	16.7	20.9	24.1	28.5	32.9	34.0	32.7	26.9	23.3	18.4	14.7		(28)
(29)		2%	WB	10.5	10.8	12.7	14.5	17.3	20.4	21.5	21.6	19.8	17.2	13.6	11.4	(29)
(30)		MCDWB	13.1	15.5	19.6	22.3	26.1	31.0	32.0	30.2	26.0	21.9	16.7	13.6		(30)
(31)		5%	WB	9.5	9.7	11.6	13.5	16.3	19.3	20.4	20.7	19.0	16.4	12.6	10.2	(31)
(32)		MCDWB	11.9	13.9	17.4	20.8	24.6	29.4	30.3	28.8	25.0	20.9	15.5	12.3		(32)
(33)		10%	WB	8.5	8.8	10.6	12.5	15.4	18.3	19.7	20.0	18.2	15.6	11.7	9.3	(33)
(34)		MCDWB	10.8	12.5	15.8	18.9	22.9	28.1	29.4	27.8	24.1	20.0	14.5	11.3		(34)
(35)	Mean Daily Temperature Range	MDBR	10.7	11.6	12.5	12.6	13.5	15.5	16.4	15.3	13.2	12.0	10.7	10.1	(35)	
(36)		5% DB	13.7	16.2	17.2	17.0	17.1	18.1	18.1	17.4	16.3	15.8	13.8	11.9		(36)
(37)		MCWBR	8.9	9.3	8.6	8.0	7.2	7.0	6.8	6.2	5.8	6.7	8.1	8.1		(37)
(38)		5% WB	10.7	13.0	14.2	15.3	15.3	16.8	16.7	15.3	13.8	11.9	10.7	10.0		(38)
(39)		MCWBR	7.6	8.0	7.6	7.7	7.0	7.2	7.1	6.2	5.7	5.7	6.8	7.3		(39)
(40)	Clear-Sky Solar Irradiance	taub	0.280	0.301	0.341	0.350	0.372	0.384	0.370	0.378	0.362	0.339	0.304	0.286	(40)	
(41)		taud	2.494	2.456	2.352	2.344	2.314	2.307	2.339	2.321	2.369	2.432	2.493	2.498	(41)	
(42)		Ebn at Noon	906	929	916	926	907	893	902	886	882	869	867	871	(42)	
(43)		Edh at Noon	77	92	113	122	128	129	124	123	110	93	77	72	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.36	3.21	4.41	5.52	6.55	7.50	7.66	6.60	5.11	3.66	2.55	2.11	(44)	
(45)		RadStd	0.29	0.39	0.47	0.45	0.50	0.28	0.20	0.26	0.27	0.30	0.30	0.19	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	-0.77	-0.63	N/A	N/A	N/A	N/A
(47)	Regional (5 neighbors)	N/A	N/A	-1.40	+0.47	N/A	N/A	N/A	N/A	N/A	+55

Nomenclature: See separate page