

BADAJOZ AP, Spain

WMO: 083300

Lat: 38.883N

Lon: 6.814W

Elev: 192

StdP: 99.04

Time Zone: 1.00 (EUC)

Period: 03-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-1.2	0.0	-5.7	2.4	5.7	-3.4	2.9	6.4	10.8	12.9	9.4	11.7	0.8	100	0.435

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	16.8	39.2	22.2	37.4	21.2	35.9	20.7	23.7	36.9	22.5	35.0	21.5	33.4	3.3	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.2	14.3	27.7	18.4	13.6	25.9	17.8	13.1	25.0	71.2	37.0	66.5	35.2	63.2	33.3	31.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
8.7	7.5	6.6	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	17.4	8.7	10.0	12.9	16.0	19.5	23.9	26.1	26.6	23.7	18.7	13.0	9.4
	DBStd	7.01	2.75	2.77	2.58	2.98	3.44	3.55	2.85	2.83	2.61	3.05	3.00	2.79
	HDD10.0	153	59	32	7	0	0	0	0	0	0	9	47	
	HDD18.3	1284	298	232	169	83	28	1	0	0	32	162	278	
	CDD10.0	2858	18	33	96	179	295	417	499	514	412	270	98	27
	CDD18.3	949	0	0	0	12	64	168	241	256	162	44	1	0
	CDH23.3	12004	0	0	26	233	863	2138	3149	3337	1808	445	4	0
	CDH26.7	6409	0	0	1	58	353	1151	1846	1971	878	151	0	0
Wind	WSAvg	2.7	2.4	2.9	3.2	3.0	3.0	3.0	2.8	2.3	2.3	2.5	2.3	
Precipitation	PrecAvg	488	54	56	48	48	33	22	4	23	64	64	57	
	PrecMax	806	208	167	181	145	109	134	27	34	122	256	226	244
	PrecMin	228	0	0	0	1	0	0	0	0	0	2	0	
	PrecStd	141	41	44	43	33	29	24	7	26	49	46	53	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	18.1	21.1	26.2	30.2	35.2	40.2	41.2	42.2	38.0	33.6	24.0	18.4
		MCWB	12.5	13.2	14.6	16.8	19.6	22.9	23.6	23.9	21.2	18.9	16.4	14.3
	2%	DB	16.2	19.0	24.0	28.6	32.8	37.1	39.0	39.6	35.8	30.7	21.7	16.9
		MCWB	12.0	12.2	14.0	16.5	18.4	21.5	21.8	22.8	20.4	17.3	15.0	13.8
	5%	DB	15.0	17.3	22.0	26.1	30.3	35.2	37.1	37.6	33.7	28.0	20.0	15.8
		MCWB	11.6	11.6	13.4	15.8	17.8	20.7	21.3	21.0	19.7	17.4	14.7	12.6
	10%	DB	14.0	15.9	19.8	23.8	28.2	33.1	35.2	35.8	31.8	25.8	18.4	14.6
		MCWB	11.1	11.5	12.8	15.0	17.0	19.8	20.7	20.8	19.3	16.5	14.1	11.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.5	15.2	16.2	18.9	21.3	24.3	24.8	26.0	23.1	20.3	18.5	16.1
		MCDB	15.8	17.5	22.9	26.8	33.3	37.8	39.2	40.7	35.8	26.7	21.0	16.9
	2%	WB	13.5	13.9	15.1	17.5	19.7	22.6	23.3	23.9	21.5	19.5	17.0	14.5
		MCDB	15.0	16.6	20.9	25.9	29.8	35.3	36.8	36.5	32.9	25.4	19.3	16.3
	5%	WB	12.6	12.9	14.2	16.4	18.6	21.5	22.1	22.4	20.6	18.7	15.9	13.4
		MCDB	14.2	15.8	19.8	24.2	28.0	33.3	34.8	34.7	30.8	24.3	18.4	15.1
	10%	WB	11.7	12.0	13.4	15.4	17.6	20.5	21.0	21.4	19.7	17.9	14.9	12.3
		MCDB	13.4	15.1	18.3	22.3	26.4	31.4	32.9	33.1	29.2	23.3	17.6	14.2
Mean Daily Temperature Range	5% DB	MDBR	10.3	11.6	12.2	12.9	14.1	15.7	17.3	16.8	15.2	12.7	10.6	10.1
		MCDBR	12.0	13.9	16.9	17.3	18.0	18.5	19.2	19.3	18.1	17.2	12.6	10.6
		MCWBR	8.0	8.1	8.6	7.4	7.0	6.4	7.1	6.7	6.9	6.9	6.9	7.0
	5% WB	MCDBR	7.9	10.5	13.5	14.7	16.1	17.8	18.4	17.7	16.0	12.6	8.6	7.8
		MCWBR	5.7	6.7	7.4	6.7	6.5	6.4	7.6	7.1	6.4	5.9	5.5	5.8
Clear-Sky Solar Irradiance	taub	0.314	0.332	0.365	0.367	0.376	0.379	0.358	0.374	0.368	0.353	0.327	0.314	
	taud	2.493	2.444	2.357	2.366	2.370	2.378	2.403	2.368	2.408	2.471	2.500	2.501	
	Ebn at Noon	863	892	892	910	904	897	913	891	877	856	839	835	
	Edh at Noon	78	94	113	119	121	120	116	117	106	90	77	73	
All-Sky Solar Radiation	RadAvg	2.31	3.27	4.37	5.50	6.69	7.62	7.92	6.93	5.31	3.64	2.55	2.05	
	RadStd	0.32	0.42	0.50	0.51	0.56	0.39	0.20	0.22	0.34	0.32	0.32	0.24	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (10 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page