

ALICANTE AP, Spain

WMO: 083600

Lat: 38.283N

Lon: 0.571W

Elev: 142

StdP: 14.62

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	38.1	40.7	18.2	13.8	47.8	22.6	17.1	50.6	28.9	58.0	25.5	57.7	5.7	290	0.398

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	15.0	91.0	70.1	88.6	70.7	86.8	71.0	77.3	83.6	76.1	83.0	74.9	82.4	10.3	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
75.4	133.8	81.0	73.7	126.4	80.6	72.3	120.3	80.2	40.9	83.1	39.6	83.0	38.4	82.2	82.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
23.1	20.1	17.6	33.1	98.0	2.3	3.1	31.5	100.3	30.1	102.1	28.9	103.9	27.2	106.1		
			29.2	78.1	2.9	2.0	27.1	79.5	25.3	80.7	23.7	81.8	21.5	83.2		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	65.2	53.5	54.1	57.3	61.1	66.7	73.7	78.5	79.5	74.6	68.3	59.7	54.8
	DBStd	10.19	4.80	4.98	4.90	3.99	4.01	3.85	2.93	2.79	3.75	4.21	5.23	4.56
	HDD50	50	18	15	3	0	0	0	0	0	0	0	2	12
	HDD65	1570	356	307	244	128	28	0	0	0	17	172	318	
	CDD50	5606	128	129	231	334	517	710	884	914	739	567	293	160
	CDD65	1650	1	1	7	11	80	261	419	449	289	119	13	0
	CDH74	13660	1	6	47	67	401	1916	4057	4525	2062	533	44	1
	CDH80	4035	0	1	7	6	60	489	1343	1552	499	75	3	0
Wind	WSAvg	7.2	8.0	8.2	7.9	7.6	6.9	6.8	6.7	6.6	6.7	6.3	7.5	7.6
Precipitation	PrecAvg	11.0	0.9	0.7	1.0	1.2	1.0	0.5	0.2	0.4	1.5	1.3	1.3	1.1
	PrecMax	18.4	2.9	3.6	2.8	3.2	3.9	2.9	0.9	2.5	7.5	5.9	3.5	5.9
	PrecMin	5.5	0.0	0.0	0.0	0.2	0.0	0.0	0.0	0.0	0.1	0.1	0.2	0.0
	PrecStd	3.1	0.8	0.9	0.8	0.9	0.9	0.6	0.2	0.6	1.6	1.2	0.9	1.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	71.9	74.1	79.2	79.7	85.3	92.1	93.4	95.0	91.7	86.1	78.8	71.7
		MCWB	55.6	56.2	58.2	60.0	63.4	66.0	69.1	70.4	68.4	67.2	62.0	57.8
	2%	DB	68.1	69.8	73.8	75.5	81.0	87.9	90.1	91.0	87.5	81.8	74.4	68.1
		MCWB	54.2	55.0	56.7	58.5	62.4	67.4	70.4	71.8	69.1	66.2	60.5	56.0
	5%	DB	65.1	66.5	70.2	72.9	78.3	85.1	88.1	88.4	84.9	79.1	71.4	65.7
		MCWB	52.6	53.2	55.4	57.9	62.0	67.2	70.8	72.5	70.0	66.1	59.7	54.9
	10%	DB	62.4	63.4	67.1	70.2	75.6	82.5	86.3	86.6	82.6	76.9	68.6	63.1
		MCWB	51.9	52.3	54.4	57.1	61.8	66.8	71.2	72.9	69.8	65.4	58.3	54.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	58.7	58.9	61.2	63.8	68.9	74.2	78.2	79.3	77.1	71.6	65.8	61.0
		MCDB	65.9	69.3	72.3	73.1	75.1	82.3	84.2	84.6	82.3	79.1	72.6	66.8
	2%	WB	56.4	56.9	59.2	61.9	66.9	72.3	76.5	78.0	74.7	69.9	63.6	58.8
		MCDB	63.9	65.5	68.9	70.0	74.1	79.9	83.4	83.9	81.7	76.6	70.5	64.5
	5%	WB	54.9	55.4	57.6	60.5	65.6	70.9	75.3	76.8	73.2	68.7	61.8	57.0
		MCDB	62.3	63.2	66.0	68.5	73.1	78.7	82.6	83.4	80.5	75.7	68.6	63.1
	10%	WB	53.5	53.9	56.4	59.3	64.2	69.7	74.2	75.6	72.0	67.4	60.2	55.4
		MCDB	60.8	61.3	64.1	67.2	72.1	77.9	82.0	82.9	79.6	74.5	66.8	61.8
Mean Daily Temperature Range	5% DB	MDBR	17.1	17.5	18.1	17.5	16.7	16.3	15.3	15.0	15.7	16.3	16.2	16.4
		MCDBR	20.0	21.0	22.7	21.1	20.7	20.1	18.3	18.0	18.7	19.4	18.8	18.8
		MCWBR	11.1	11.2	11.2	10.2	9.6	9.2	9.6	9.6	9.6	9.9	10.5	10.7
	5% WB	MCDBR	17.4	18.9	19.3	18.4	17.0	16.1	14.9	14.9	15.8	16.4	16.3	16.7
		MCWBR	11.2	11.8	11.3	10.3	8.8	9.0	9.0	9.2	9.2	9.6	10.2	10.7
Clear-Sky Solar Irradiance	taub	0.311	0.336	0.382	0.394	0.421	0.442	0.449	0.452	0.423	0.388	0.344	0.319	
	taud	2.502	2.453	2.329	2.318	2.270	2.239	2.233	2.230	2.313	2.399	2.482	2.503	
	Ebn at Noon	277	283	278	280	273	267	264	260	261	259	261	265	
	Edh at Noon	25	30	37	40	43	44	44	43	37	31	25	23	
All-Sky Solar Radiation	RadAvg	792	1046	1427	1758	2093	2360	2336	2020	1572	1162	821	683	
	RadStd	78	107	117	126	144	74	60	66	86	92	76	55	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	-2.97	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (5 neighbors)	N/A	N/A	-2.43	+0.74	N/A	N/A	N/A	N/A	N/A	+88

Nomenclature: See separate page