

IBIZA AP, Spain

WMO: 083730

Lat: 38.876N

Lon: 1.384E

Elev: 17

StdP: 101.12

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	4.2	5.5	-2.1	3.2	9.0	-0.1	3.8	9.4	13.3	13.9	12.2	14.2	1.4	340	0.416

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.1	31.1	23.9	30.2	23.6	29.5	23.4	25.8	29.3	25.1	28.6	24.5	28.1	4.3	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.7	19.8	28.0	24.0	18.9	27.7	23.2	18.0	27.3	79.4	29.5	76.6	28.7	74.1	28.1	29.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
11.1	9.6	8.4	1.9	34.1	1.3	1.4	1.0	35.2	0.3	36.0	-0.4	36.8	-1.4	37.9		
			0.7	26.7	1.3	1.1	-0.2	27.4	-1.0	28.1	-1.7	28.6	-2.6	29.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	18.3	11.9	11.9	13.6	15.8	18.8	22.8	25.6	26.3	23.6	20.3	15.7	12.9
	DBStd	5.55	2.30	2.46	2.21	1.87	2.02	2.04	1.53	1.55	2.05	2.26	2.67	2.33
	HDD10.0	23	8	9	2	0	0	0	0	0	0	0	1	4
	HDD18.3	884	199	179	147	79	19	1	0	0	0	8	84	168
	CDD10.0	3056	67	63	114	173	272	384	484	504	408	319	172	95
	CDD18.3	874	0	0	0	2	33	134	226	246	158	69	6	0
	CDH23.3	6585	0	0	1	3	70	804	2057	2417	1031	198	5	0
	CDH26.7	1577	0	0	0	0	3	136	551	713	164	10	0	0
Wind	WSAvg	3.6	3.9	4.1	4.1	4.0	3.5	3.4	3.3	3.3	3.3	3.3	3.9	3.7
Precipitation	PrecAvg	414	39	29	33	33	26	16	2	23	46	64	50	54
	PrecMax	720	148	98	122	110	99	145	15	97	167	190	171	169
	PrecMin	175	0	0	0	0	0	0	0	0	0	0	1	0
	PrecStd	139	35	27	33	28	25	24	3	30	47	53	37	46
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	19.5	20.0	21.8	23.6	26.9	31.0	32.2	33.0	30.8	27.9	23.9	19.8
		MCWB	13.8	13.9	14.2	15.9	18.4	22.0	23.1	23.8	23.6	21.7	18.0	15.4
	2%	DB	18.0	18.3	19.9	21.9	25.1	29.3	30.9	31.5	29.2	26.3	22.2	18.6
		MCWB	13.5	13.3	13.9	15.6	18.2	21.9	23.6	24.3	23.1	21.2	17.6	14.8
	5%	DB	16.9	17.1	18.7	20.8	23.9	28.1	30.0	30.5	28.4	25.3	21.2	17.8
		MCWB	13.3	13.0	13.8	15.5	18.1	21.5	23.3	24.2	22.7	20.6	17.1	14.4
	10%	DB	16.0	16.1	17.6	19.8	22.9	27.1	29.2	29.8	27.6	24.3	20.1	17.0
		MCWB	12.7	12.4	13.5	15.2	17.8	21.3	23.2	24.0	22.2	20.0	16.6	14.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.7	15.2	16.2	17.9	21.0	25.1	26.2	26.9	25.5	23.3	19.9	16.7
		MCDB	17.4	17.9	18.8	20.6	23.9	28.7	29.8	29.8	28.5	26.1	21.8	18.2
	2%	WB	14.7	14.5	15.4	17.1	20.0	23.6	25.4	26.1	24.4	22.4	18.8	15.9
		MCDB	16.6	17.0	18.1	20.0	23.0	27.2	29.0	29.5	27.8	24.9	21.0	17.5
	5%	WB	14.0	13.8	14.8	16.5	19.3	22.7	24.7	25.5	23.7	21.6	18.0	15.2
		MCDB	16.1	16.1	17.5	19.4	22.4	26.4	28.4	29.0	27.2	24.3	20.4	17.0
	10%	WB	13.3	13.1	14.2	15.9	18.6	22.0	24.1	24.9	23.0	20.8	17.0	14.5
		MCDB	15.4	15.4	16.7	18.8	21.8	25.8	27.9	28.4	26.6	23.5	19.7	16.5
Mean Daily Temperature Range	5% DB	MDBR	7.3	7.4	7.6	7.5	7.6	7.7	7.3	7.1	7.1	7.1	6.9	7.1
		MCDBR	7.8	8.0	8.8	8.7	8.7	8.9	8.1	7.8	7.5	7.7	7.5	7.4
		MCWBR	5.6	5.3	5.4	5.0	4.8	5.0	4.3	4.3	4.0	4.5	5.0	5.3
	5% WB	MCDBR	7.0	7.3	7.9	7.9	7.6	7.9	7.2	7.1	7.0	6.9	6.9	6.7
		MCWBR	5.5	5.3	5.3	5.2	4.7	4.8	4.2	4.3	4.2	4.5	5.0	5.2
Clear-Sky Solar Irradiance	taub	0.325	0.346	0.388	0.405	0.429	0.441	0.456	0.452	0.428	0.397	0.358	0.330	
	taud	2.538	2.482	2.363	2.335	2.296	2.296	2.267	2.284	2.352	2.421	2.488	2.530	
	Ebn at Noon	853	878	869	874	855	842	826	819	818	807	803	817	
	Edh at Noon	76	91	113	123	131	131	134	128	113	96	80	72	
All-Sky Solar Radiation	RadAvg	2.36	3.21	4.60	5.79	6.73	7.58	7.39	6.43	4.96	3.58	2.44	2.04	
	RadStd	0.17	0.31	0.35	0.34	0.43	0.26	0.21	0.24	0.28	0.26	0.20	0.13	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
Station Only	N/A	-0.70	N/A	N/A	N/A	N/A	N/A	+78	N/A	N/A	N/A
Regional (3 neighbors)	N/A	N/A	-1.11	N/A	N/A	-0.54	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page