

MURCIA SAN JAVIER AB, SpainWMO: **084330**Lat: **37.789N**Lon: **0.803W**Elev: **11**StdP: **14.69**Time Zone: **1.00 (EUC)**Period: **82-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	35.8	38.9	23.5	17.8	48.4	26.9	20.8	49.3	27.4	52.6	23.5	54.9	5.3	250	0.442

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	13.2	89.9	74.5	87.7	74.6	85.9	74.6	78.5	86.1	77.4	84.6	76.4	83.4	11.1	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
76.1	136.6	83.8	75.1	131.8	82.9	73.9	126.2	81.8	41.9	86.5	40.8	84.8	39.8	83.4	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	25.2	22.0	19.0	DB	30.8	96.3	3.0	2.9	28.7	98.4	26.9	100.1	25.3	101.8	23.1	103.9
(5)				WB	28.7	80.3	2.7	1.4	26.8	81.3	25.2	82.1	23.6	82.9	21.6	84.0

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	64.6	52.3	53.7	56.5	60.4	65.0	72.5	78.0	78.7	75.0	67.9	59.5	54.4
	DBStd	10.24	4.94	5.26	4.42	3.62	3.98	3.85	3.04	3.35	3.15	4.47	5.31	4.16
	HDD50	70	30	23	4	0	0	0	0	0	0	0	2	11
	HDD65	1704	394	319	266	144	50	1	0	0	0	24	176	330
	CDD50	5381	101	125	205	311	466	675	868	891	750	555	288	146
	CDD65	1541	0	1	2	6	51	226	403	426	300	114	12	0
	CDH74	12363	2	3	28	24	182	1401	3851	4161	2160	495	54	2
	CDH80	3178	0	0	3	1	9	300	1125	1255	437	40	8	0
Wind	WSAvg	8.9	8.1	9.5	9.9	10.4	9.7	9.6	8.8	9.2	8.8	7.8	8.0	7.5
Precipitation	PrecAvg	11.0	1.3	0.9	1.0	1.1	0.8	0.3	0.0	0.2	1.5	1.2	1.4	1.4
	PrecMax	17.4	6.3	6.1	3.1	5.3	2.5	2.1	0.5	1.5	6.5	5.0	4.8	8.5
	PrecMin	4.6	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.1	0.0	0.2	0.0
	PrecStd	3.0	1.5	1.3	0.8	1.1	0.7	0.6	0.1	0.4	1.5	1.2	1.2	1.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	71.1	73.7	77.5	76.9	81.3	89.4	94.0	94.0	89.8	83.8	80.0	71.1
		MCWB	56.5	59.5	60.7	62.2	65.9	71.2	73.3	76.2	72.1	68.8	64.0	57.1
	2%	DB	67.5	68.5	72.8	73.6	78.4	85.9	89.7	90.1	86.4	80.7	74.4	67.3
		MCWB	55.7	55.9	59.6	59.9	65.0	71.0	74.1	76.1	72.9	69.5	62.9	57.1
	5%	DB	64.4	65.7	69.3	70.9	75.9	83.2	87.5	87.9	84.4	78.8	71.3	64.8
		MCWB	53.8	55.2	57.9	59.1	64.1	70.2	74.7	76.1	72.7	69.3	61.2	56.8
	10%	DB	61.7	62.7	66.3	68.3	73.5	80.9	85.6	86.0	82.4	76.9	68.5	62.8
		MCWB	53.0	54.3	56.0	58.3	63.8	69.4	75.0	75.6	72.6	68.2	60.9	56.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	60.3	60.8	63.8	64.8	69.1	75.7	79.2	80.3	77.5	73.5	67.8	61.8
		MCDB	66.7	68.9	73.1	71.5	77.3	84.4	86.7	88.5	85.0	79.0	75.7	64.8
	2%	WB	58.0	58.3	60.8	62.9	67.4	73.8	78.0	79.1	76.1	71.9	65.5	60.1
		MCDB	63.6	65.4	69.3	69.1	75.0	82.0	85.8	86.9	83.2	77.9	70.7	64.0
	5%	WB	56.2	56.9	59.2	61.6	66.3	72.5	77.0	78.0	75.0	70.8	64.1	58.8
		MCDB	61.3	63.2	67.2	67.7	73.2	80.0	84.5	85.2	81.7	76.9	69.2	63.4
	10%	WB	54.5	55.5	57.5	60.3	65.2	71.3	76.0	77.0	74.1	69.3	62.5	57.4
		MCDB	59.8	60.9	63.9	66.4	71.6	78.3	83.4	83.8	80.4	75.3	67.5	61.8
Mean Daily Temperature Range	5% DB	MDBR	18.7	17.0	17.3	16.0	15.2	14.0	13.8	13.2	14.5	15.8	16.7	17.9
		MCDBR	21.3	20.9	23.2	20.7	18.5	18.4	17.6	15.8	17.5	18.0	19.7	20.2
		MCWBR	12.7	12.8	13.9	11.9	10.4	9.7	9.7	8.7	9.4	10.2	12.0	12.8
	5% WB	MCDBR	18.9	18.6	20.7	16.9	15.1	14.9	14.6	14.0	14.7	16.0	15.6	18.0
		MCWBR	13.4	12.8	13.7	10.8	9.6	8.9	9.2	8.6	9.1	9.6	10.4	12.5
Clear-Sky Solar Irradiance	taub	0.317	0.342	0.389	0.401	0.428	0.450	0.463	0.463	0.431	0.396	0.351	0.324	
	taud	2.506	2.456	2.322	2.314	2.266	2.223	2.197	2.202	2.301	2.391	2.480	2.507	
	Ebn at Noon	276	281	276	279	272	265	260	257	259	258	260	264	
	Edh at Noon	25	30	37	40	43	45	46	44	38	32	26	24	
All-Sky Solar Radiation	RadAvg	811	1079	1459	1808	2132	2385	2347	2052	1609	1186	843	703	
	RadStd	73	103	111	117	147	77	52	71	81	88	73	54	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (5 neighbors)	N/A	N/A	-2.34	+0.92	N/A	N/A	N/A	N/A	N/A	+104