

BEJA AB, Portugal

WMO: 085610

Lat: 38.0786N

Lon: 7.9267W

Elev: 203

StdP: 98.91

Time Zone: 0.00 (EUW)

Period: 06-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	1.9	3.0	-3.8	2.8	9.3	-1.6	3.4	10.2	11.0	13.0	10.1	11.5	2.5	100	0.495

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	15.7	36.7	20.4	35.0	19.8	33.3	19.3	22.5	33.2	21.6	31.6	20.7	29.8	4.1	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.2	14.3	24.8	18.5	13.7	24.0	17.8	13.1	23.4	66.8	33.4	63.5	31.6	60.5	29.9	26.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
9.7	8.6	7.8	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
			-0.4	40.1	1.3	1.8	-1.3	41.4	-2.1	42.5	-2.8	43.5	-3.7	44.8		
			-1.2	23.8	1.2	1.5	-2.0	24.8	-2.7	25.7	-3.4	26.5	-4.3	27.6		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	16.8	9.9	10.5	12.6	14.7	18.3	21.8	23.9	24.6	22.2	18.9	13.4	10.7
	DBStd	5.92	2.38	2.41	2.37	2.78	3.38	3.42	2.65	2.60	2.66	2.94	2.71	2.50
	HDD10.0	83	31	22	4	1	0	0	0	0	0	0	4	22
	HDD18.3	1234	262	219	177	112	43	6	0	0	1	28	148	236
	CDD10.0	2578	27	36	86	143	257	356	432	451	366	275	107	44
	CDD18.3	687	0	0	0	4	42	112	174	193	117	44	1	0
	CDH23.3	7776	0	0	7	71	554	1326	2060	2272	1137	348	2	0
	CDH26.7	3664	0	0	0	6	199	630	1057	1196	479	97	0	0
Wind	WSAvg	3.9	3.6	4.0	4.2	4.1	4.1	4.1	4.5	4.1	3.6	3.6	3.8	3.6
Precipitation	PrecAvg	583	80	69	51	58	43	21	2	3	25	66	76	88
	PrecMax	1042	275	164	143	152	149	84	19	38	118	214	283	279
	PrecMin	355	0	3	0	4	0	0	0	0	1	0	2	4
	PrecStd	156	64	52	38	38	37	22	4	8	27	54	59	72
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.7	19.3	24.3	27.7	33.8	38.4	38.9	38.7	36.4	31.9	23.2	19.2
		MCWB	13.1	12.8	14.8	17.5	18.6	19.1	21.4	21.1	20.1	17.1	16.2	13.9
	2%	DB	16.1	17.6	22.2	25.4	31.4	35.2	36.5	36.5	33.7	29.3	21.2	17.3
		MCWB	12.6	12.3	13.7	17.1	18.0	19.7	20.1	20.7	18.7	17.3	15.3	14.4
	5%	DB	15.0	16.3	20.3	23.5	28.8	32.8	34.5	34.8	31.7	27.1	19.5	16.1
		MCWB	12.3	12.3	13.6	16.0	17.5	19.2	19.8	20.0	18.5	17.2	15.1	13.5
	10%	DB	14.1	15.2	18.2	21.4	26.5	30.4	32.5	32.9	29.4	24.9	18.1	15.0
		MCWB	11.9	12.1	12.6	14.9	16.6	18.7	19.6	19.4	18.3	17.1	14.7	12.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.1	15.2	16.9	19.3	21.3	23.0	24.1	23.6	22.5	20.2	18.7	16.3
		MCDB	16.2	16.9	22.4	25.3	30.3	34.6	36.2	36.1	33.0	24.6	20.3	17.4
	2%	WB	14.0	14.4	15.5	17.8	19.5	21.5	22.5	22.2	21.1	19.4	17.4	15.0
		MCDB	14.9	15.8	19.7	24.2	27.5	31.2	33.0	33.2	28.7	23.8	19.0	16.4
	5%	WB	13.2	13.5	14.6	16.5	18.4	20.2	21.4	21.4	20.1	18.8	16.2	14.1
		MCDB	14.3	15.3	18.0	21.9	25.9	29.0	31.1	31.8	27.2	23.3	18.1	15.4
	10%	WB	12.4	12.6	13.6	15.4	17.3	19.4	20.3	20.6	19.3	18.1	15.4	13.3
		MCDB	13.6	14.6	16.7	20.1	24.4	28.0	29.4	30.2	25.9	22.5	17.5	14.7
Mean Daily Temperature Range	5% DB	MDBR	8.2	8.8	9.9	10.3	12.5	13.8	15.6	15.7	13.0	10.7	8.7	8.3
		MCDBR	9.4	10.4	13.7	14.2	17.0	17.8	18.8	18.3	16.7	14.3	10.5	8.8
		MCWBR	6.0	6.1	6.8	6.6	6.0	5.4	5.8	5.7	5.1	5.0	5.4	5.5
	5% WB	MCDBR	6.8	8.1	10.8	12.9	14.6	15.7	16.7	16.2	12.9	10.4	7.3	7.1
		MCWBR	5.1	5.5	6.4	6.6	6.4	6.2	6.8	6.4	5.1	4.7	4.6	5.2
Clear-Sky Solar Irradiance	taub	0.315	0.331	0.363	0.370	0.377	0.381	0.360	0.378	0.375	0.353	0.328	0.317	
	taud	2.496	2.449	2.365	2.358	2.363	2.368	2.400	2.362	2.393	2.481	2.509	2.504	
	Ebn at Noon	869	897	897	909	903	896	912	889	873	861	845	839	
	Edh at Noon	79	94	113	121	122	122	117	119	109	91	78	74	
All-Sky Solar Radiation	RadAvg	2.40	3.34	4.47	5.61	6.75	7.62	7.89	7.00	5.40	3.75	2.65	2.14	
	RadStd	0.30	0.40	0.47	0.48	0.56	0.40	0.22	0.22	0.34	0.32	0.30	0.24	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (15 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page