

BEJA, Portugal

WMO: 085620

Lat: 38.0259N

Lon: 7.8676W

Elev: 810

StdP: 14.27

Time Zone: 0.00 (EUW)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	36.2	38.4	23.9	18.7	47.9	28.0	22.6	49.0	23.3	54.3	20.9	54.2	6.0	290	0.460

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	29.0	99.6	68.1	96.3	67.4	93.0	66.4	71.1	90.7	69.8	88.7	68.6	86.5	6.9	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.2	99.6	73.0	65.0	95.4	71.8	63.8	91.3	70.9	35.3	90.8	34.1	88.6	33.2	86.6	77.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
19.8	17.2	15.3	DB	32.2	105.5	2.4	3.3	30.4	107.9	29.0	109.9	27.6	111.8	25.8	114.2	78.5
			WB	29.7	73.5	2.7	1.9	27.8	74.9	26.2	76.0	24.7	77.1	22.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	62.6	50.1	51.3	55.6	58.6	64.9	72.2	75.7	76.5	72.0	65.7	56.2	51.5
	DBStd	10.85	4.33	4.32	4.94	5.63	6.71	6.42	5.34	5.24	5.04	5.49	5.12	4.44
	HDD50	140	52	34	9	2	0	0	0	0	0	0	8	35
	HDD65	2188	463	384	293	206	87	10	0	0	3	56	267	419
	CDD50	4736	54	70	182	261	461	667	796	822	661	488	193	81
	CDD65	1308	0	0	1	14	83	227	331	357	214	79	2	0
	CDH74	14975	0	0	29	184	1050	2828	4118	4158	2045	559	4	0
	CDH80	7435	0	0	1	28	407	1434	2258	2257	887	163	0	0
Wind	WSAvg	7.4	7.1	7.5	7.7	7.9	7.7	7.6	8.3	7.8	7.0	6.8	6.9	6.9
Precipitation	PrecAvg	23.0	3.1	2.7	2.0	2.3	1.7	0.8	0.1	0.1	1.0	2.6	3.0	3.5
	PrecMax	41.0	10.8	6.5	5.6	6.0	5.9	3.3	0.7	1.5	4.6	8.4	11.1	11.0
	PrecMin	14.0	0.0	0.1	0.0	0.2	0.0	0.0	0.0	0.0	0.0	0.1	0.2	0.2
	PrecStd	6.1	2.5	2.0	1.5	1.5	1.5	0.9	0.2	0.3	1.1	2.1	2.3	2.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	64.4	67.8	77.4	83.5	93.9	101.6	103.6	103.2	97.5	89.9	73.8	66.0
		MCWB	55.3	56.8	59.1	62.1	65.4	67.7	68.4	69.8	67.0	63.2	61.0	57.0
	2%	DB	61.1	64.4	73.6	79.5	89.1	96.9	99.5	99.0	92.6	84.6	69.9	62.6
		MCWB	54.7	55.2	57.9	61.8	64.1	67.2	67.9	68.4	65.5	62.8	60.0	57.8
	5%	DB	59.1	61.9	69.8	75.2	84.6	93.0	95.8	95.7	89.1	80.0	67.1	60.7
		MCWB	54.5	54.1	57.3	59.7	62.9	66.5	67.1	67.7	65.0	62.6	59.0	56.6
	10%	DB	57.3	59.4	65.9	70.9	80.0	88.6	92.0	91.7	85.3	76.0	64.4	58.9
		MCWB	53.6	53.5	56.0	58.3	61.9	65.3	66.6	66.5	64.8	62.0	58.5	55.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	59.3	60.0	63.2	66.2	69.6	71.6	72.3	73.4	70.8	68.8	65.3	61.0
		MCDB	61.2	63.5	71.4	78.5	86.6	93.0	93.2	94.1	87.2	76.4	69.1	62.5
	2%	WB	57.4	58.0	60.4	63.3	66.9	69.5	70.7	71.1	69.1	66.9	63.2	59.3
		MCDB	59.1	61.4	68.3	74.9	82.2	90.3	91.3	90.9	83.7	74.6	66.3	61.0
	5%	WB	55.9	56.3	58.6	61.1	64.9	68.0	69.2	69.7	67.8	65.5	61.4	57.6
		MCDB	57.8	59.7	66.0	71.9	78.6	87.5	89.7	88.8	80.7	72.8	64.5	59.7
	10%	WB	54.3	54.7	57.0	59.3	63.0	66.6	67.9	68.4	66.5	64.3	59.7	55.9
		MCDB	56.5	58.1	63.8	68.7	76.5	84.9	88.1	86.5	78.6	71.2	63.0	58.1
Mean Daily Temperature Range	5% DB	MDBR	13.7	15.9	18.3	20.0	23.3	27.7	30.2	29.0	23.8	18.2	14.6	13.5
		MCDBR	14.8	18.7	23.9	26.1	30.5	33.9	34.9	32.9	29.5	24.2	17.0	14.2
		MCWBR	9.8	11.3	11.9	11.7	11.4	10.7	10.6	10.3	9.8	9.2	8.8	9.2
	5% WB	MCDBR	11.6	15.3	19.7	23.0	26.6	30.7	31.7	29.6	23.5	17.5	12.8	11.6
MCWBR		9.1	10.5	11.5	11.9	11.7	11.3	11.1	10.6	9.3	8.6	8.3	8.7	
Clear-Sky Solar Irradiance	taub	0.313	0.329	0.361	0.367	0.374	0.378	0.357	0.375	0.372	0.351	0.326	0.315	
	taud	2.500	2.453	2.370	2.366	2.370	2.374	2.406	2.368	2.400	2.484	2.512	2.507	
	Ebn at Noon	277	285	285	289	287	285	290	283	278	274	269	267	
	Edh at Noon	25	30	36	38	39	38	37	37	34	29	25	23	
All-Sky Solar Radiation	RadAvg	764	1062	1422	1783	2143	2421	2507	2222	1714	1191	843	682	
	RadStd	96	127	149	152	179	125	68	70	109	99	96	76	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (14 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page