

MINDELO CESARIA EVORA AP, Cape Verde

WMO: 085830

Lat: 16.834N

Lon: 25.055W

Elev: 18

StdP: 101.11

Time Zone: -1.00 (W01)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	18.6	19.0	10.4	7.9	22.7	11.3	8.4	22.4	17.7	23.2	16.9	23.3	5.9	60	0.721

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	5.2	31.8	24.2	31.1	24.3	30.5	24.0	25.7	29.0	25.4	28.9	25.1	28.7	8.0	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.9	20.0	27.2	24.2	19.2	27.5	24.0	18.9	27.6	79.3	29.1	77.9	29.0	76.5	28.9	27.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.8	14.5	13.6	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			13.7	25.9	1.0	1.1	12.9	26.7	12.3	27.3	11.8	27.9	11.0	28.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	25.0	22.8	22.1	22.5	23.5	24.4	25.3	26.4	27.6	28.1	27.7	25.7	24.0		
	DBStd	2.24	1.24	1.25	0.81	0.98	0.97	0.82	0.84	0.96	0.74	0.95	1.19	1.21		
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDD10.0	5487	397	339	388	406	447	458	509	544	543	547	472	435		
	CDD18.3	2445	139	106	130	156	188	208	251	286	293	289	222	177		
	CDH23.3	17259	373	227	354	636	974	1301	2054	2883	3174	2934	1599	749		
	CDH26.7	3838	31	13	9	42	104	189	441	822	991	854	266	76		
(14) Wind	WSAvg	8.3	9.0	9.6	9.6	9.3	9.5	9.2	6.9	6.0	7.0	7.8	7.5	8.1		
(15) Precipitation	PrecAvg	201	10	11	5	4	2	3	13	25	54	32	23	20		
	PrecMax	418	64	64	39	25	8	8	66	76	174	149	132	139		
	PrecMin	98	1	0	0	0	0	0	2	4	2	2	1	1		
	PrecStd	84	14	12	7	5	2	2	14	19	45	28	30	29		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	29.1	28.8	27.9	29.1	29.9	30.1	31.2	32.1	32.2	32.9	31.0	29.2		
		MCWB	19.2	18.0	18.7	20.4	19.7	22.1	23.0	23.9	24.9	23.5	23.1	22.1		
	2%	DB	27.1	26.2	26.7	27.8	28.6	29.0	30.1	31.1	31.8	31.5	29.9	28.2		
		MCWB	20.0	19.1	19.0	20.6	21.0	22.0	22.9	24.6	24.8	24.1	23.2	21.4		
	5%	DB	26.1	25.5	26.0	26.9	27.9	28.2	29.5	30.6	31.0	30.9	29.0	27.2		
		MCWB	19.5	18.8	18.9	20.5	20.9	21.6	22.7	24.3	24.6	24.2	22.6	20.8		
	10%	DB	25.2	24.8	25.1	26.1	27.1	27.8	28.9	30.0	30.4	30.1	28.1	26.7		
		MCWB	18.9	18.5	18.7	19.8	20.5	21.5	22.5	23.9	24.5	23.9	22.1	20.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.4	20.8	21.4	21.8	22.5	23.4	24.6	26.2	26.2	26.1	24.6	23.4		
		MCDB	25.8	24.9	23.9	26.4	27.8	27.9	29.0	29.3	29.3	29.1	28.0	28.0		
	2%	WB	20.8	20.2	20.3	21.2	21.9	22.7	24.0	25.7	25.8	25.3	24.0	22.5		
		MCDB	24.8	24.4	23.7	25.9	27.0	27.1	28.3	29.0	29.0	29.3	27.9	26.7		
	5%	WB	20.3	19.6	19.9	20.9	21.4	22.3	23.5	25.2	25.6	24.8	23.5	21.9		
		MCDB	24.3	24.0	23.6	25.5	26.2	27.0	27.9	28.8	28.9	29.2	27.4	25.8		
	10%	WB	19.7	19.1	19.5	20.5	21.0	21.9	23.1	24.8	25.2	24.4	23.0	21.1		
		MCDB	24.0	23.7	23.7	25.0	25.7	26.9	27.4	28.5	28.6	28.8	26.9	25.2		
(35) Mean Daily Temperature Range	5% DB	MDBR	5.2	5.3	5.8	5.5	5.5	5.3	5.2	5.2	5.2	5.4	5.2	5.2		
		MCDBR	6.3	6.1	6.7	6.4	6.4	5.8	5.9	5.6	5.8	6.1	5.9	6.1		
	5% WB	MCWBR	2.7	2.6	2.6	2.5	2.5	2.3	2.1	2.1	1.9	2.4	2.2	2.4		
		MCWBR	6.0	6.0	6.3	6.1	5.6	5.6	5.5	5.2	5.1	5.6	5.5	6.1		
(40) Clear-Sky Solar Irradiance	taub	taub	0.443	0.446	0.468	0.462	0.544	0.645	0.664	0.619	0.578	0.523	0.448	0.447		
		taud	2.179	2.176	2.126	2.222	1.969	1.774	1.762	1.881	1.969	2.071	2.272	2.235		
	Ebn at Noon	Ebn at Noon	838	858	849	852	774	692	681	718	748	778	830	823		
		Edh at Noon	141	148	161	146	186	224	227	203	185	163	128	131		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	4.93	5.59	6.56	6.84	6.93	6.62	6.22	6.18	6.05	5.62	4.95	4.52		
	RadStd	RadStd	0.37	0.38	0.31	0.21	0.18	0.18	0.21	0.17	0.30	0.25	0.34	0.39		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page