

SAL AMILCAR CABRAL INTL, Cape VerdeWMO: **085940**Lat: **16.742N**Lon: **22.949W**Elev: **183**StdP: **14.60**Time Zone: **-1.00 (W01)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	64.2	64.7	51.9	57.6	69.7	53.5	61.4	69.8	27.9	73.8	26.9	74.3	12.3	40	0.552

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	9.4	88.2	76.6	87.5	76.5	86.1	75.9	79.1	84.1	78.4	83.4	77.8	83.0	13.7	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
77.4	143.5	81.4	77.0	141.6	81.3	75.9	136.5	81.1	42.7	84.1	41.9	84.1	41.4	82.6	83.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 25.3	23.4	22.0	DB	61.2	91.5	3.8	2.0	58.5	92.9	56.3	94.0	54.2	95.1	51.4	96.6	(4)
(5)			WB	56.0	81.0	2.4	1.2	54.3	81.9	52.9	82.6	51.6	83.3	49.9	84.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	76.1	72.1	71.4	72.0	73.0	74.3	76.0	78.3	80.8	81.7	80.8	77.9	74.6	(6)	
	DBStd	4.06	2.08	2.37	2.20	1.80	1.86	1.60	1.58	1.79	1.69	1.97	2.15	1.92	(7)	
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)	
	CDD50	9525	686	598	681	690	753	781	877	954	952	953	837	763	(10)	
	CDD65	4051	221	178	217	240	288	331	412	489	502	488	387	298	(11)	
	CDH74	24576	492	369	552	634	972	1468	2664	4443	5028	4424	2469	1061	(12)	
(13)	CDH80	4699	20	21	47	37	69	129	404	1043	1341	1097	414	77	(13)	
(14)	Wind	WSAvg	13.8	15.1	15.7	15.1	15.4	15.8	14.8	12.0	11.1	12.0	12.6	12.8	13.6	(14)
(15) Precipitation	PrecAvg	3.2	0.2	0.0	0.0	0.0	0.0	0.0	0.1	0.5	2.0	0.6	0.1	0.1	(15)	
	PrecMax	9.1	1.5	0.2	0.4	0.4	0.5	0.0	1.4	3.4	15.3	3.3	0.9	1.5	(16)	
	PrecMin	0.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	(17)	
	PrecStd	2.1	0.3	0.0	0.1	0.1	0.1	0.0	0.3	0.7	3.2	0.8	0.2	0.3	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	82.3	82.6	84.2	83.9	84.5	84.6	87.4	89.7	89.9	91.0	88.1	84.2	(19)	
		MCWB	68.6	66.9	66.0	69.3	69.4	72.7	75.2	77.5	77.8	76.2	74.1	70.3	(20)	
	2%	DB	79.8	80.2	80.8	80.6	81.8	82.6	84.7	87.8	88.2	88.1	85.8	82.2	(21)	
		MCWB	67.9	67.1	67.3	69.4	70.6	71.9	74.2	76.9	77.6	76.4	74.0	70.2	(22)	
	5%	DB	78.5	78.0	78.8	78.9	80.3	81.0	83.8	86.2	87.4	86.4	84.0	80.5	(23)	
		MCWB	67.4	67.1	67.6	68.6	70.1	71.3	73.7	76.4	77.5	75.9	73.2	69.9	(24)	
	10%	DB	76.8	76.2	77.0	77.3	78.8	80.4	82.3	84.6	86.0	85.3	82.4	79.0	(25)	
		MCWB	66.8	66.4	66.9	67.6	69.2	71.1	72.8	75.5	76.9	75.5	72.6	69.1	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	71.3	71.6	70.9	71.8	72.7	74.7	77.4	79.5	80.3	79.5	77.4	74.5	(27)	
		MCDB	77.7	77.2	77.6	79.4	80.2	81.1	83.0	84.8	85.7	85.3	83.1	79.5	(28)	
	2%	WB	69.9	69.7	69.7	70.2	71.6	73.4	76.0	78.6	79.2	78.3	76.0	72.8	(29)	
		MCDB	76.1	75.3	76.6	77.3	78.7	79.7	81.8	83.8	84.1	84.0	81.7	78.2	(30)	
	5%	WB	68.9	68.5	68.7	69.4	70.7	72.5	75.0	77.9	78.8	77.5	75.0	71.8	(31)	
		MCDB	75.1	74.7	75.5	76.4	77.5	78.8	80.8	83.2	83.5	83.2	80.7	77.3	(32)	
	10%	WB	67.9	67.5	67.8	68.6	69.9	71.7	74.1	77.2	78.2	76.6	74.1	70.7	(33)	
		MCDB	74.3	74.0	74.4	75.3	76.5	78.1	80.0	82.4	83.0	82.4	79.9	76.5	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	9.7	10.1	10.9	10.0	9.6	9.4	9.0	9.4	9.4	9.8	9.6	9.7	(35)	
		MCDBR	11.5	11.9	13.2	11.4	10.9	10.2	10.4	10.6	10.7	11.2	11.1	11.4	(36)	
	5% WB	MCWBR	4.8	4.8	4.9	4.6	4.1	4.0	4.0	4.0	4.0	4.1	4.4	5.0	(37)	
		MCWBR	10.6	10.7	12.0	11.1	10.1	10.0	9.7	9.8	9.6	10.2	10.6	10.1	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.475	0.476	0.509	0.488	0.578	0.683	0.695	0.645	0.607	0.550	0.464	0.464	(40)	
		taud	2.059	2.063	1.992	2.128	1.877	1.696	1.701	1.823	1.894	1.991	2.197	2.156	(41)	
	Ebn at Noon		256	263	259	264	237	211	209	222	230	239	258	255	(42)	
		Edh at Noon	51	53	58	51	65	77	76	68	63	56	44	45	(43)	
(44) All-Sky Solar Radiation	RadAvg		1564	1755	2060	2133	2135	2025	1898	1921	1899	1770	1566	1431	(44)	
	RadStd		110	119	95	81	68	78	90	60	81	82	101	106	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	+1.26	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page