

SAL AMILCAR CABRAL INTL, Cape VerdeWMO: **085940**Lat: **16.742N**Lon: **22.949W**Elev: **56**StdP: **100.66**Time Zone: **-1.00 (W01)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	17.9	18.2	11.0	8.2	21.0	12.0	8.8	21.0	12.5	23.2	12.0	23.5	5.5	40	0.552

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	5.2	31.2	24.8	30.9	24.7	30.1	24.4	26.1	29.0	25.8	28.6	25.5	28.3	6.1	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.2	20.5	27.4	25.0	20.2	27.4	24.4	19.5	27.3	81.5	28.9	79.7	28.9	78.3	28.1	28.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.3	10.4	9.8	16.2	33.0	2.1	1.1	14.7	33.8	13.5	34.5	12.3	35.1	10.8	35.9		
(5)			13.4	27.2	1.3	0.7	12.4	27.7	11.6	28.1	10.9	28.5	9.9	29.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	24.5	22.3	21.9	22.2	22.8	23.5	24.5	25.7	27.1	27.6	27.1	25.5	23.7
	DBStd	2.25	1.15	1.32	1.22	1.00	1.03	0.89	0.88	1.00	0.94	1.09	1.19	1.07
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	5292	381	332	378	383	418	434	487	530	529	529	465	424
	CDD18.3	2251	123	99	121	133	160	184	229	272	279	271	215	166
	CDH23.3	13653	273	205	307	352	540	816	1480	2468	2793	2458	1372	589
CDH26.7	2611	11	12	26	21	38	72	224	579	745	609	230	43	
Wind	WSAvg	6.2	6.7	7.0	6.7	6.9	7.1	6.6	5.4	4.9	5.4	5.6	5.7	6.1
Precipitation	PrecAvg	81	4	0	0	1	1	0	2	13	52	14	3	2
	PrecMax	230	37	5	9	10	13	1	36	87	388	83	22	38
	PrecMin	18	0	0	0	0	0	0	0	0	1	2	1	0
	PrecStd	53	8	1	2	2	2	0	7	19	82	21	4	7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	27.9	28.1	29.0	28.8	29.2	29.2	30.8	32.1	32.2	32.8	31.2	29.0
		MCWB	20.3	19.4	18.9	20.7	20.8	22.6	24.0	25.3	25.4	24.6	23.4	21.3
	2%	DB	26.5	26.8	27.1	27.0	27.7	28.1	29.3	31.0	31.2	31.2	29.9	27.9
		MCWB	19.9	19.5	19.6	20.8	21.4	22.2	23.4	25.0	25.4	24.6	23.3	21.2
	5%	DB	25.9	25.6	26.0	26.0	26.8	27.2	28.8	30.1	30.8	30.2	28.9	27.0
		MCWB	19.7	19.5	19.8	20.3	21.2	21.9	23.2	24.6	25.3	24.4	22.9	21.0
	10%	DB	24.9	24.5	25.0	25.1	26.0	26.9	28.0	29.2	30.0	29.6	28.0	26.1
		MCWB	19.3	19.1	19.4	19.8	20.7	21.7	22.7	24.2	25.0	24.2	22.6	20.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.8	22.0	21.6	22.1	22.6	23.7	25.2	26.4	26.8	26.4	25.2	23.6
		MCDB	25.4	25.1	25.3	26.3	26.8	27.3	28.4	29.3	29.8	29.6	28.4	26.4
	2%	WB	21.1	20.9	20.9	21.2	22.0	23.0	24.5	25.9	26.2	25.7	24.5	22.7
		MCDB	24.5	24.1	24.8	25.2	26.0	26.5	27.7	28.8	28.9	28.9	27.6	25.7
	5%	WB	20.5	20.3	20.4	20.8	21.5	22.5	23.9	25.5	26.0	25.3	23.9	22.1
		MCDB	23.9	23.7	24.1	24.7	25.3	26.0	27.1	28.4	28.6	28.4	27.1	25.2
	10%	WB	19.9	19.7	19.9	20.3	21.1	22.0	23.4	25.1	25.7	24.8	23.4	21.5
		MCDB	23.5	23.3	23.6	24.0	24.7	25.6	26.7	28.0	28.3	28.0	26.6	24.7
Mean Daily Temperature Range	5% DB	MDBR	5.4	5.6	6.1	5.6	5.3	5.2	5.0	5.2	5.2	5.5	5.3	5.4
		MCDBR	6.4	6.6	7.3	6.3	6.1	5.7	5.8	5.9	5.9	6.2	6.2	6.4
		MCWBR	2.7	2.7	2.7	2.5	2.3	2.2	2.2	2.2	2.2	2.3	2.4	2.8
	5% WB	MCDBR	5.9	5.9	6.7	6.2	5.6	5.5	5.4	5.4	5.3	5.7	5.9	5.6
		MCWBR	2.9	2.7	2.7	2.7	2.5	2.4	2.4	2.3	2.3	2.4	2.5	2.7
Clear-Sky Solar Irradiance	taub	0.475	0.476	0.509	0.488	0.578	0.683	0.695	0.645	0.607	0.550	0.464	0.464	
	taud	2.059	2.063	1.992	2.128	1.877	1.696	1.701	1.823	1.894	1.991	2.197	2.156	
	Ebn at Noon	806	830	815	831	748	666	660	700	725	755	813	805	
	Edh at Noon	160	166	184	161	204	242	241	215	200	176	138	142	
All-Sky Solar Radiation	RadAvg	4.93	5.53	6.50	6.72	6.73	6.38	5.98	6.06	5.99	5.58	4.94	4.51	
	RadStd	0.35	0.38	0.30	0.26	0.21	0.25	0.28	0.19	0.26	0.26	0.32	0.33	