

SCHLESWIG JAGEL, Germany

WMO: 100370

Lat: 54.4569N

Lon: 9.5203E

Elev: 25

StdP: 101.02

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-9.1	-6.8	-11.2	1.4	-7.4	-9.1	1.7	-5.4	15.9	7.9	14.5	7.1	2.8	120	0.634

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.2	28.1	19.2	26.0	18.4	23.9	17.5	20.2	26.1	19.1	24.4	18.1	22.7	4.5	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.0	13.0	22.6	17.0	12.2	21.7	16.1	11.5	20.4	57.6	26.3	54.3	24.4	51.2	22.8	25.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.6	11.0	9.6	-13.0	31.8	3.3	1.8	-15.4	33.1	-17.4	34.1	-19.2	35.2	-21.6	36.5		
(5)			-13.1	22.3	3.2	1.0	-15.4	23.0	-17.3	23.6	-19.1	24.1	-21.5	24.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	9.1	1.3	1.7	4.0	8.0	11.9	15.0	17.6	17.3	14.0	9.8	5.3	2.4
	DBStd	6.79	4.17	4.02	3.51	3.46	3.21	2.93	3.08	2.82	2.68	3.28	3.48	4.25
	HDD10.0	1214	271	233	188	79	17	1	0	0	2	44	144	236
	HDD18.3	3447	529	466	446	309	201	108	53	54	131	264	391	494
	CDD10.0	873	0	0	1	19	76	150	235	228	123	37	3	1
	CDD18.3	64	0	0	0	0	1	8	30	23	2	0	0	0
	CDH23.3	545	0	0	0	3	14	77	253	179	18	1	0	0
	CDH26.7	123	0	0	0	0	2	16	62	41	1	0	0	0
Wind	WSAvg	4.5	5.1	5.2	5.2	4.6	4.4	4.3	4.1	3.8	4.0	4.2	4.4	4.8
Precipitation	PrecAvg	908	81	54	57	48	59	73	90	91	85	89	93	88
	PrecMax	1190	178	146	137	140	131	157	186	248	188	194	277	221
	PrecMin	531	1	9	7	3	5	3	15	3	21	16	19	16
	PrecStd	145	39	28	30	27	30	37	43	50	41	40	52	46
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.8	11.3	16.0	22.5	25.0	29.1	31.1	30.3	25.9	19.9	14.3	11.9
		MCWB	9.2	8.3	10.3	14.3	16.4	19.1	20.0	19.6	18.8	15.8	12.5	10.5
	2%	DB	9.1	9.3	12.5	18.9	22.2	25.6	28.2	27.7	22.8	17.1	12.7	10.3
		MCWB	7.9	7.6	8.7	12.1	15.3	17.9	19.1	19.2	17.1	14.1	11.2	9.2
	5%	DB	7.9	8.1	10.3	16.4	20.2	23.0	26.2	25.2	20.4	15.7	11.3	9.0
		MCWB	6.9	6.8	7.8	11.2	14.1	16.6	18.5	18.4	16.0	13.4	9.8	8.1
	10%	DB	6.8	7.0	9.0	14.1	18.2	20.9	24.0	23.0	18.7	14.5	10.1	7.9
		MCWB	5.9	5.8	7.0	10.1	13.1	15.6	17.6	17.5	15.0	12.6	8.9	7.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.5	9.2	11.2	14.8	18.0	20.8	21.3	21.3	19.3	16.2	13.2	10.8
		MCDB	10.3	10.5	14.5	20.6	23.1	27.2	27.6	26.9	24.2	19.0	14.4	11.9
	2%	WB	7.9	7.7	9.4	13.0	16.2	18.8	20.2	20.0	17.6	14.7	11.5	9.3
		MCDB	8.8	8.8	11.6	17.5	20.8	24.2	26.5	25.4	21.4	16.6	12.7	10.1
	5%	WB	6.8	6.8	8.2	11.6	14.9	17.3	19.2	18.9	16.5	13.7	10.1	8.1
		MCDB	7.6	7.9	10.1	15.6	18.8	21.4	24.8	23.8	19.6	15.4	11.1	8.8
	10%	WB	5.8	5.8	7.1	10.3	13.6	16.1	18.1	17.9	15.6	12.8	9.0	7.0
		MCDB	6.6	6.9	8.5	13.6	17.4	19.9	23.0	22.0	18.2	14.4	9.9	7.7
Mean Daily Temperature Range	5% DB	MDBR	4.5	5.2	6.9	9.0	9.4	9.0	9.2	9.2	8.1	6.6	5.1	4.5
		MCDBR	4.5	5.5	9.4	12.8	13.0	12.8	12.9	12.6	10.6	7.7	5.3	4.4
		MCWBR	4.2	4.4	6.3	7.3	7.2	6.8	5.8	5.9	6.1	5.4	4.5	4.1
	5% WB	MCDBR	4.5	5.2	8.3	11.3	10.8	11.3	11.8	10.8	9.3	6.8	4.9	4.3
		MCWBR	4.3	4.4	6.0	6.8	6.5	6.6	5.8	5.8	5.7	5.2	4.4	4.2
Clear-Sky Solar Irradiance	taub	0.322	0.341	0.368	0.405	0.397	0.394	0.412	0.409	0.385	0.359	0.336	0.311	
	taud	2.287	2.309	2.265	2.212	2.294	2.327	2.296	2.316	2.364	2.397	2.342	2.282	
	Ebn at Noon	612	737	798	817	848	853	829	807	776	709	592	540	
	Edh at Noon	59	80	104	125	121	119	121	112	94	73	56	48	
All-Sky Solar Radiation	RadAvg	0.51	1.16	2.44	4.08	5.17	5.36	5.05	4.10	2.93	1.57	0.64	0.37	
	RadStd	0.07	0.17	0.22	0.45	0.51	0.44	0.60	0.32	0.32	0.18	0.08	0.03	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	+0.43	N/A	N/A	N/A	N/A	N/A	N/A	-193	N/A	N/A
(47)	Regional (50 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	-143	N/A	N/A

Nomenclature: See separate page