

HOHN, Germany

WMO: 100380

Lat: 54.316N

Lon: 9.539E

Elev: 59

StdP: 14.66

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	15.6	19.5	11.2	9.8	18.6	15.4	12.0	21.9	30.8	43.7	27.3	42.5	5.7	110	0.595

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.7	82.9	66.4	79.0	65.0	75.4	63.4	68.4	79.4	66.5	76.2	64.7	73.2	8.1	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.5	91.0	72.5	62.7	85.4	70.7	61.0	80.4	68.4	32.6	80.2	31.1	76.0	29.7	73.3	75.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.0	20.9	18.4	8.7	89.5	5.7	3.3	4.6	91.9	1.2	93.8	-2.0	95.7	-6.1	98.1
			8.3	72.3	5.6	1.8	4.3	73.6	1.0	74.6	-2.1	75.6	-6.2	76.9
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	48.3	34.5	35.4	39.4	46.7	53.4	58.8	63.4	63.1	57.1	49.6	41.6	36.3
	DBStd	12.11	7.70	7.24	6.39	6.34	5.95	5.34	5.48	4.98	4.89	6.07	6.32	7.78
	HDD50	2160	482	410	332	137	32	1	0	0	3	82	257	424
	HDD65	6189	947	829	794	548	363	201	101	99	241	477	701	888
	CDD50	1555	0	0	2	39	137	264	414	405	217	70	6	1
	CDD65	109	0	0	0	0	3	14	49	39	4	0	0	0
	CDH74	1095	0	0	0	7	35	157	503	354	38	1	0	0
	CDH80	268	0	0	0	0	4	32	138	91	3	0	0	0
Wind	WSAvg	8.5	9.7	9.8	10.1	9.0	8.6	8.3	7.8	7.0	7.2	7.7	8.1	9.0
Precipitation	PrecAvg	33.5	2.9	2.2	2.0	1.7	2.2	2.8	3.7	3.4	3.1	3.1	3.1	3.2
	PrecMax	42.4	6.1	5.7	4.5	4.4	4.0	5.6	7.0	8.5	6.7	7.3	7.2	7.6
	PrecMin	22.4	0.0	0.3	0.3	0.2	0.6	0.0	1.3	1.1	0.7	1.0	0.7	1.1
	PrecStd	4.8	1.6	1.1	1.1	0.9	0.9	1.3	1.7	1.7	1.5	1.3	1.7	1.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.6	53.1	61.2	73.8	78.2	84.4	89.3	87.5	78.8	68.0	58.0	53.8
		MCWB	48.6	47.0	50.8	58.5	62.6	66.8	68.1	67.2	65.4	59.9	54.7	51.0
	2%	DB	48.5	49.6	55.4	67.2	73.3	78.6	83.9	82.5	73.5	63.0	55.1	51.3
		MCWB	46.4	45.7	48.1	54.3	59.9	64.5	66.8	66.3	62.9	57.6	52.4	48.9
	5%	DB	46.4	46.8	51.5	62.7	69.4	73.8	79.6	77.7	69.4	60.5	52.4	48.3
		MCWB	44.6	44.2	46.5	52.6	58.1	62.4	65.6	64.9	60.8	56.0	49.7	46.5
	10%	DB	44.4	44.9	48.5	58.1	65.7	69.8	75.4	73.6	65.9	58.4	50.3	46.4
		MCWB	42.8	42.6	44.6	50.5	56.1	60.3	63.9	63.2	59.1	54.7	48.0	44.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.5	48.5	52.4	59.0	64.6	69.8	70.7	70.2	66.8	61.1	55.7	52.0
		MCDB	51.0	51.3	58.6	71.1	73.7	80.0	82.3	80.9	75.9	66.4	57.9	53.9
	2%	WB	46.5	46.0	49.4	55.7	61.5	66.3	68.8	67.6	63.8	58.4	52.7	49.1
		MCDB	48.1	48.2	53.6	64.5	70.0	75.9	80.6	77.3	70.7	62.3	55.0	50.6
	5%	WB	44.6	44.5	47.2	53.3	59.0	63.5	66.9	65.7	61.7	56.6	50.4	46.7
		MCDB	45.9	46.5	50.9	60.8	66.8	71.5	77.2	74.9	67.6	59.9	52.1	48.0
	10%	WB	42.6	42.7	44.9	51.0	56.9	61.2	64.8	64.1	60.0	55.0	48.3	44.6
		MCDB	44.0	44.7	47.7	57.6	64.2	68.0	73.5	72.2	64.8	58.0	50.0	45.9
Mean Daily Temperature Range	5% DB	MDBR	8.1	9.7	12.8	17.0	18.2	17.1	17.7	17.5	15.3	12.6	9.4	8.0
		MCDBR	8.3	11.2	17.8	24.6	25.1	24.7	25.4	24.5	20.6	14.8	9.7	8.0
		MCWBR	7.6	8.7	12.0	14.1	14.3	13.7	11.9	12.0	11.9	10.3	8.2	7.6
	5% WB	MCDBR	7.8	9.7	15.7	21.3	21.4	21.7	23.0	20.9	17.5	12.9	9.1	7.9
		MCWBR	7.5	8.1	11.3	13.1	13.1	13.1	11.8	11.5	10.9	9.7	8.2	7.7
Clear-Sky Solar Irradiance	taub	0.321	0.340	0.368	0.407	0.399	0.397	0.414	0.410	0.386	0.359	0.336	0.311	
	taud	2.295	2.313	2.266	2.207	2.284	2.316	2.285	2.307	2.357	2.399	2.347	2.290	
	Ebn at Noon	196	235	253	259	268	270	262	255	246	226	189	173	
	Edh at Noon	19	25	33	40	39	38	39	36	30	23	18	16	
All-Sky Solar Radiation	RadAvg	166	371	773	1292	1634	1696	1600	1304	933	504	207	121	
	RadStd	21	54	71	146	165	139	193	100	104	57	24	9	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	+0.92	N/A	N/A	N/A	N/A
(47) Regional (49 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	-257	N/A	N/A

Nomenclature: See separate page