

DOERNICK, Germany

WMO: 101500

Lat: 54.1656N

Lon: 10.3519E

Elev: 28

StdP: 100.99

Time Zone: 1.00 (EUC)

Period: 01-13

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-9.7	-6.7	-11.7	1.4	-8.4	-9.2	1.7	-5.7	12.8	6.5	11.3	6.2	2.0	140	0.570

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.2	27.0	19.3	25.1	18.7	23.4	17.8	20.4	25.1	19.5	23.6	18.6	22.2	3.2	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.8	13.7	21.9	17.9	12.9	21.1	17.2	12.3	20.4	58.8	25.1	55.5	23.8	52.8	22.2	23.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.7	8.4	7.5	-13.5	30.8	5.7	1.6	-17.6	32.0	-21.0	33.0	-24.2	33.9	-28.4	35.1		
(5)			-13.7	22.5	5.7	0.7	-17.8	23.0	-21.2	23.5	-24.4	23.9	-28.5	24.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	8.9	1.2	1.0	3.5	8.2	11.8	14.8	17.5	17.2	14.2	9.6	5.7	1.8
	DBStd	6.88	4.60	3.95	4.06	3.36	3.04	2.83	2.74	2.51	2.70	3.32	3.36	4.10
	HDD10.0	1257	274	251	203	74	16	1	0	0	1	48	133	256
	HDD18.3	3493	532	484	461	304	204	113	51	52	127	270	381	514
	CDD10.0	858	0	1	1	19	71	144	232	223	127	36	3	0
	CDD18.3	51	0	0	0	0	1	6	24	18	3	0	0	0
	CDH23.3	389	0	0	0	0	8	46	217	103	16	1	0	0
	CDH26.7	63	0	0	0	0	1	3	43	16	1	0	0	0
Wind	WSAvg	3.6	4.5	4.2	4.0	3.5	3.2	3.3	3.0	3.0	3.2	3.4	3.8	4.0
Precipitation	PrecAvg	765	68	54	47	40	54	71	80	77	66	62	70	75
	PrecMax	1006	155	145	123	87	139	168	205	169	143	178	169	187
	PrecMin	526	0	5	6	4	10	2	18	27	25	22	14	26
	PrecStd	121	38	29	28	20	27	37	43	40	32	29	41	44
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.7	11.6	15.1	21.3	24.1	27.0	30.3	28.7	25.2	19.1	14.1	11.1
		MCWB	10.1	9.9	10.4	13.9	16.9	19.2	20.3	19.8	18.3	16.4	12.1	9.6
	2%	DB	9.6	9.7	12.8	18.6	21.8	24.7	27.7	26.3	22.9	17.0	12.4	9.4
		MCWB	8.4	8.6	9.0	12.6	15.3	18.3	19.4	19.4	17.6	14.7	11.1	8.3
	5%	DB	8.4	8.0	10.9	16.5	19.7	22.4	25.9	24.1	21.0	15.4	11.2	8.1
		MCWB	7.3	6.9	8.8	11.3	14.4	17.1	19.0	18.3	16.7	13.7	10.1	7.2
	10%	DB	7.4	6.5	9.2	14.4	18.0	20.5	23.8	22.5	19.1	14.3	10.1	7.0
		MCWB	6.4	5.4	7.2	10.5	13.7	15.9	18.1	17.8	15.6	12.9	9.2	6.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.2	10.8	11.5	14.6	18.4	20.8	22.0	21.3	19.4	16.6	12.7	10.0
		MCDB	11.3	11.1	13.5	20.0	22.9	24.8	27.2	26.4	23.4	18.4	13.4	10.7
	2%	WB	8.7	8.6	10.0	13.1	16.5	19.3	20.8	19.9	18.1	15.1	11.2	8.4
		MCDB	9.4	9.6	11.4	17.2	19.9	23.4	25.8	24.2	21.4	16.5	12.2	9.2
	5%	WB	7.5	7.0	8.7	12.0	15.1	17.9	19.7	19.1	17.2	14.1	10.2	7.3
		MCDB	8.2	7.9	11.0	15.7	18.3	21.1	24.1	22.8	20.5	15.2	11.0	8.0
	10%	WB	6.5	5.6	7.3	10.9	13.9	16.5	18.7	18.4	16.1	13.1	9.3	6.2
		MCDB	7.4	6.4	9.1	14.0	17.1	19.5	22.6	21.6	18.8	14.1	10.0	6.8
Mean Daily Temperature Range	5% DB	MDBR	4.1	4.4	6.3	8.8	9.3	9.0	9.2	8.1	7.8	5.9	4.2	3.9
		MCDBR	4.3	5.1	9.4	12.9	12.6	12.2	13.2	11.2	11.0	7.0	4.5	4.5
		MCWBR	4.2	4.5	6.5	7.7	7.5	6.8	6.0	5.5	6.2	5.1	4.0	4.3
	5% WB	MCDBR	4.2	5.0	8.4	11.2	10.5	10.7	11.9	9.4	9.9	6.4	4.5	4.4
		MCWBR	4.2	4.5	6.3	7.1	6.9	6.7	6.2	5.2	6.0	5.0	4.2	4.3
Clear-Sky Solar Irradiance	taub	0.318	0.338	0.368	0.409	0.401	0.398	0.417	0.413	0.386	0.358	0.335	0.309	
	taud	2.313	2.325	2.269	2.202	2.289	2.325	2.289	2.314	2.373	2.418	2.368	2.307	
	Ebn at Noon	628	745	801	814	845	851	824	804	778	717	604	557	
	Edh at Noon	58	79	104	126	122	119	122	112	94	72	56	48	
All-Sky Solar Radiation	RadAvg	0.52	1.16	2.42	4.09	5.19	5.47	5.13	4.17	3.03	1.61	0.66	0.38	
	RadStd	0.07	0.18	0.23	0.51	0.59	0.39	0.64	0.30	0.32	0.20	0.08	0.03	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (57 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	-149	N/A	N/A

Nomenclature: See separate page